

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

10/18/2012

ADDENDUM # 1

To prospective Bidder(s) on **Bid # 31047** for ELECTRICAL CABLE, THREE CONDUCTOR, TRIPLEXED 5KV M 600V. QUANTITY 15,000 FEET

Due back on 11/6/2012, no later than 11:00AM

CLARIFICATIONS:

**THE CURRENT SPECIFICATION SHALL REMAIN STATING:
“COPPER TAPED CABLE/PVC JACKET”.**

**THE CURRENT SPECIFICATION SHALL REMAIN STATING:
“THE NEED FOR BINDING STRAPS”.**

**THE SUBJECT CABLE IS:
“ 3#500MCM 5000V RATED WITH 1#1/0 GROUNDING, 600V RATED”.**

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

LARRY WAXMAN
COMMODITIES AND SERVICES DIV.

BIDDER'S FIRM NAME: _____

INITIALED: _____ DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO LARRY WAXMAN, WHO CAN BE REACHED AT (201) 395-3451 or at Lwaxman@panynj.gov.

PS11A11