

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

12/4/2012

ADDENDUM # 1

To prospective Bidders for Bid # 31504 for Inspection and Testing Services of all FM-200 and Dry Chemical Fire Suppression Systems at LaGuardia Airport:

Due on 12/10/2012, no later than 11:00 AM

I. CHANGES/MODIFICATIONS

The following changes/modifications are hereby made to the solicitation documents:

- A. In Part V, Section 3, Periodic Testing and Inspection, Semi-Annually, item 7, page 5, at the end add the following:

“Chemical cylinders that have liquid level indicators do not have to be weighed. These cylinders are located in CTB Room 3587A, CTB Room 3910 and Aircraft Rescue and Fire Fighting Building 2nd Fl Computer Room.”

- B. In Part V, Section 3, Periodic Testing and Inspection, Annual, at the end add the following:

“13. Aircraft Rescue and Fire Fighting Facility Computer Room”

II. See attached “Attendance Sheet – Facility Inspection Meeting” dated December 3, 2012.

This communication should be initialed by you and annexed to your Bid upon submission. In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

KATHY LESLIE WHELAN, MANAGER
COMMODITIES & SERVICES DIVISION

BIDDER'S FIRM NAME: _____

INITIALED: _____ DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
MR. RICHARD A. GREHL AT (201) 395-3441 or rgrehl@panynj.gov.

Attendance Sheet - Facility Inspection Meeting

TITLE: RE-BID FOR INSPECTION AND TESTING SERVICES OF ALL FM-200 AND DRY CHEMICAL FIRE SUPPRESSION SYSTEMS AT LAGUARDIA AIRPORT

BID NO.: 31504

DATE: DECEMBER 3, 2012

LOCATION: LGA

TIME: 10:00 AM

	<u>NAME</u>	<u>COMPANY</u>	<u>CONTACT PHONE / E-MAIL</u>
1	JIM GOELI	METRO PROTECTION	212-947-4300 / JGOELLE@METROPROTECTION
2	RICH CAFFIERO	UNITED FIRE	908-688-0300 / RICHCAFFIERO@UNITEDFIRESYSTEMS.COM
3	RICH GRAHL	PA-PROCUREMENT	201-395-3441 / RGRAHL@PA.NY.NJ.GOV
4	Joe Elliott	PA LGACHIP	718-533-3564 / jelliott@pa.nj.gov
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			