

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

7/12/2013

ADDENDUM # 1

To prospective Bidder(s) on Bid # 33934 - Maintenance, Repair and Emergency Response Service for Uninterruptible Power Systems and Lighting Inverters at Newark Liberty International Airport

Due back on 7/18/2013, no later than 11:00AM

BIDDER'S QUESTIONS AND ANSWERS

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidders does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the foregoing information, and that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever.

The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

<i>Question #1</i>	Can you please provide the model of batteries that are listed on Exhibit C?
<i>Answer #1</i>	See attached list.

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

KATHY LESLIE WHELAN
ASSISTANT DIRECTOR
COMMODITIES & SERVICES DIVISION

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
EMILY BAXTER, WHO CAN BE REACHED AT (201) 395-3421 or at
ebaxter@panynj.gov.

EWR UPS

UPS LOCATIONS	UPS MANUFACTURER	Model	Unit Serial #	# of batteries	Batteries Currently In Unit
NEC West Platform	Controlled Power	ELE JYX - 18KW	ELE-0788	50	DEKA UNIGY 24HR3000S
NEC Airtrain Platform	Controlled Power	ELU JYX-7KW	ELU00757	20	POWER PRC1290S
Station P1	Controlled Power	EL5JJX-5000EL	EL00382	16	DEKA UNIGY 27HR3500S
Station P2	Controlled Power	EL5JJX-5000EL	EL00353	16	DEKA UNIGY 27HR3500S
Station P3	Controlled Power	EL5JJX-5000EL	EL00352	16	DEKA UNIGY 27HR3500S
Station P4	Controlled Power	EL5JJX-10KEL	EL-00121	30	POWER ARC12100S
BUILDING 1	CHLORIDE	EDP70L/125	B204288	40	DEKA UNIGY HR5500
BUILDING 1	TOSHIBA G-9000 100 kva	G-9000 100 kva	T90S3S10K6XSN	40	POWER TC12120S
Terminal B B2 Satellite	Dual Lite		LDLZOK3455	8	HUBBELL 93012368
Terminal B B2 Satellite	Dual Lite		LDLZOK3456	8	HUBBELL 93012368