

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

10/3/2013

ADDENDUM # 1

To prospective Bidder(s) on Bid # 34966 RUNWAY LIGHTING FIXTURES AND PARTS FOR NEWARK LIBERTY INTERNATIONAL AIRPORT PER SPECIFICATIONS

Due back on 10/17/2013, no later than 11:00 AM

I. CHANGES/MODIFICATIONS

The following changes/modifications are hereby made to the solicitation documents:

SEE ANSWERS TO BIDDERS QUESTIONS WHICH SHALL BECOME PART OF THE SPECIFICATIONS.

II. BIDDER'S QUESTIONS AND ANSWERS

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidder does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the foregoing information, and that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of

the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever.

The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

Question # 1	<i>Item #7, in the description, there are 3 adders (i,ii, iii) but for all the other bases, there are adders (i,ii,iii,iv,v,vi, vii) I would assume #7 should also have all the adders? yes /no</i>
Answer # 1	No; a mid-ring is not required. The other adders should be: -iv.) Provide a bottom wall thickness of .25" -v.) Provide epoxy hooks on the exterior bottom of the base can. -vi.) Grommet openings
Question # 2	<i>Item #29, is a conflict in description "Class 1B - Galvanized extension collars" you cannot have 1B equipment that are only galvanized.</i>
Answer # 2	Class 1B – stainless steel
Question # 3	<i>Item #5) L867D junction boxes What are the specifics on these bases? height?, conduit size? number/location of conduit openings drain holes? ground straps? copper lugs?</i>
Answer # 3	-i.) One piece, 24" high -ii.) Bolted connection ground lug and ground strap on the interior wall of the base can. Exterior wall to include ground strap. -iii.) Provide 1-1/4" diameter offset -iv.) Provide epoxy hooks on the exterior bottom of the base can. -v.) 4 – grommet openings -vi.) Provide 3/4" thick cover plate
Question # 4	<i>Items #1,2,3,4) Are these items suppose to be L867D ? to match #5?</i>
Answer # 4	No, items # 1 thru 4 are for L-867B.

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

KATHY LESLIE WHELAN
COMMODITIES & SERVICES DIVISION

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
LARRY WAXMAN, WHO CAN BE REACHED AT (201) 395-3951 or at
Lwaxman@panynj.gov.