

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

10/9/2013

ADDENDUM #1

To prospective Bidder(s) on Bid #34975 - Self-Filling Modular Flood Barriers and Multi-Hubs

Due back on 10/18/2013, no later than 11:00AM

I. CHANGES TO BID DOCUMENTS

The following changes are hereby made to the bid documents:

- On Pages 2 and 3, delete these specifications in their entirety:

“AS1100600

Self Filling Modular Barrier. Medium density polyethylene foam gasketed bottoms, made from EPDM or PVC / Nitrite modular flood barrier. Connecting keys are included, made from Recycled PVC and Concrete with MDPE Shell. Equipped with Connecting Key Handle. Dimensions are: 39.4" in length X 19.7" in width X 35.4" in height.”

and:

“AS1100610

Multi-Hubs used in conjunction with Modular barriers to make 60 or 90 degree corners, to fit tightly against any perpendicular structure.

Note:

These barriers must be:

1. able to stop water up to 24" high.
2. easily assembled and stored by one person in a minimum amount of time.
3. able to utilize water as fill
4. modular and capable of being assembled to allow immediate 90-degree turns.”

and replace the above with:

“Supply and deliver Water Filled Flood Barriers totaling a minimum of 1,130 feet in length.

These barriers must:

- be able to stop water up to 24" high;
- be able to utilize water as fill;
- have standard, interchangeable modules able to be used at any location;
- have alternating modules be self-filling and self-draining;

PS11All

- have connecting sections capable of providing different degrees of curvature up to 90 degrees and the ability to connect modules into various combinations of lengths;
 - be easily assembled, disassembled, and stored by one person in a minimum amount of time.”
-
- For Stock No. AS1100600, in the “Quantity” column, delete the phrase “344 EA” in its entirety.
 - For Stock No. AS1100610, in the “Quantity” column, delete the phrase “32 EA” in its entirety.

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

KATHY LESLIE WHELAN
ASSISTANT DIRECTOR
COMMODITIES AND SERVICES DIVISION

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO MARGARET D'EMIC,
WHO CAN BE REACHED AT (201) 395-3410 or at mdemic@panynj.gov.