

THE PORT AUTHORITY OF NY & NJ
PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, THIRD FLOOR
JERSEY CITY, NJ 07302

Date: 4/28/2014

ADDENDUM #1

To prospective bidders on Bid # 37634 Furnish, deliver and install (1) one Environmental Test Chamber and Room (Controlled Temperature, Humidity, etc.).

Due back on May 15, 2014, no later than 11:00AM

I. CHANGES/MODIFICATIONS

Bidders attention is called to page 1 of 5, REQUEST FOR QUOTATION under the word “Description”, delete in its entirety the first five (5) lines as originally stated and replace it with the following:

Furnish, deliver and install (1) one Concrete Curing Room, as described below including the removal of the existing insulated chamber originally installed by Environmental Growth Chambers approximately thirty (30) years ago.

II. BIDDER'S QUESTIONS AND ANSWERS

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidder does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its bid, expressly agrees that it has not relied upon the foregoing information, and that it shall not hold the Port Authority liable or responsible therefore in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers,

PS11A11

agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever.

The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

| | |
|--------------------|---|
| Question #1 | Can you please tell me the temperature and humidity set-points/range? |
| Answer #1 | There are no requirements for temperature /humidity control to the bidders. Port Authority will re-install its equipment from the existing room. However, for information purposes only, the system operates at 73F and 100% humidity. |

This communication should be initialed by you and annexed to your bid upon submission.

In case any bidder fails to conform to these instructions, its bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

Kathy Leslie-Whelan, Assistant Director
Commodities and Services Assignments

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO Dinesh Chheda, WHO CAN BE REACHED AT (201) 395-3432 or at dchheda@panynj.gov.