

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

10/16/2014

ADDENDUM # 1

To prospective Bidder(s) on Bid # 39793 Electrical Cable for PATH, Low Voltage 480,
Furnish and Deliver

Due back on 10/21/2014, no later than 11:00AM

**1. CHANGES/MODIFICATIONS TO THE TITLE AND THE SPECIFICATIONS
STATED IN THE ABOVE REFERENCED REQUEST FOR QUOTATION.**

**YOUR ATTENTION IS CALLED TO PAGE 1 OF 6 THE “REQUEST FOR
QUOTATION” FORM, DESCRIPTION, THE FIFTH LINE, AFTER THE
WORDS “NOTE: PATH WILL COLOR CODE THE CABLE.**

**INSERT: The subject cable should be twisted / combined together as its is
being pulled together in a duct bank system.**

This communication should be initialed by you and annexed to your Bid upon
submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be
construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

KATHY LESLIE WHELAN
COMMODITIES AND SERVICES DIV
PROCUREMENT DEPARTMENT

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
LARRY WAXMAN, WHO CAN BE REACHED AT (201) 395-3451 or at
Lwaxman@panynj.gov.