

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

11/5/2014

ADDENDUM #1

To prospective Bidder(s) on Bid # 40250 - Overhaul Of PATH's 1460 DC Traction Motors

Due back on 11/18/2014 no later than 11:00 A.M.

I. CHANGES TO BID DOCUMENTS

The following changes/modifications are hereby made to the solicitation documents:

- **The Facility Inspection date has been changed from 11/6/14 to 11/12/14 at 10:00 A.M.**

II. BIDDERS' QUESTIONS AND ANSWERS

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidders does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms of this Bid.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the foregoing information, and that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever.

The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

PS11All

Question #1	Can we see the previous results of a similar Bid Solicitation including pricing from all the participants?
Answer #1	This information is not available.
Question #2	Can you supply drawings of the traction motor armature and field coils used in the stator frame?
Answer #2	Drawings are not available.

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

KATHY LESLIE WHELAN
 ASSISTANT DIRECTOR
 COMMODITIES AND SERVICES DIVISION

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO MARGARET D'EMIC, WHO CAN BE REACHED AT (201) 395-3410 or at mdemic@panynj.gov.