

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

12/17/2014

ADDENDUM # 1

To prospective Bidder(s) on Bid # 40722 UPS BATTERIES FOR GALAXY 3000 UPS SYSTEM: REMOVE AND DISPOSAL OF EXISTING BATTERIES AND FURNISH, DELIVER AND INSTALL REPLACEMENT BATTERIES AT PATH, JERSEY CITY, NJ.07306

Due back on 12/29/2014, no later than 11:00 AM

**REQUEST FOR QUOTATION (RFQ) CHANGES/MODIFICATIONS
BIDDER(S) ATTENTION IS CALLED TO PAGE 5 OF 6 OF THE RFQ DOCUMENT
(THIS PAGE IS CURRENTLY BLANK) AND INSERT THE FOLLOWING:**

- 1) The Galaxy 300 unit (SN: A09-102965) is 30 KVA.
- 2) The battery cabinet is Model # U4C1UF55XV2401B10010A01BP, Serial # is 99029754.
- 3) The installation of the UPS batteries shall be done by Electricians that are licensed by the State of New Jersey with an Electrical license(s).
- 4) The subject battery is type is DEKAHR5500ET that are 12V batteries.
- 5) Proof of disposal at a certified landfill is required.
- 6) The vendor awarded the subject BID is responsible that the batteries are installed correctly into the UPS system.
- 7) The make and model of UPS –MGE Galaxy 300 -30KVA UPS
- 8) A loading dock is available at the subject site during the times specified in the RFQ.
- 9) The vendor can ship directly to the site, but is responsible for off loading and placement of all equipment / material to the 11th floor location at the same time of said delivery. PATH SHALL NOT BE RESPONSIBLE FOR RECEIVING / MOVING / STORING ANY EQUIPMENT / MATERIAL.
- 10) The vendor, either on the first of second consecutive day can load on its truck the recycle old product.
- 11) On-site parking at no charge for one (1) vehicle will be made available to the vendor during the work times stated in the RFQ.
- 12) The vendor is responsible for moving all subject equipment and materials including its own equipment and materials under the subject requirement.
- 13) Distance is not a significant factor between the freight elevator and UPS location.
- 14) There may be ramps and or steps for access to the UPS and batteries to and from delivery and to and from installation.
- 15) Photo of subject item is not available.

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ
KATHY LESLIE WHELAN
ASSISTANT DIRECTOR
COMMODITIES AND SERVICES DIVISION

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO LARRY WAXMAN, WHO CAN BE REACHED AT (201) 395-3951 or at Lwaxman@panynj.gov.
ADDENDUM #1, #40722.