

**THE PORT AUTHORITY OF NY & NJ
PROCUREMENT DEPARTMENT
4 WORLD TRADE CENTER (4 WTC)
150 GREENWICH STREET, 21ST FLOOR
NEW YORK, NY 10007**

4/21/2015

ADDENDUM #1

To prospective bidders on Bid # 42023 for Electrical Cable Three Types: 500 MCM-5KV Triplexed, and 350MCM-5KV Triplexed, and 2/0-4AWG to be Furnished and Delivered on Non-Returnable Steel Reels per Port Authority Cable Specifications

Due back on April 28, 2015, no later than 11:00AM

CHANGES/MODIFICATIONS

The following changes/modifications are hereby made to the solicitation document:

REQUEST FOR QUOTATION (RFQ) Page 6 of 8. Item “CS0100011”, after the words ‘COMPACT ROUND COPPER’

Insert: triplexed 2/0 5KV conductors with a #4 insulated ground”.

<i>Question #1</i>	clarification on item 3 on this RFQ. They are interpreting the requirement as triplexed 2/0 5KV conductors with a #4 insulated ground
<i>Answer #1</i>	Yes, this cable is a triplexed 2/0 5KV conductors with a #4 insulated ground. See the above in CHANGES/MODIFICATIONS.

This communication should be initialed by you and annexed to your bid upon submission. In case any bidder fails to conform to these instructions, its bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

KATHY LESLIE WHELAN
ASSISTANT DIRECTOR
COMMODITIES & SERVICES DIVISION
PROCUREMENT DEPARTMENT

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO Larry Waxman, WHO CAN BE REACHED AT (212) 435-4639 or at lwaxman@panynj.gov.

PS11All