

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
4 WORLD TRADE CENTER
150 GREENWICH STREET, 21ST FL.
NEW YORK, NY 10007**

4/14/2016

ADDENDUM # 2

To prospective Bidder(s) on Bid # 45647 for Air Filter Services for Heating, Ventilation, and Air Conditioning (HVAC) Systems at the Port Authority Bus Terminal (PABT)

Now Due back on 4/18/2016, no later than 11:00 AM

Original due on 4/14/2016, no later than 11:00AM

I. CHANGES/MODIFICATIONS

The following changes/modifications are hereby made to the solicitation documents:

- A. The bid due date has been EXTENDED until April 18, 2016, no later than 11:00 AM.
- B. Addendum #1, delete items C, D and E on pages 2 of 4 and 3 of 4 in their entirety and replace with the following:

In Part IV, Exhibit A – Pre Pleated Filters and Cell Filters Pricing Sheet delete sentence #1, #2 and #3 under Notes: and replace it with:

- 1. All filters shall be UL 900 Class Rating. Pre-filters 2” thick, merv8/30% or Port Authority approved equal. Cell filters shall be a minimum of MERV 14.
- 2. Cell filters 12” thick merv14/90-95% or Port Authority or approved equal.
- 3. All carbon filters shall be 2” thick, charcoal 75% Viledon, carbopleat or Port Authority approved equal (are not Class 1 due to its carbon content).

In Part IV, Exhibit B – Roll Filters Pricing Sheets delete sentence #1 #2 and #3 under Notes: and replace it with:

- 1. All filters shall be UL 900 Class Rating. .
- 2. Cell filters 12” thick merv14/90-95% or Port Authority or approved equal.
- 3. All carbon filters shall be 2” thick, charcoal 75% Viledon, carbopleat or Port Authority approved equal (are not Class 1 due to its carbon content).

PS11All

In Part IV, Exhibit C – Pleated Filters Pricing Sheets delete sentence #1, #2 and #3 under Notes: and replace it with:

1. All filters shall be UL 900 Class Rating. Pre-filters 2” thick, merv8/30% or Port Authority approved equal.
2. Cell filters 12” thick merv14/90-95% or Port Authority or approved equal.
3. All carbon filters shall be 2” thick, charcoal 75% Viledon, carbopleat or Port Authority approved equal (are not Class 1 due to its carbon content).

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

SELENE ORTEGA, MANAGER
COMMODITIES AND SERVICES
PROCUREMENT DEPARTMENT

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
LUZ SANTANA, WHO CAN BE REACHED AT (212) 435 -4625 OR AT
LSANTANA@PANYNJ.GOV.