

**THE PORT AUTHORITY OF NEW YORK AND NEW JERSEY
TWO MONTGOMERY STREET - 1st FLOOR
JERSEY CITY, NJ 07302**

October 10, 2017

ADDENDUM NO. 3

TO PROSPECTIVE BIDDERS ON CONTRACT **JFK-154.021** – JOHN F. KENNEDY INTERNATIONAL AIRPORT – AIRSIDE SWITCHGEAR REPLACEMENT

The following changes are hereby made in the Contract Documents for the subject Contract.

This communication should be physically annexed to back cover of the book and initialed by each bidder before submitting his bid.

In case any bidder fails to conform to these instructions, his Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

REVISED CONTRACT DRAWINGS

Drawings G002, E202, E203 and E207 have been revised as of 10/05/17. Copies of these drawings are forwarded herewith on CD. Destroy the drawings of these numbers now in your possession and substitute therefor the revised drawings.

CHANGES TO THE CONTRACT DRAWINGS

Dwg. G003 Underneath GENERAL NOTE 25, insert the following:

"26. DO NOT PERFORM WORK ON MORE THAN ONE SITE AT A TIME."

Dwg. C001 Make the following changes in the LEGEND under the column entitled "DESCRIPTION":

- A. In the first row, immediately after "FLEXIBLE GROWTH MEDIUM.", insert "THE HAUNCH SHALL BE 3 FEET."
- B. In the second row, delete "CHAIN LINK FENCE (SEE CIVIL NOTE 7 ON THIS DRAWING)" and substitute therefor "CHAIN LINK FENCE (SEE CIVIL NOTE 5 ON THIS DRAWING)".

Dwg. E302 Underneath Note 2, insert the following:

"3. THE CONCRETE SHALL BE 3000 PSI, HIGH EARLY STRENGTH CONCRETE."

THE PORT AUTHORITY OF NEW YORK AND NEW JERSEY

James Starace, P.E.
Chief Engineer/Director

INITIALED BY THE BIDDER:
