

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

10/22/2013

ADDENDUM # 4

To prospective Bidder(s) on Bid # 34966 RUNWAY LIGHTING FIXTURES AND PARTS FOR NEWARK LIBERTY INTERNATIONAL AIRPORT PER SPECIFICATIONS

Now Due back on 11/12/2013, no later than 11:00 A.M.

(Originally due on 10/17/2013, no later than 11:00 A.M.)

I. CHANGES/MODIFICATIONS

The following changes/modifications are hereby made to the solicitation documents:

NOTE: THE NEW BID DATE IS NOW 11/12/2013 no later than 11:00 A.M.

SEE ANSWERS TO BIDDERS QUESTIONS WHICH SHALL BECOME PART OF THE SPECIFICATIONS.

II. BIDDER'S QUESTIONS AND ANSWERS

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidder does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the foregoing information, and that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. Accordingly, nothing contained herein and no

representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

Question #8	<i>What is a 3/4" cover with alignment rings ? This "alignment ring" is what?</i>
Answer # 8	<i>Alignment ring is a 3/4" thick by 12" diameter load bearing blank cover for an L-868 light base /Alignment rings are raised circular protrusion on the cover to aid in the alignment of the coring process.</i>
Question #9	<i>The specification calls out an aviation yellow painted cover. Perhaps its part number C-08 but changed to PA size requirement at 3/4 inch.</i>
Answer #9	<i>The C-08 is not the cover this item is referring to. This item should be Jacquith Industries (or approved equal manufacturer) C-10f Mud Plate for L-867 & L-868 No. AK4001120. (or approved equal part number).</i>

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

KATHY LESLIE WHELAN
ASSISTANT DIRECTOR
COMMODITIES & SERVICES DIVISION

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO LARRY WAXMAN, WHO CAN BE REACHED AT (201) 395-3951 or at Lwaxman@panynj.gov.