

THE PORT AUTHORITY OF NY & NJ

PROCUREMENT DEPARTMENT
4 WORLD TRADE CENTER
150 GREENWICH STREET, 21ST FLOOR
NEW YORK, NY 10007

12/1/2016

ADDENDUM # 4

To prospective Bidder(s) on Bid # 47544: Remove Outside Air Supply Fan Motor and Install Port Authority Supplied Spare Fan Motor at the Port Authority Bus Terminal.

Now Due back on 12/7/2016, no later than 11:00 AM

I. CHANGES/MODIFICATIONS

The following changes/modifications are hereby made to the solicitation documents:

- a.) The Bid due date is hereby extended to 12/7/2016, no later than 11:00 AM
- b.) **Page 4 of 6 Section entitled “OUTSIDE AIR SUPPLY FAN #3 REPLACEMENT”**, page 4 of 6, add the following after the last sentence in #4, “The Contractor may use the existing steel framing for rigging purposes, with loads not to exceed 1,900 lbs. “The Contractor must submit the rigging layout and details for review and approval prior to commencement of work. During the lifting operations, the Contract must ensure that the 7th floor above remains free of live loading. In addition, fireproofing material shall be restored to match existing in accordance with recommendations by the Facility Manager.”

II. BIDDER'S QUESTIONS AND ANSWERS

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidders does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the foregoing information, and that it shall

PS11All

not hold the Port Authority liable or responsible therefore in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefore in any manner whatsoever.

The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

<i>Question #1</i>	Can we utilize overhead beams for rigging purposes, and if so, if any insulation flakes off, can we spray with generic insulator?
<i>Answer #1</i>	See Changes/Modifications in b) above.
<i>Question #2</i>	Can you please verify the name of the Fan Manufacturer?
<i>Answer #2</i>	The manufacturer is Howden American Fan Company.
<i>Question #3</i>	Is the fan floor mounted on an angle stand, or hung from slab above?
<i>Answer #3</i>	The fan is mounted inside an enclosure which is floor mounted.
<i>Question #4</i>	Are there any pictures available?
<i>Answer #4</i>	No.

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ
 SELENE ORTEGA, MANAGER
 COMMODITIES AND SERVICES DIVISION
 PROCUREMENT DEPARTMENT

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO STEVEN JOSEPH, WHO CAN BE REACHED AT (212) 435-4658 or at stjoseph@panynj.gov.