

**THE PORT AUTHORITY OF NEW YORK AND NEW JERSEY
TWO MONTGOMERY STREET - 1st FLOOR
JERSEY CITY, NJ 07302**

May 18, 2017

ADDENDUM NO. 4

TO PROSPECTIVE BIDDERS ON CONTRACT JFK-154.019 – JOHN F. KENNEDY INTERNATIONAL AIRPORT – INSTALLATION OF GATE / CHECK VALVES FOR EXISTING STORMWATER SYSTEMS (OUTFALLS 2, 3, 4, 5 & 6)

The following changes are hereby made in the Contract Documents for the subject Contract.

This communication should be physically annexed to back cover of the book and initialled by each bidder before submitting his bid.

In case any bidder fails to conform to these instructions, his Bid will nevertheless be construed as though this communication had been so physically annexed and initialled.

CHANGES IN THE CONTRACT BOOKLET

Page 264- Immediately after 2.02 B. 1., insert the following.

"C. Contractor shall provide pumping capacities based on the following peak flow conditions for each Work Area:

Outfall 4: 0.50 cubic feet per second (This flow is pumped from a groundwater treatment holding tank to outfall 4, so the flow is not constant. This flowrate does not include flows related to a storm event. The Contractor shall remove the plug in the pipe and not perform Work during a storm event.)."

REVISED CONTRACT DRAWINGS

Drawings G103, C204, C602, C605, S101, S204 and S301 have been revised as of 5/10/17. Copies of these drawings are forwarded herewith on CD. Destroy the drawings of these numbers now in your possession and substitute therefor the revised drawings.

THE PORT AUTHORITY OF NEW YORK AND NEW JERSEY

James Starace, P.E.
Chief Engineer/Director

INITIALLED BY THE BIDDER:
