



### REQUEST FOR QUOTATION

Vendor No.

Collective#

Bid Due Date

0000031047

11/06/2012

Bids must be received no later than 11:00 AM on the above Bid Due Date.

Contact person/Telephone

Larry Waxman/201-395-3451

Deliver Goods/Services To:

Laguardia Airport

Bldg 2B Hangar 7 - Stockroom

Jackson Heights NY 11371

Quantity	Description	Unit Price		Total	
	<p>ELECTRICAL CABLE THREE CONDUCTOR, TRIPLEXED, 5KV M 600V PER PORT AUTHORITY SPECIFICATIONS.</p> <p>ALL BIDDERS SHALL INDICATE WITH ITS BID RESPONSE THE FOLLOWING INFORMATION:</p> <p>MANUFACTURER NAME: _____            MFGR. PLANT LOCATION: _____            MANUFACTURER PART NUMBER: _____</p> <p>DRAWING AND SPECIFICATIONS SUBMITTAL SHALL BE REQUIRED WITHIN THREE (3) BUSINESS DAYS FROM NOTICE BY THE PROCUREMENT DEPARTMENT FOR REVIEW AND APPROVAL.</p> <p>ITEM A)            QUANTITY 15,000 FEET ELECTRICAL CABLE. TIMES \$ _____ PER FOOT EQUALS \$ _____.</p> <p>ITEM B) LUMP SUM PRICE FOR NON-RETURNABLE WOOD REELS            LUMP SUM PRICE FOR FIFTEEN (15) REELS EQUALS \$ _____.</p> <p>ITEM C)            FOB DELIVERED TOTAL BID AMOUNT \$ _____.</p>				
	<p><b>PLEASE QUOTE FULLY DELIVERED PRICES</b></p>	<p><b>PAYMENT TERMS</b></p>	<p><b>Total Delivered Price</b></p>		

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_

Firm Name \_\_\_\_\_

Telephone number \_\_\_\_\_ Date \_\_\_\_\_

Fax Number \_\_\_\_\_

Federal Taxpayer ID \_\_\_\_\_

Bidder  
Must  
Sign  
In  
Two  
Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_

Firm Name \_\_\_\_\_



## REQUEST FOR QUOTATION

Bid Due Date  
 11/06/2012

Quantity	Description	Unit Price	Total
	A PLUS B = C)  ===== ===== ESTIMATED LENGTHS /REEL R1= 970 FT R2= 1014 FT R3= 983 FT R4= 835 FT R5= 810 FT R6= 956 FT R7= 1064 FT R8= 905 FT R9= 905 FT R10= 759 FT R11= 998 FT R12= 1019 FT R13= 828 FT R14= 1133 FT R15= 1821 FT END.		
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>

**This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.**

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

**NOTICE TO BIDDERS:** Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_  
 Firm Name \_\_\_\_\_  
 Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
 Fax Number \_\_\_\_\_  
 Federal Taxpayer ID \_\_\_\_\_

**Bidder  
 Must  
 Sign  
 In  
 Two  
 Places**

Signed \_\_\_\_\_ Date \_\_\_\_\_  
 Firm Name \_\_\_\_\_



## REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price	Total
	<p>This is a Formal Bid Invitation Mail Sealed Bids to:</p> <p>The Port Authority of NY &amp; NJ Attn: Bid Custodian Procurement Department 2 Montgomery Street, 3rd Floor Jersey City, NJ 07302</p> <p>by the date and time listed above, where it will be publicly opened and read.</p> <p>Bids are only accepted Monday through Friday, excluding Port Authority holidays, between the hours of 8 A.M. &amp; 5 P.M., via regular mail, express delivery service or hand delivery.</p> <p>If you do not use or have an envelope provided, you must clearly mark the outside envelope/package with 'BID ENCLOSED' and show the company name, address, as well as Bid number and Due date as stated on this bid document.</p> <p>A valid photo id is required to gain access into the building, to attend the bid opening or hand deliver a bid.</p>		
15,000 FT	CS0100018		
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>

**This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.**

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
Firm Name \_\_\_\_\_  
Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
Fax Number \_\_\_\_\_  
Federal Taxpayer ID \_\_\_\_\_

**Bidder  
Must  
Sign  
In  
Two  
Places**

**NOTICE TO BIDDERS:** Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
Firm Name \_\_\_\_\_



### REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price		Total	
	<p>CABLE, THREE CONDUCTOR, TRIPLEXED, 5KV MEDIUM VOLTAGE, COPPER COMPACT CLASS B STRAND. TYPE MV-105, 500KCMIL 5KV AND 1/0 AWG 600V GROUND, EPR, 133% INSULATION LEVEL, /COPPER TAPE SHIELD/PVC. CABLE MUST BE DELIVERED ON NON-RETURNABLE WOOD REELS. LENGTH OF EACH REEL TO BE SPECIFIED AT TIME OF ORDER. TOLLERENCE: MINUS ZERO / PLUS 5% PER REEL / TOTAL RUN.</p> <p>1.01 DESIGN AND PERFORMANCE REQUIREMENTS  A. WIRES AND CABLES FOR MEDIUM VOLTAGE, 5000 VOLTS, SHALL BE FURNISHED IN ACCORDANCE WITH THIS SECTION.  B. COMPONENTS OF THE MEDIUM VOLTAGE SYSTEM MANUFACTURED AND SUPPLIED, SHALL COMPLY WITH THE REQUIREMENTS OF NFPA 70, ALL LOCAL CODES AND THE REQUIREMENTS OF OSHA.</p> <p>1.02 REFERENCES  A. NETA ATS: ACCEPTANCE TESTING SPECIFICATION.  B. ASTM INTERNATIONAL (ASTM)  1. B1 - STANDARD SPECIFICATION FOR HARD-DRAWN COPPER WIRE  2. B2 - STANDARD SPECIFICATION FOR MEDIUM-HARD-DRAWN COPPER WIRE  3. B3 - STANDARD SPECIFICATION FOR SOFT OR ANNEALED COPPER WIRE</p>				
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>		

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
Firm Name \_\_\_\_\_  
Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
Fax Number \_\_\_\_\_  
Federal Taxpayer ID \_\_\_\_\_

Bidder  
Must  
Sign  
In  
Two  
Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
Firm Name \_\_\_\_\_



### REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price		Total	
	4. B8 - STANDARD SPECIFICATION FOR CONCENTRIC-LAY-STRANDED COPPER CONDUCTORS, HARD, MEDIUM-HARD, OR SOFT 5. B33 - STANDARD SPECIFICATION FOR TINNED SOFT OR ANNEALED COPPER WIRE FOR ELECTRICAL PURPOSES 6. B272 - STANDARD SPECIFICATION FOR COPPER FLAT PRODUCTS WITH FINISHED (ROLLED OR DRAWN) EDGES (FLAT WIRE AND STRIP) 7. B496 - STANDARD SPECIFICATION FOR COMPACT ROUND CONCENTRIC-LAY-STRANDED COPPER CONDUCTORS 8. D1248 - STANDARD SPECIFICATION FOR POLYETHYLENE PLASTICS EXTRUSION MATERIALS FOR WIRE AND CABLE 9. D2802 - STANDARD SPECIFICATION FOR OZONE-RESISTANT ETHYLENE-ALKENE POLYMER INSULATION FOR WIRE AND CABLE 16121-MEDIUM VOLTAGE (5KV) C 06/15/12 16121C - 2 10. D3005 - STANDARD SPECIFICATION FOR LOW-TEMPERATURE RESISTANT VINYL CHLORIDE PLASTIC PRESSURE-SENSITIVE ELECTRICAL INSULATING TAPE 11. D4388 - STANDARD SPECIFICATION FOR NONMETALLIC SEMI-CONDUCTING AND ELECTRICALLY INSULATING RUBBER TAPES C. ASSOCIATION OF EDISON ILLUMINATING COMPANIES				
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>		

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
 Firm Name \_\_\_\_\_  
 Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
 Fax Number \_\_\_\_\_  
 Federal Taxpayer ID \_\_\_\_\_

Bidder  
 Must  
 Sign  
 In  
 Two  
 Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
 Firm Name \_\_\_\_\_



### REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price		Total	
	(AEIC) 1. CS8 - SPECIFICATION FOR EXTRUDED DIELECTRIC SHIELDED POWER CABLES RATED 5 THROUGH 46 KV D. PORT AUTHORITY OF NEW YORK AND NEW JERSEY (PANYNJ) 1. EO-17 - PURCHASE AND TEST SPECIFICATION FOR ETHYLENE PROPYLENE RUBBER (EPR)INSULATED CABLES 5 TO 35 KV E. INSULATED CABLE ENGINEERS ASSOCIATION (ICEA) 1. S-97-682 - UTILITY SHIELDED POWER CABLES RATED 5 THROUGH 46 KV F. INTERNATIONAL ORGANIZATION FOR STANDARDIZATION (ISO) 1. 9001 - QUALITY MANAGEMENT SYSTEMS - REQUIREMENTS G. INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE) 1. 48 - STANDARD TEST PROCEDURES AND REQUIREMENTS FOR ALTERNATING-CURRENT CABLE TERMINATIONS 2.5 KV THROUGH 765 KV 2. 383 - STANDARD FOR QUALIFYING CLASS 1E ELECTRIC CABLES AND FIELD SPLICES FOR NUCLEAR POWER GENERATING STATIONS 3. 404 - STANDARD FOR TYPE TEST OF CABLE JOINTS FOR USE WITH EXTRUDED DIELECTRIC CABLE RATED 5,000 THROUGH 46,000 VOLTS, AND CABLE JOINTS FOR USE WITH LAMINATED DIELECTRIC CABLE RATED 2,500 THROUGH 500,000 VOLTS				
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>		

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
 Firm Name \_\_\_\_\_  
 Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
 Fax Number \_\_\_\_\_  
 Federal Taxpayer ID \_\_\_\_\_

Bidder Must Sign In Two Places
---

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
 Firm Name \_\_\_\_\_



### REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price	Total
	4. 837 - IEEE STANDARD FOR QUALIFYING PERMANENT CONNECTIONS USED IN SUBSTATION GROUNDING H. NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) 1. 70 - NATIONAL ELECTRICAL CODE 2. 258 - RESEARCH METHOD FOR DETERMINING SMOKE GENERATION OF SOLID MATERIALS 3. 502 - STANDARD FOR ROAD TUNNELS, BRIDGES, AND OTHER LIMITED ACCESS HIGHWAYS I. NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA) 1. WC74 - 5-46 KV SHIELDED POWER CABLE FOR USE IN THE TRANSMISSION AND DISTRIBUTION OF ELECTRIC ENERGY J. OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA) K. UNDERWRITERS LABORATORIES INC. (UL) 1. 44 - THERMOSET-INSULATED WIRES AND CABLES 16121-MEDIUM VOLTAGE (5KV) C 06/15/12 16121C - 3 2. 467 - STANDARD FOR GROUNDING AND BONDING EQUIPMENT 3. 510 - STANDARD FOR POLYVINYL CHLORIDE, POLYETHYLENE AND RUBBER INSULATING TAPE 4. 1072 - MEDIUM VOLTAGE POWER CABLE 5. 1581 - REFERENCE STANDARD FOR ELECTRICAL WIRES, CABLES, AND FLEXIBLE CORDS  1.03 QUALITY ASSURANCE		
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
 Firm Name \_\_\_\_\_  
 Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
 Fax Number \_\_\_\_\_  
 Federal Taxpayer ID \_\_\_\_\_

Bidder  
 Must  
 Sign  
 In  
 Two  
 Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
 Firm Name \_\_\_\_\_



## REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price	Total
	<p>A. WIRES AND CABLES THAT HAVE BEEN MANUFACTURED MORE THAN ONE YEAR PRIOR TO DELIVERY SHALL NOT BE ACCEPTABLE.</p> <p>B. THE CABLE MANUFACTURER SHALL BE ISO 9001/Q9001 CERTIFIED FOR A QUALITY SYSTEM FOR WIRE AND CABLE MANUFACTURING.</p> <p>C. SOURCE LIMITATIONS: OBTAIN CABLES AND ACCESSORIES THROUGH ONE SOURCE FROM A SINGLE MANUFACTURER.</p> <p>D. ALL WIRES AND CABLES SHALL BE LISTED AND LABELED AS DEFINED IN NFPA 70, ARTICLE 100, BY A TESTING AGENCY ACCEPTABLE TO AUTHORITIES HAVING JURISDICTION, AND MARKED FOR INTENDED USE. ACCEPTABLE TESTING AGENCY SHALL BE UL.</p> <p>1.04 SUBMITTALS</p> <p>A. PROOF OF WIRE OR CABLE MANUFACTURER ISO 9001/Q9001 CERTIFICATION</p> <p>B. CATALOG CUTS</p> <p>1. MEDIUM VOLTAGE CABLE(S)</p> <p>2. GROUND WIRE(S)</p> <p>C. SUBMIT CERTIFIED SHOP TEST REPORTS FOR WIRES AND CABLES. REPORTS SHALL CONTAIN THE FOLLOWING AT A MINIMUM:</p> <p>1. AC WITHSTAND TEST, IN ACCORDANCE WITH NETA ATS.</p> <p>2. PARTIAL DISCHARGE TEST, IN ACCORDANCE WITH NETA ATS.</p>		
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>

**This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.**

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
 Firm Name \_\_\_\_\_  
 Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
 Fax Number \_\_\_\_\_  
 Federal Taxpayer ID \_\_\_\_\_

Bidder  
Must  
Sign  
In  
Two  
Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
 Firm Name \_\_\_\_\_



### REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price		Total	
	3. CONDUCTOR RESISTANCE TEST, IN ACCORDANCE WITH NETA ATS. 4. INSULATION RESISTANCE TEST, IN ACCORDANCE WITH NETA ATS. 5. DIMENSIONAL MEASUREMENTS INCLUDING CABLE LENGTHS AND CABLE DIAMETERS. FOR TRIPLEX CABLE PROVIDE INDIVIDUAL WIRE DIAMETERS AND OVERALL CABLE DIAMETER. D. SUBMIT SHOP DRAWINGS SHOWING 1. COMPLETE (TRIPLEX) ASSEMBLY 2. PULLING EYE LOOP AND END CAPS TO BE USED. E. SUBMIT MATERIAL CERTIFICATION SHEETS (MILL CERTIFICATION) SHOWING THE CHEMICAL AND PHYSICAL PROPERTIES OF THE MATERIALS USED IN THE MANUFACTURE OF THE WIRES AND CABLES. 16121-MEDIUM VOLTAGE (5KV) C 06/15/12 16121C - 4  1.05 DELIVERY, STORAGE AND HANDLING A. WHERE MULTIPLE SINGLE CONDUCTOR CABLES ARE TO BE INSTALLED AS ONE CABLE, CABLE MANUFACTURER SHALL MULTIPLEX SINGLE CONDUCTOR CABLES PRIOR TO SHIPMENT. CABLE ASSEMBLY OVERALL DIAMETER SHALL BE KEPT TO A MAXIMUM OF 2.90". B. STORE MATERIAL IN A CLEAN, DRY SPACE AND PROTECT IT FROM THE WEATHER. C. THE VENDOR, AFTER PORT AUTHORITY APPROVAL				
	<b>PAYMENT TERMS</b>				
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>Total Delivered Price</b>			

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
 Firm Name \_\_\_\_\_  
 Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
 Fax Number \_\_\_\_\_  
 Federal Taxpayer ID \_\_\_\_\_

Bidder
Must
Sign
In
Two
Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
 Firm Name \_\_\_\_\_



## REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price	Total
	<p>OF ALL VENDOR DRAWINGS, AND APPROVAL OF ELECTRICAL TESTING (INCLUDING EPR INSULATION) SHALL NOTIFY THE PORT AUTHORITY'S INVENTORY CONTROL SPECIALIST AND RESIDENT ENGINEER 72 HOURS PRIOR TO DELIVERY.</p> <p>PART 2 - PRODUCTS</p> <p>2.01 MANUFACTURERS A. SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE PRODUCTS BY ONE OF THE FOLLOWING PA APPROVED MANUFACTURERS, OR APPROVED FIT, FORM AND FUNCTION EQUIVALENT.</p> <p>1. WIRES AND CABLE A. OKONITE COMPANY, THE B. HOUSTON WIRE &amp; CABLE COMPANY C. SOUTHWIRE D. KERITE E. GENERAL CABLE</p> <p>2.02 MATERIALS A. WIRES AND CABLES 1. PROVIDE TRIPLEX CABLE AS SPECIFIED BELOW. ALL CABLE SHALL BE OF SAME TYPE BY SAME MANUFACTURER. PROCUREMENT OF MULTIPLE CABLE TYPES AND/OR MULTIPLE MANUFACTURERS AND OR OF MULTIPLE MANUFACTURING PERIODS WILL NOT BE ACCEPTED. CABLES SHALL BE TRIPLEXED AT THE</p>		
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>

**This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.**

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
Firm Name \_\_\_\_\_  
Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
Fax Number \_\_\_\_\_  
Federal Taxpayer ID \_\_\_\_\_

Bidder  
Must  
Sign  
In  
Two  
Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
Firm Name \_\_\_\_\_



# REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price		Total	
	FACTORY PRIOR TO SHIPPING 2. PULLING EYE LOOP AND END SEALS A. WIRES AND CABLES SHALL BE PROVIDED WITH FACTORY FITTED PULLING EYE LOOP AND END CAPS. SHOP DRAWINGS SHOWING THE PULLING EYE LOOP AND END CAPS TO BE USED SHALL BE SUBMITTED TO THE ENGINEER FOR APPROVAL. B. FOR PULLING TENSIONS UP TO 1000 POUNDS PER GRIP, BASKET GRIPS MAY BE UTILIZED. C. ALL WIRES AND CABLES SHALL BE END-SEALED, AT BOTH ENDS OF EACH LENGTH. 3. WIRES AND CABLES SHALL BE IDENTIFIED IN ACCORDANCE WITH AEIC CS8. A. OUTER JACKET SHALL BE PRINTED WITH MANUFACTURER'S IDENTIFICATION, TYPE OF INSULATION, SIZE OF CONDUCTOR, RATED VOLTAGE, MONTH/YEAR OF MANUFACTURE, INSULATION THICKNESS AND UL LISTING. B. NON-RETURNABLE WOOD REEL MARKINGS: THE VENDOR SHALL INDICATE IN BLACK INK OR WHITE INK, NOT LESS THAN THREE (3) INCHES IN SIZE, THE PURCHASE ORDER NUMBER, REEL NUMBER, CABLE LENGTH, DATE OF MANUFACTURE, MANUFACTURER'S NAME, AND MANUFACTURER'S PART NUMBER. C. EACH SINGLE CONDUCTOR CABLE WHEN SHIPPED TRIPLEXED, THERE SHALL BE A UNIQUE SERIES OF "111" OR "222" OR "333" RESPECTIVELY PER PHASE OR LEG TO IDENTIFY THE PHASE CONNECTION.				
	<b>PAYMENT TERMS</b>				
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>Total Delivered Price</b>			

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
 Firm Name \_\_\_\_\_  
 Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
 Fax Number \_\_\_\_\_  
 Federal Taxpayer ID \_\_\_\_\_

Bidder
Must
Sign
In
Two
Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
 Firm Name \_\_\_\_\_



# REQUEST FOR QUOTATION

Bid Due Date  
11/06/2012

Quantity	Description	Unit Price		Total	
	16121-MEDIUM VOLTAGE (5KV) C 06/15/12 16121C - 5 4. THREE CONDUCTOR TRIPLEXED MEDIUM VOLTAGE CABLE A. RATING: 5KV, MV-105 B. CONDUCTOR SIZE: 500KCMIL AND #1/0 AWG GROUND C. QUANTITY: LENGTH OF EACH CABLE ON REEL SHALL BE SPECIFIED AT TIME OF ORDER. D. CABLE ASSEMBLY: CABLE ASSEMBLY SHALL BE TRIPLEX, IN ACCORDANCE WITH THE FOLLOWING: 1) PHASE CONDUCTOR: A) TYPE: TYPE MV-105, COPPER CONDUCTOR, UNCOATED, CLASS B COMPACT STRANDED. B) SHIELDING: EXTRUDED CONDUCTOR SHIELDING C) INSULATION: ETHYLENE-PROPYLENE-RUBBER (EPR), 133 PERCENT INSULATION LEVEL, CONFORMING WITH AEIC CS8, NEMA WC74, AND UL1072. D) EXTRUDED EPR SEMI-CONDUCTING INSULATION SHIELDING E) COPPER SHIELDING TAPE, 5-MIL, SPIRALLY WRAPPED WITH A MINIMUM 12.5 PERCENT OVERLAP. F) JACKET SHALL BE A NO LEAD, SUNLIGHT RESISTANT PVC THAT MEETS OR EXCEEDS ICEA AND UL 1072 2) GROUND CONDUCTOR: A) COPPER, UNCOATED, CLASS B COMPACT STRANDED, RATED FOR 600V RHW. B) COVERING SHALL BE A CONTINUOUS GREEN COLOR AND CONFORM TO UL 44				
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>		

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
 Firm Name \_\_\_\_\_  
 Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
 Fax Number \_\_\_\_\_  
 Federal Taxpayer ID \_\_\_\_\_

Bidder  
 Must  
 Sign  
 In  
 Two  
 Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
 Firm Name \_\_\_\_\_



## REQUEST FOR QUOTATION

Bid Due Date  
 11/06/2012

Quantity	Description	Unit Price	Total
	3) BOND WITH ROUNDED-EDGE FLAT PVC COATED COPPER BINDING STRAP.  QUOTE FOB DELIVERED PRICING ON ALL ITEMS. ++++++ ++++++  A price preference of 10 % is available for NY/NJ Minority and Women Business Enterprises (M/WBE) or 5% for NY/NJ Small Business Enterprises (SBE) certified by the Port Authority (PA) by the day before bid opening for awards not exceeding \$1,000,000. My firm was certified as a _____ on _____.		
	<b>PLEASE QUOTE FULLY DELIVERED PRICES</b>	<b>PAYMENT TERMS</b>	<b>Total Delivered Price</b>

**This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.**

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed \_\_\_\_\_  
 Firm Name \_\_\_\_\_  
 Telephone number \_\_\_\_\_ Date \_\_\_\_\_  
 Fax Number \_\_\_\_\_  
 Federal Taxpayer ID \_\_\_\_\_

Bidder  
 Must  
 Sign  
 In  
 Two  
 Places

**NOTICE TO BIDDERS:** Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed \_\_\_\_\_ Date \_\_\_\_\_  
 Firm Name \_\_\_\_\_

## TERMS AND CONDITIONS

1. The Port Authority (PA) reserves the right to request information relating to seller's responsibility, experience and capability to perform the work.
2. Unless otherwise provided, complete shipment of all items must be in one delivery FOB delivery point. Payment will not be made on partial deliveries unless authorized in advance by the party to be charged and the discount, if any, will be taken on the total order.
3. PA payment terms are net 30 days. Cash discounts for prompt payment of invoices may be taken but will not be considered in determining award, except in the case of tie bids.
4. Separate unit and total FOB delivered prices must be shown.
5. Sales to the PA and to PATH are currently exempt from New York and New Jersey State and local taxes and generally from federal taxation. The seller certifies that there are no federal, state, municipal or any other taxes included in the prices shown hereon.
6. The PA shall have the absolute right to reject any or all proposals or to accept any proposal in whole or part and to waive defects in proposals.
7. Unless the phrase "no substitute" is indicated, bidder may offer alternate manufacturer / brands, which shall be subject to Port Authority approval. Please indicate details of product being offered with bid.
8. Acceptance of seller's offer will be only by Purchase Order Form signed by the PA. No change shall be made in the agreement except in writing.
9. If the seller fails to perform in accordance with the terms of this purchase order, the PA may obtain the goods or services from another contractor and charge the seller the difference in price, if any, a reletting cost of \$100, plus any other damages to the PA.
10. Upon request, sellers are encouraged to extend the terms and conditions of any terms agreement with the PA to other government and quasi-government entities by separate agreement.
11. By signing this quotation or bid, the seller certifies to all statements on Form PA 3764A regarding non-collusive bidding; compliance with the PA Code of Ethics; and the existence of investigations, indictments, convictions, suspensions, terminations, debarments and other stated occurrences to assist the PA in determining whether there are integrity issues which would prevent award of the contract to the seller. The PA has adopted a policy set forth in full on PA 3764A, that it will honor a determination by an agency of the State of New York or New Jersey that a bidder is not eligible to bid on or be awarded public contracts because the bidder has been determined to have engaged in illegal or dishonest conduct or to have violated prevailing wage legislation. The Terms and Conditions of PA 3764A apply to this order. A copy can be obtained by calling (201) 395-3405 or at <http://www.panynj.gov/business-opportunities/become-vendor.html>
12. The vendor may subcontract the services or use a supplier for the furnishing of materials required hereunder to such persons or entities as the Manager, Purchasing Services may from time to time expressly approve in writing. All further subcontracting shall also be subject to such approval.
13. The successful bidder (vendor) shall not issue nor permit to be issued any press release, advertisement, or literature of any kind, which refers to the Port Authority or that goods will be, are being or have been provided to it and/or that services will be, are being or have been performed for it in connection with this Agreement, unless the vendor first obtains the written approval of the Port Authority. Such approval may be withheld if for any reason the Port Authority believes that the publication of such information would be harmful to the public interest or is in any way undesirable.