



REQUEST FOR QUOTATION

Contact person/Telephone
Larry Waxman/201-395-3451

Collective# 0000037227
Bid Due Date 04/10/2014
Bids must be received no later than 11:00 AM on the above Bid Due Date.

Deliver Goods/Services To:
John F Kennedy International Airpor
Building No. 14 - Stockroom
Jamaica NY 11430

Quantity	Description	Unit Price		Total	
	<p>LOAD BANK, TRAILER MOUNTED AS MANUFACTURED BY SIMPLEX OR APPROVED EQUAL. FURNISH AND DELIVER.</p> <p>QUOTE FOB DELIVERED PRICING ON ALL ITEMS.</p> <p>IN THE INVENT OF AN ORDER ADVISE DELIVERY IN _____ DAYS A.R.O.</p> <p>PLEASE FOLLOW RETURN TO BID INSTRUCTIONS. REPLY IF POSSIBLE ONLY ON PATH / PA REQUEST FOR QUOTATION FORM AS ATTACHING YOUR COMPANIES TERMS & CONDITIONS MAY CAUSE YOUR BID TO BE DEEMED NON RESPONSIVE AND OR DELAY AN AWARD ISSUED.</p> <p>A price preference of 10 % is available for NY/NJ Minority and Women Business Enterprises (M/WBE) or 5% for NY/NJ Small Business Enterprises (SBE) certified by the Port Authority (PA) by the day before bid opening for awards not exceeding \$1,000,000. My firm was certified as a _____ on _____.</p> <p>QUESTIONS ONLY CONTACT: LARRY WAXMAN TEL: 201 395 3451 OR EMAIL: Lwaxman@panynj.gov</p>				
	<p>PLEASE QUOTE FULLY DELIVERED PRICES</p>	<p>PAYMENT TERMS</p>		<p>Total Delivered Price</p>	

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed _____
Firm Name _____
Telephone number _____ Date _____
Fax Number _____
Federal Taxpayer ID _____

**Bidder
Must
Sign
In
Two
Places**

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed _____ Date _____
Firm Name _____



REQUEST FOR QUOTATION

Bid Due Date
04/10/2014

Quantity	Description	Unit Price		Total	
	<p>WITH BID RESPONSE ADVISE EQUIPMENT TO BE OFFERED: MANUFACTURER: _____ PLANT LOCATION: _____ MAKE/MODEL/PART NUMBER: _____</p> <p>IF OFFERING OTHER THAN SIMPLEX TRAILER MOUNTED LOAD BANK AS SPECIFIED INCLUDE WITH YOUR BID RESPONSE TWO COPIES OF CATALOG CUTS/SPECIFICATIONS/DRAWINGS FOR PORT AUTHORITY REVIEW AND APPROVAL.</p>				
	<p>PLEASE QUOTE FULLY DELIVERED PRICES</p>				
		<p>PAYMENT TERMS</p>		<p>Total Delivered Price</p>	

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed _____
 Firm Name _____
 Telephone number _____ Date _____
 Fax Number _____
 Federal Taxpayer ID _____

**Bidder
 Must
 Sign
 In
 Two
 Places**

Signed _____ Date _____
 Firm Name _____



REQUEST FOR QUOTATION

Bid Due Date
04/10/2014

Quantity	Description	Unit Price		Total	
	<p>This is a Formal Bid Invitation Mail Sealed Bids to:</p> <p>The Port Authority of NY & NJ Attn: Bid Custodian Procurement Department 2 Montgomery Street, 3rd Floor Jersey City, NJ 07302</p> <p>by the date and time listed above, where it will be publicly opened and read.</p> <p>Bids are only accepted Monday through Friday, excluding Port Authority holidays, between the hours of 8 A.M. & 5 P.M., via regular mail, express delivery service or hand delivery.</p> <p>If you do not use or have an envelope provided, you must clearly mark the outside envelope/package with 'BID ENCLOSED' and show the company name, address, as well as Bid number and Due date as stated on this bid document.</p> <p>A valid photo id is required to gain access into the building, to attend the bid opening or hand deliver a bid.</p>				
1 EA	<p>DM0400010</p> <p style="text-align: center;">PLEASE QUOTE FULLY DELIVERED PRICES</p>	PAYMENT TERMS			
			Total Delivered Price		

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed _____
 Firm Name _____
 Telephone number _____ Date _____
 Fax Number _____
 Federal Taxpayer ID _____

**Bidder
Must
Sign
In
Two
Places**

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed _____ Date _____
 Firm Name _____



REQUEST FOR QUOTATION

Bid Due Date
04/10/2014

Quantity	Description	Unit Price		Total	
	LOAD BANK, NEPTUNE TRAILER MOUNTED, MANUFACTURED BY SIMPLEX OR APPROVED EQUAL. 200KW-650KW. TO INCLUDE THE INSTRUMENTATION PACKAGE(MULTI FUNCTION METERING AND DATA LOGGING), AND THE FOLLOWING SPECIFICATIONS: Capacity - 200KW-650KW Load Type - Resistive Power Factor - 1.0 Voltages - All common 3-phase 50, 60, and 400 Hz voltages: 60 Hertz: 208V, 220V, 240V, 416V, 440V, 450V, 460V, 480V, 575V, 600V 50 Hertz: 190V, 200V, 208V, 380V, 400V, 416V Frequency - 50, 60 Hertz Load Steps - 50KW resolution Duty Cycle - Continuous Temperature - 120°F maximum ambient temperature. Exhaust rise: 150°F - 200°F (Note: as airflow is not laminary, exhaust air temperatures are not equal at all points at the plane of air exhaust. Some parcels of air may reach approximately 575°F before mixing. Airflow 200KW-350KW: - 10,400 CFM, 3-HP 400KW-650KW: 13,400 CFM, 5-HP Fault Rating - Fuses are rated 200KAIC. The load bank has a 5KAIC short circuit current rating. Load Wire Insulation Rating - 600V, 150°C				
	PLEASE QUOTE FULLY DELIVERED PRICES	PAYMENT TERMS	Total Delivered Price		

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed _____
 Firm Name _____
 Telephone number _____ Date _____
 Fax Number _____
 Federal Taxpayer ID _____

Bidder Must Sign In Two Places

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed _____ Date _____
 Firm Name _____



REQUEST FOR QUOTATION

Bid Due Date
04/10/2014

Quantity	Description	Unit Price		Total	
	<p>Control Wire Insulation Rating - 600V, 105°C Fan/Control Power Internal, from load bus. Load control circuits and fan motor control operate 120V via transformer. Control circuits are fused. The cooling fan operates at 3-phase line voltage. Dimensions 200KW: - 43"W x 91.75"H x 36"D - includes 42" exhaust hood up to 650KW: - 40"W x 108"H x 54"D - includes 42" exhaust hood Weight 1,600 lbs - 4,200 lbs</p> <p>Load Elements # Elements mounted in easily accessible, slide out trays. # Simplex Powr-Web chromium alloy, open wire, continuously supported, power resistor. # UL Recognized</p> <p>System Controls # Standard: Simplex D-Series Digital Controller with local or remote touchscreen. Cooling # Integral forced air cooling system. # 3-phase, direct drive motor. # Rain shedding exhaust hood. # Forced air, vertical airflow -- cold air intake at bottom, hot air exhaust at top. Malfunction Protections # Sensors, alarms (alarm messages and exhaust temperature displays on touchscreen), lock-outs as appropriate, for the following: fan failure, high exhaust temperature and high intake temperature. # Load Circuit Protection: branch circuit fuses. One set of</p>				
	<p>PLEASE QUOTE FULLY DELIVERED PRICES</p>	<p>PAYMENT TERMS</p>		<p>Total Delivered Price</p>	

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed _____
 Firm Name _____
 Telephone number _____ Date _____
 Fax Number _____
 Federal Taxpayer ID _____

**Bidder
Must
Sign
In
Two
Places**

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed _____ Date _____
 Firm Name _____



REQUEST FOR QUOTATION

Bid Due Date
04/10/2014

Quantity	Description	Unit Price		Total	
	<p>fuses each 50KW branch. Fuses are current limiting type, 200,000 AIC, 600V, enabling safe use on large generating or UPS system.</p> <p>Load Control # Branch circuit contactors each step or each 50KW circuit maximum.</p> <p># Contactors with enclosed silver surfaced contacts, 120V coils; electrically operated and electrically held.</p> <p>Connections</p> <p># Control Wiring: 105°C, color coded.</p> <p># Power Wiring: 150°C XLP color-coded.</p> <p># Cables connect to full rated copper bus bar with an oversized terminal junction box.</p> <p># Cables connectable through top or bottom of chassis.</p> <p>Enclosure # Type 3R weatherproof power section, including load elements and cooling fan.</p> <p># Type 3R weatherproof control section, thermally and electrically isolated from resistive load power section.</p> <p># Double wall construction for cool exterior.</p> <p># Service access from three sides via hinged doors with lockable latches.</p> <p># Finish painted with a UL Listed process consisting of either a powder-coated finish or a liquid-coated finish consisting of an epoxy primer and a polyurethane finish.</p> <p>Trailer Construction # Extra-heavy duty steel trailer with steel deck. All welded frame construction. Meets all DOT requirements for highway use. 2000# lift jack.</p> <p>Vehicle Connections # User specified hitches (2 5/16" ball hitch or 3" pintle ring hitch adjustable in 2" increments).</p>				
	PLEASE QUOTE FULLY DELIVERED PRICES	PAYMENT TERMS			
		Total Delivered Price			

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

Signed _____

Firm Name _____

Telephone number _____ Date _____

Fax Number _____

Federal Taxpayer ID _____

**Bidder
Must
Sign
In
Two
Places**

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.

Signed _____ Date _____

Firm Name _____



REQUEST FOR QUOTATION

Bid Due Date
 04/10/2014

Quantity	Description	Unit Price	Total
	36" safety chains with hooks. Electric beak-away battery and switch. Brakes and Lights # Electric driving breaks. Mechanical parking brake. DOT lighting and connector. Rear reflectors. ...END...		
	PLEASE QUOTE FULLY DELIVERED PRICES	PAYMENT TERMS	Total Delivered Price

This Quotation is subject to the terms and conditions set forth on the back page hereof. Bidder is advised to read these before signing.

We have read the instructions and, if favored with an order, we agree to furnish the items enumerated herein at the prices and under the conditions indicated.

NOTICE TO BIDDERS: Unless the following term of assurance that the above offer is irrevocable is signed, the offer submitted herein shall not be deemed to be complete.

Signed _____
 Firm Name _____
 Telephone number _____ Date _____
 Fax Number _____
 Federal Taxpayer ID _____

Bidder
Must
Sign
In
Two
Places

The foregoing offer shall be irrevocable for 90 days after the date on which the Port Authority of New York and New Jersey opens this proposal.
 Signed _____ Date _____
 Firm Name _____

TERMS AND CONDITIONS

1. The Port Authority (PA) reserves the right to request information relating to seller's responsibility, experience and capability to perform the work.
2. Unless otherwise provided, complete shipment of all items must be in one delivery FOB delivery point. Payment will not be made on partial deliveries unless authorized in advance by the party to be charged and the discount, if any, will be taken on the total order.
3. PA payment terms are net 30 days. Cash discounts for prompt payment of invoices may be taken but will not be considered in determining award, except in the case of tie bids.
4. Separate unit and total FOB delivered prices must be shown.
5. Sales to the PA and to PATH are currently exempt from New York and New Jersey State and local taxes and generally from federal taxation. The seller certifies that there are no federal, state, municipal or any other taxes included in the prices shown hereon.
6. The PA shall have the absolute right to reject any or all proposals or to accept any proposal in whole or part and to waive defects in proposals.
7. Unless the phrase "no substitute" is indicated, bidder may offer alternate manufacturer / brands, which shall be subject to Port Authority approval. Please indicate details of product being offered with bid.
8. Acceptance of seller's offer will be only by Purchase Order Form signed by the PA. No change shall be made in the agreement except in writing.
9. If the seller fails to perform in accordance with the terms of this purchase order, the PA may obtain the goods or services from another contractor and charge the seller the difference in price, if any, a reletting cost of \$100, plus any other damages to the PA.
10. Upon request, sellers are encouraged to extend the terms and conditions of any terms agreement with the PA to other government and quasi-government entities by separate agreement.
11. By signing this quotation or bid, the seller certifies to all statements on Form PA 3764A regarding non-collusive bidding; compliance with the PA Code of Ethics; and the existence of investigations, indictments, convictions, suspensions, terminations, debarments and other stated occurrences to assist the PA in determining whether there are integrity issues which would prevent award of the contract to the seller. The PA has adopted a policy set forth in full on PA 3764A, that it will honor a determination by an agency of the State of New York or New Jersey that a bidder is not eligible to bid on or be awarded public contracts because the bidder has been determined to have engaged in illegal or dishonest conduct or to have violated prevailing wage legislation. The Terms and Conditions of PA 3764A apply to this order. A copy can be obtained by calling (201) 395-3405 or at <http://www.panynj.gov/business-opportunities/become-vendor.html>
12. The vendor may subcontract the services or use a supplier for the furnishing of materials required hereunder to such persons or entities as the Manager, Purchasing Services may from time to time expressly approve in writing. All further subcontracting shall also be subject to such approval.
13. The successful bidder (vendor) shall not issue nor permit to be issued any press release, advertisement, or literature of any kind, which refers to the Port Authority or that goods will be, are being or have been provided to it and/or that services will be, are being or have been performed for it in connection with this Agreement, unless the vendor first obtains the written approval of the Port Authority. Such approval may be withheld if for any reason the Port Authority believes that the publication of such information would be harmful to the public interest or is in any way undesirable.
14. Neither the Commissioners of the Port Authority, nor Directors of PATH, nor any of them, nor any officer, agent or employee thereof, shall be charged personally by the Contractor with any liability, or held personally liable to the Contractor under any term or provision of this Agreement, or because of its execution or attempted execution, or because of any breach, or attempted or alleged breach, thereof.