

THE PORT AUTHORITY OF NY & NJ
Procurement Department,
ATTENTION: BID CUSTODIAN,
4 World Trade Center 21st Floor,
150 Greenwich Street
New York, NY 10007

9/3/2015

ADDENDUM # 1

To prospective Bidder(s) on Bid # 43475

HIGH VOLTAGE SPLICE KITS (8KV, 15KV AND 35KV RATED) FOR PATH RAIL SYSTEM

Originally Due back on 9/10/2015.

BIDDERS ATTENTION IS CALLED TO THE "REQUEST FOR QUOTATION" (RFQ), PAGES 4, 5 AND 6 OF 7.

**DELETE DESCRIPTIONS AS ORIGINALLY SHOWN IN THE RFQ.
INSERT AMENDED DESCRIPTIONS AS STATED BELOW INTO THE RFQ.**

1. ITEM # 1. 8KV Splice Kit: "Kit shall be able to splice 3/C #2 AWG Polymer Cable to 3/C #2 AWG Polymer Cable with tape shield and #6 AWG ground wire with 8KV system voltage rating." Or approved equal as determined by PA/PATH.
2. ITEM # 2. 15KV Splice Kit: "Kit shall be able to splice 3/C 4/0 Polymer Cable to 3/C 4/0 Polymer Cable with tape shield and 1/0 ground wire with 15KV system voltage rating." Or approved equal as determined by PA/PATH.
3. ITEM # 3. 35KV Splice Kit: "Kit shall be able to splice three (3)- 1/C 2/0 Polymer Cable to three (3)- 1/C 2/0 Polymer Cable with tape shield and 1/0 ground wire with 35KV system voltage rating, with one re-jacketing modification kits to convert three (3) 1/C splices into one (1) 3/C splice." Or approved equal as determined by PA/PATH.

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidders does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information

PS11All

accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the foregoing information, and that it shall not hold the Port Authority liable or responsible therefore in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefore in any manner whatsoever.

The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

<i>Question #1</i>	“Is there any way we can get the actual conductor size for those voltages?”
<i>Answer # 1</i>	Yes. See the answers as stated above.

THE PORT AUTHORITY OF NY & NJ
 KATHY LESLIE WHELAN.
 COMMODITIES AND SERVICES
 DIVISION

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
 LARRY WAXMAN, WHO CAN BE REACHED AT (212) 435-4639 or at
Lwaxman@panynj.gov. BID #43475.