

THE PORT AUTHORITY OF NY & NJ

PROCUREMENT DEPARTMENT
4 WORLD TRADE CENTER
150 GREENWICH STREET, 21ST FL.
NEW YORK, NY 10007

2/23/2016

ADDENDUM # 1

To prospective Bidder(s) on Bid # 45143 for Air Filter Services for Heating, Ventilation, and Air Conditioning (HVAC) Systems at the Port Authority Bus Terminal (PABT)

Due back on 3/3/2016, no later than 11:00AM

Originally due on 2/25/2016, no later than 11:00AM

I. CHANGES/MODIFICATIONS

The following changes/modifications are hereby made to the solicitation documents:

- A. The bid due date has been EXTENDED until March 3, 2016, no later than 11:00 AM.
- B. Delete Part IV, Pricing Sheets , Pages 5 through 15 in their entirety
And Replace them with the attachment entitled “Contractor’s Pricing Sheet – Exhibit A” Revised 2/23/2016
- C. In Part V, Section I entitled “Specific Definitions”, delete the following sentence
“Regular Working Hours” means the hours between 7:00 a.m. to 3:00 p.m.,
Monday through Friday, excluding Holidays.
And Replace it with:
“Regular Working Hours” means the hours between 11:00 p.m. to 7:00 a.m.,
Monday through Friday, excluding Holidays.
- D. In Part V, page 5, Section 7 entitled “Vacuuming “, delete the following sentence
“All vacuuming shall be done between the hours of 7:00 a.m. to 3:00 p.m. on
weekdays, unless otherwise specifically permitted or directed by the Manager.”
And replace it with the following:
“All vacuuming shall be done between the hours of 11:00 p.m. to 7:00 a.m. on
weekdays, unless otherwise specifically permitted or directed by the Manager.”

II. BIDDER'S QUESTIONS AND ANSWERS

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidders does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the foregoing information, and that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

<i>Question # 1</i>	Please provide the current contract's pricing.
<i>Answer # 1</i>	See attached current contract's pricing

FOR INFORMATION PURPOSES ONLY, ATTACHED IS THE PRICING FROM THE MOST RECENT PURCHASE:

The Port Authority of New York and New Jersey does not guarantee the relevancy of the pricing material as it may pertain to proposals solicited for other contracts. Vendors are cautioned that the use of this information, to determine future bid prices, or for any other purpose, shall be used at the vendor's own risk. Bid prices should be based on the company's costs, overhead and profit. The material requested may be based on a different specification and/or different quantity or delivery requirements than those in future solicitations.

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

SELENE ORTEGA, MANAGER
COMMODITIES AND SERVICES
PROCUREMENT DEPARTMENT

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
LUZ SANTANA, WHO CAN BE REACHED AT (212) 435-4625 OR AT
LSANTANA@PANYNJ.GOV.

**CONTRACTOR'S PRICING SHEET
EXHIBIT A**

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated Pre-Filter	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Pre-Filter Pleated Price	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
1	AC-04	2nd FL. MER-2		24X24X2	12	3027026-003	24X				24X24X12	12	14	6X			
2	AC-04	2nd FL. MER-2		12X24X2	3	3027026-001	24X				12X24X12	3	14	6X			
3	AC-05	2nd FL.. MER-2		24X24X2	12	3027026-003	24X				24X24X12	12	14	6X			
4	AC-05	2nd FL. MER-2		12X24X2	3	3027026-001	24X				12X24X12	3	14	6X			
5	AHU-S24A-ACT5	2nd FL. MER-3		24X24X2	6	3027026-003	24X				24X24X12	6	14	6X			
6	AHU-S24A-ACT5	2nd FL. MER-3		12X24X2	2	3027026-001	24X				12X24X12	2	14	6X			
7	AHU-S24A-ACT6	2nd FL. MER-3		24X24X2	12	3027026-003	24X				24X24X12	12	14	6X			
8	AHU-SS4B-AC18	S/W Subway Level		24X24X2	8	3027026-003	24X				24X24X12	8	14	6X			
9	AHU-SS4B-AC18	S/W Subway Level		12X24X2	4	3027026-001	24X				12X24X12	4	14	6X			

PART IV – 5

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
10	AHU-S22B-AC02	2nd FL. MER-2		24X24X2	8	3027026-003	24X				24X24X12	8	14	6X			
11	AHU-S22B-AC02	2nd FL. MER-2		12X24X2	6	3027026-001	24X				12X24X12	6	14	6X			
12	AHU-S22B-AC03	2nd FL. MER-2		24X24X2	12	3027026-003	24X				24X24X12	12	14	6X			
13	AHU-S22B-AC03	2nd FL. MER-2		12X24X2	3	3027026-001	24X				12X24X12	3	14	6X			
14	AHU-S22B-ACT3	2nd FL.. MER-2		24X24X2	10	3027026-003	24X				24X24X12	10	14	6X			
15	AHU-S22B-ACT3	2nd FL. MER-2		12X24X2	5	3027026-001	24X				12X24X12	5	14	6X			
16	AHU-S22B-ACT4	2nd FL. MER-2		24X24X2	8	3027026-003	24X				24X24X12	8	14	6X			
17	AHU-SL30-AC08	S/W Lower Level		24X24X2 Carbon Pleated	8	3027026-003	24X				24X24X12	8	14	6X			
18	AHU-SL30-AC08	S/W Lower Level		12X24X2 Carbon Pleated	4	3027026-001	24X				12X24X12	4	14	6X			
19	AHU-S23A-P200	2nd FL. MER-3		12X24X2	4	3027026-003	24X				12X24X12	4	14	6X			

PART IV – 6

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
20	AHU-S24A-P201/202	2nd FL. MER-3		20X24X2	4	3027026-003	24X				20X24X12	4	14	6X			
21	AHU-S24A-P201/202	2nd FL. MER-3		20X20X2	2	3027026-001	24X				20X20X12	2	14	6X			
22	AHU-S24A-P203/206	2nd FL. MER-3		20X24X2	4	3027026-003	24X				20X24X12	4	14	6X			
23	AHU-S24A-P203/206	2nd FL. MER-3		20X20X2	2	3027026-001	24X				20X20X12	2	14	6X			
24	AHU-S24A-P204/207	2nd FL. MER-3		20X24X2	4	3027026-003	24X				20X24X12	4	14	6X			
25	AHU-S24A-P204/207	2nd FL. MER-3		20X20X2	2	3027026-001	24X				20X20X12	2	14	6X			
26	AHU-S24-P205/208	2nd FL. MER-3		20X24X2	2	3027026-003	24X				20X24X12	2	14	6X			
27	AHU-S24-P205/208	2nd FL. MER-3		20X20X2	1	3027026-001	24X				20X20X12	1	14	6X			

PART IV – 7

PART IV – SIGNATURE SHEET, NAME AND RESIDENCE OF PRINCIPALS SHEET AND PRICING SHEET(S)

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
28	AHU-S24A-AC04	2nd FL. MER-3		12x24x2	4	N/A	24X				12x24x12	4	14	6X			
29	AHU-S24A-AC04	2nd FL. MER-3		24x24x2	12	N/A	24X				24x24x12	12	14	6X			
30	AHU-S24A-AC05	2nd FL. MER-3		12x24x2	4	N/A	24X				12x24x12	4	14	6X			
31	AHU-S24A-AC05	2nd FL. MER-3		24x24x2	8	N/A	24X				24x24x12	8	14	6X			
32	AHU-S24A-ACT5	2nd FL. MER-3		12x24x2	4	N/A	24X				12x24x12	4	14	6X			
33	AHU-S24A-AC05	2nd FL. MER-3		24x24x2	8	N/A	24X				24x24x12	8	14	6X			
34	AHU-S24A-ACT6	2nd FL. MER-3		12x24x2	4	N/A	24X				12x24x12	4	14	6X			
35	AHU-S24A-ACT6	2nd FL. MER-3		24x24x2	8	N/A	24X				24x24x12	8	14	6X			
36	AHU-SL4H-AC06	LL East MER		24X24X2	8	N/A	24X				24X24X12	8	14	6X			
37	AHU-SL4H-AC06	LL East MER		24X12X2	2	N/A	24X				24X12X12	2	14	6X			
38	AHU-S54B-HV05	5th FL. 30-31,U3-U4		24X20X2	2	N/A	24X				24X20X12	2	14	6X			

PART IV – 8

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
39	AHU-SS4B-AC18	Subway Level		24X24X2	8	N/A	24X				24X24X12	8	14	6X			
40	AHU-SS4B-AC18	Subway Level		20X24X2	2	N/A	24X				24X12X12	2	14	6X			
41	AHU-S23B-P210/214	2nd FL. MER-2		24X24X2	3	N/A	24X				24X24X12	3	14	6X			
42	AHU-S23B-P210/214	2nd FL. MER-2		20X24X2	3	N/A	24X				20X24X12	3	14	6X			
43	AHU-S23B-P211/220	2nd FL. MER-2		24X20X2	4	N/A	24X				24X20X12	4	14	6X			
44	AHU-S23B-P211/220	2nd FL. MER-2		24X12X2	2	N/A	24X				24X12X12	2	14	6X			
45	AHU-SL4H-AC06	LL East MER		24X24X2	8	N/A	24X				24X24X12	8	14	6X			
46	AHU-SL4H-AC06	LL East MER		24X24X2	2	N/A	24X				24X24X12	2	14	6X			
47	AHU-S23B-P212	2nd FL. MER-2		24X12X2	1	N/A	24X				24X12X12	1	14	6X			

PART IV – 9

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
48	AHU-S23B-P212	2nd FL. MER-2		24X20X2	2	N/A	24X				24X20X12	2	14	6X			
49	AHU-S23B-P213/2 21	2nd FL. MER-2		20X24X2	3	N/A	24X				20X24X12	3	14	6X			
50	AHU-S23B-P213/2 21	2nd FL. MER-2		24X24X2	3	N/A	24X				24X24X12	3	14	6X			
51	AHU-S22B-AC02	2nd FL. MER-2		5' Roll	1	N/A	20X										
52	AHU-S22B-AC03	2nd FL. MER-2		6' Roll	1	N/A	20X										
53	AHU-S22B-ACT3	2nd FL. MER-2		6' Roll	1	N/A	20X										
54	AHU-S22B-ACT4	2nd FL. MER-2		4' Roll	1	N/A	20X										
55	AHU-SL30-AC21	L.L. Col. 21-L		24X24x2	2	N/A	24X				24X24X12	2	8	6X			
56	AHU-SL30-AC21	L.L. Col. 21-L		12X24X2	1	N/A	24X				12X24X12	2	8	6X			
57	AHU-SL30-AC08	L.L. Col. 21-E		5' Roll	1	N/A	20X										

PART IV – 10

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
58	AHU-SB3A-AC01	L.L. Sub Basement		16X20X4	2	N/A	24X										
59	AHU-SB3A-AC02	L.L. Sub Basement		16X20X4	2	N/A	24X										
60	P-2	Inside on Door		25X20X1	1	N/A	24X										
61	P-2	Outside on door		24X47x1	1	N/A	24X										
62	A/C - 20	Gate 56		20X25X2	1	N/A	24X										
63	A/C - 28	Const. Office		24X24X2	1	N/A	24X				24X24X12	1	14	6X			
64	AHU-SL30-AC21	L.L. Col. 21-L		20X24X2	1	N/A	24X				24X20X12	1	14	6X			
65	AHU-SL30-AC21	L.L. Col. 21-L		12X24X2	1	N/A	24X				12X24X12	1	14	6X			
66	A/C - 29	TSH		20X20X2	2	N/A	24X				20X20X12	2	14	6X			
67	A/C - 27	Const. Conf. Rm.		12X20X1	1	N/A	24X										
68	A/C - 27	Const. Conf. Rm.		16X20X1	1	N/A	24X										
69	A/C-16	A/C Plant S/W 4th FL.		20X24X1	2	N/A	24X										
70	A/C-16	A/C Plant S/W 4th FL.		12X24X1	2	N/A	24X										

PART IV – 11

PART IV – SIGNATURE SHEET, NAME AND RESIDENCE OF PRINCIPALS SHEET AND PRICING SHEET(S)

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
71	A/C-17	A/C Plant S/W 4th FL.		12X24X2	32	N/A	24X										
72	A/C-31	S/W 3rd FL..		16X25X2	2	N/A	24X										
73	P-1	TS Room		20X20X1	1	N/A	24X										
74	A/C-203	Det. Office		20X20X2	3	N/A	24X										
75	A/C-204	Det. Office		16X25X2	2	N/A	24X										
76	A/C-205	Det. Office		16X25X2	2	N/A	24X										
77	A/C-290	Sign Room		16X20X2	1	N/A	24X										
78	ACT-206	N/W Hallmark		16X20X2	2	N/A	24X										
79	ACT-214	USO		20X25X2	2	N/A	24X										
80	ACT – 215	Regional Alliance		20X20X2	3	N/A	24X										
81	ACT – 215	Regional Alliance		20X25X2	3	N/A	24X										
82	ACT-213	VRH Const. Office		20X25X2	2	N/A	24X										
83	ACT-216	42nd st. Conf. Room		20X25X2	3	N/A	24X										
84	A/C-201	N/W Old Hallmark		16X20X2	2	N/A	24X										
85	A/C-26	Mgr. Office 1st FL..		20X24X2	3	N/A	24X										
86	A/C-9	5th FL. Parking		16X20X2	4	N/A	36X										

PART IV – 12

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
87	A/C-9	5th FL. Parking		16X25X2	8	N/A	36X										
88	A/C-10	5th FL. Parking		16X20X2	4	N/A	36X										
89	A/C-10	5th FL. Parking		16X25X2	8	N/A	36X										
90	A/C-11	5th FL. Parking		16X20X2	4	N/A	36X										
91	A/C-11	5th FL. Parking		16X25X2	8	N/A	36X										
92	A/C-12	5th FL. Parking		16X20X2	4	N/A	36X										
93	A/C-12	5th FL. Parking		16X25X2	8	N/A	36X										
94	A/C-13	5th FL. Parking		16X20X2	4	N/A	36X										
95	A/C-13	5th FL. Parking		16X25X2	8	N/A	36X										
96	A/C-14	S/W B-3 Basement		20X25X2	3	N/A	24X										
97	A/C-14	S/W B-3 Basement		12X24X2	5	N/A	24X										
98	A/C-15	S/W B-3 Basement		12X24X2	12	N/A	24X										
99	A/C-22	S/W B-3 Basement		12X24X2	15	N/A	24X										
100	HV-3	S/W B-3 Basement		20X25X2	6	N/A	24X										
101	A/C-23	S/W B-3 Basement		12X24X2	15	N/A	24X										
102	3' Rolls	Mer-1-2 N/W		N/A	N/A	N/A	20X										
103	4' Rolls	S/W MER1-2 3		N/A	N/A	N/A	20X										

PART IV – 13

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
104	4' Rolls	N/W A/C 3		N/A	N/A	N/A	20X										
105	5' Rolls	N/W A/C 1-2-6-7		N/A	N/A	N/A	20X										
106	6' Rolls	N/W Pent 1-2		N/A	N/A	N/A	20X										
107	6' Roll	S/W MER-2 A/C 11		N/A	N/A	N/A	20X										
108	2' Rolls	MERR-1		N/A	N/A	N/A	20X										
109	A/C-21	S/W L.L. Roadway		24X24X2	2	N/A	24X				24X24X12	2	14	6X			
110	A/C-21	S/W L.L. Roadway		24X12X2	2	N/A	24X				24X12X12	2	14	6X			
111	A/C-1	Telephone Room		29.5X28.5X4	1	N/A	24X										
112	A/C-2	Telephone room		29.5X28.5X4	1	N/A	24X										
113	A/C -3	B-3 Computer Rm		29.5X28.5X4	1	N/A	24X										
114	A/C-4	B-3 Computer Rm		29.5 X 28.5 X 4	1	N/A	24X										
115	A/C-24	9th Ave. Lobby		16 X 20 X 2	4	N/A	24X										
116	A/C-25	9th Ave. Lobby		16X25X2	2	N/A	24X										
117	A/C-1	M/C Evap OCC		29.5X28.5X2	1	N/A	24X										
118	A/C-2	M/C Evap OCC		29.5X28.5X2	1	N/A	24X										
119	OCC	M/C Cond OCC		16X25X2	1	N/A	24X										

PART IV – 14

Revised 2/23/2016

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
120	Info Booth	S/W		12X12X1	1	N/A	24X										
121	Info Booth	S/W		12X20X1	1	N/A	24X										
122	Info Booth	N/W		12X12X1	1	N/A	24X										
123	Info Booth	N/W		12X20X1	1	N/A	24X										
124	Video room	Fresh Air Plenum		16X20X2	4	N/A	24X										
125	P-1	Elev Rm Ring Panel		20X20X1	1	N/A	24X										
126	P-2 & P-3	Elev Rm Ring Panel		20X25X1	1	N/A	24X										
127	P-2 & P-3	Elev Rm Ring Panel		16X25X1	3	N/A	24X										
128	P-6 & P7	Elev Rm Ring Panel		20X24X1	1	N/A	24X										
129	MER # 1	2nd Floor S/W		16X25X1	8	N/A	24X										

PART IV – 15

PART IV – SIGNATURE SHEET, NAME AND RESIDENCE OF PRINCIPALS SHEET AND PRICING SHEET(S)

Rev. 6/12/15 (PA/PATH)

	A	B		C	D	E	F	G	H		I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Pleated	Biocel VXL-SH Part # (or approved equal)	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size & Total	Cell	Cell MER V	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column H + N)
130	MER # 2	2nd FL. S/W		20X25X1	7	N/A	24X										
131	MER # 3	2nd FL. S/W		16X25X1	8	N/A	24X										
132	AHU-SB1B-AC22	B-3		20X25X2	1	N/A	24X										
133	AHU-SB1C-AC23	B-3		20X25X2	1	N/A	24X										
TOTAL ESTIMATED TWO-YEAR CONTRACT PRICE																	
(Add Line Item 1 through 133)															\$		

Notes:

1. All filters shall be UL Class1. Pre-filters 2” thick, merv8/30%-flanders pre-pleat 40 or Port Authority approved equal.
2. Final filters 12” thick merv14/90-95%-flanders precisioncell 95 Port Authority or approved equal.
3. All carbon filters shall be 12” thick, charcoal 75% Viledon, carbopleat or Port Authority approved equal (are not Class 1 due to its carbon content)
4. All filter quantities type and dimensions must be verified in the field

Unit price shall be an all-inclusive price, including but not limited to the Contractor’s cost for all labor, repairs, maintenance parts and materials, testing, supervision, travel time, tolls, and overhead profit. The Port Authority has the right to add or delete filters.

CONTRACTOR'S PRICING SHEETS
EXHIBIT A

		Location	Filter size	Pleated Type	Qty	FREQ	3yr-Qty	Unit Price per Filter	Estimated Three-year amount
		DET. OFF.							
A/C	203		20x20x2		3	12 X /yr	108	\$6.66	\$719.28
A/C	204		16x25x2		2	12 X /yr	72	\$6.66	\$479.52
A/C	205		16x25x2		2	12 X /yr	72	\$6.66	\$479.52
A/C	290	SIGN ROOM	16x20x2		1	12 X /yr	36	\$6.66	\$239.76
ACT	206	NW HallMark	16x20x2		2	12 X /yr	72	\$6.66	\$479.52
ACT	214	USO	2-x25x2		2	12 X /yr	72	\$7.63	\$549.36
ACT	215	Regional Alliance	20x25x2		3	12 X /yr	108	\$7.63	\$824.04
			20x20x2		3	12 X/yr	108	\$6.66	\$719.28
		2nd FL. OLD HALLMARK							
A/C	201		16x20x2		2	12 X /yr	72	\$6.66	\$479.52
A/C	203		20x25x2		2	12 X/ yr	72	\$7.63	\$549.36
		SW MGR OFF 1ST FL.							
AC	26		20x24x12	Cell filter	3	2 X/yr	18	\$54.00	\$972.00
		5th FL. A/C UNITS							
A/C	9		16x25x2	Pleated	8	12 X yr	288	\$6.66	\$1918.08
	9		16x20x2	Pleated	4	12 X/ yr	144	\$6.66	\$959.04
A/C	10		16x25x2	Pleated	8	12 X/ yr	288	\$6.66	\$1918.08
	10		16x20x2	Pleated	4	12 X/ yr	144	\$6.66	\$959.04
A/C	11		16x25x2	Pleated	8	12 X/ yr	288	\$6.66	\$1918.08
	11		16x20x2	Pleated	4	12 X/ yr	144	\$6.66	\$959.04
A/C	12		16x25x2	Pleated	8	12 X/ yr	288	\$6.66	\$1918.08
	12		16x20x2	Pleated	4	12 X/ yr	144	\$6.66	\$959.04

PART IV - 5

PART IV - SIGNATURE SHEET, NAME AND RESIDENCE OF PRINCIPALS SHEET AND PRICING SHEET(S)

Rev. 6/1/07 (PA/PATH)

A/C	13		16x25x2	Pleated	8	12 X /yr	288	\$6.66	\$1918.08
AC	13		16x20x2		4	12 X /yr	144	\$6.66	\$959.04
		SW B-3 BASEMENT							
A/C	14		12x24x2	Pleated Charcoal	10	12 X/yr	360	\$13.60	\$4896.00
A/C	15		12x24x2	Pleated Charcoal	15	12 X/yr	540	\$13.60	\$7344.00
AHU	1 (A/C # 22)		12x24x2	Pleated Charcoal	15	12 X/yr	540	\$13.60	\$7344.00
HV	3		12x25x2	Pleated Charcoal	6	12 X/yr	216	\$13.66	\$2937.60
AHU	2 (A/C #23)		12x25x2	Pleated Charcoal	15	12 X/yr	540	\$13.60	\$7344.00
		ELEVATOR							
P	2 & 3	INSIDE	20X25X1	Pleated	1	12 X /yr	36	\$7.60	\$273.60
		OUTSIDE	16X25X1	Pleated	3	12 X/yr	108	\$6.66	\$719.28
		CONSTR. OFFICE							
A/C	28		24X24X12	Cell Filter	1	2 X /yr	6	\$57.00	\$342.00
		8-20-01 42-50	20X24X12 12x24x12	Cell Filters	1/1	2 X /yr	6/6	\$95.21	\$571.26
		TIME SQUARE RM							
A/C	29		20x20x12	Cell Filter	2	2 X/yr	12	\$56.90	\$682.80
		CONSTR. CONFER. ROOM							
A/C	27		16x25x1		2	12 X/yr	72	\$6.20	\$446.40
		AC PLANT 4TH FLOOR							
A/C	16		20X24X1		2	12 X/yr	72	\$7.60	\$547.20
			12X24X1		2	12 X/yr	72	\$6.27	\$451.44
A/C	17	SW A/C Plant 4 th Floor	12x24x2	Pleated charcoal	32	12 X /yr	1154	\$13.60	\$15,694.40
		GATE 53							
A/C	21		20x25x2		4	12 X/yr	144	\$7.63	\$1098.72

PART IV - 6

PART IV - SIGNATURE SHEET, NAME AND RESIDENCE OF PRINCIPALS SHEET AND PRICING SHEET(S)

Rev. 6/1/07 (PA/PATII)

RECOMMENDATION

		GATE 56							
A/C	22		20x25x2	1	12 X/yr	36	\$ 763	\$ 274.68	
		NW 5TH FLOOR							
A/C	30		16x25x2	1	12 X/yr	36	\$ 6.66	\$ 239.76	
		SW TENANT BATHROOM							
			16x24x2	2	12 X/yr	72	\$ 7.16	\$ 515.52	
		Roll Filters	Sizes		Approx. 3 month changes				
		2 FT			4	12	\$ 120.00	\$ 1,440.00	
		3 FT			16	48	\$ 120.00	\$ 5,760.00	
		4 FT			14	42	\$ 150.00	\$ 6,300.00	
		5 FT			14	42	\$ 180.00	\$ 7,560.00	
		6 FT			14	42	\$ 200.00	\$ 8,400.00	

Notes:

1. All filters shall be UL class 1. However, if class 1 are not available, than class 2 will be accepted
2. Pre-filters 2"thick, merv 8/30%-flanders pre-pleat 40 or approved equal shall be of class 1 only
3. Final filters 12"thick merv 14/90-95%-flanders precisioncell 95 or approved equal
4. All carbon filters shall be 12"thick, charcoal 75% Viledon, carbopleat or approved equal (are not class 1 due to its carbon content)
5. All filter quantities type and dimensions must be verified in the field

Total Three-Year Estimated Contract Price - Exhibit A (Quantity X Unit Price per Filter = 3 Year Estimate)	\$ 102,059.42
---	-------------------------

Unit price shall be an all-inclusive price, including the Contractor's cost for all labor, repairs, maintenance parts and materials, testing, supervision, travel time and overhead profit. The Port Authority has the right to add or delete filters and frequencies.