

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
4 WORLD TRADE CENTER
150 GREENWICH STREET, 21ST FLOOR
NEW YORK, NY 10007**

06/09/2016

ADDENDUM # 1

To prospective Bidder(s) on Bid # 46154 Batteries Lead Calcium Flooded Type, Battery Charger/Battery Eliminator, Racks, Spill Containment and Accessories for PATH at Jersey City, New Jersey. Furnish and Deliver per Specifications

Due back on 6/15/2016, no later than 11:00 AM

I. CHANGES/MODIFICATIONS NONE.

The following answers to questions shall become an integral part of the subject Bid.

II. BIDDER'S QUESTIONS AND ANSWERS

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidders does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the foregoing information, and that it shall not hold the Port Authority liable or responsible therefore in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder

required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefore in any manner whatsoever.
 The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

Question #1	We do have 2 tier 2 row seismic racks which house the same number of jars but do not allow one to observe the electrolyte levels of both rows from the front of the rack. A 72" rack will hold 40 jars and the rack is seismically legal to use in NY.
Answer # 1	<u>Batteries in the "back" row must be accessible for maintenance. If the configuration provides the access for such it may acceptable subject to submitting with the RFQ response documentation and specification for PA/PATH review and approval..</u>
Question #2	Are 3-tier racks acceptable?
Answer #2	<u>No.</u>
Question #3	Do you have a drawing of the existing layout.
Answer # 3	There is no existing drawing. The inside dimension of room is 7'-4" by 6'-4". Existing racks are 82"Lx 50"Hx 16"w (2 Each) and 42"Lx 50"Hx 16"w (1 each)

THE PORT AUTHORITY OF NY & NJ

SELENE ORTEGA, MANAGER
 COMMODITIES AND SERVICES DIVISION

BIDDER'S FIRM NAME: _____
 INITIALED: _____
 DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
 LARRY WAXMAN, WHO CAN BE REACHED AT (212) 435-4639 OR AT
LWAXMAN@PANYNJ.GOV BID #46154