

THE PORT AUTHORITY OF NY & NJ

**PROCUREMENT DEPARTMENT
2 MONTGOMERY STREET, 3RD FL.
JERSEY CITY, NJ 07302**

1/24/2014

ADDENDUM # 2

To prospective Bidder(s) on Bid # **36208**
**AIRCRAFT RUNWAY RATED CONCRETE HANDHOLDS 4FT X 4FT X 4FT,
NEWARK LIBERTY INTERNATIONAL AIRPORT. FURNISH AND DELIVER
IN ACCORDANCE WITH SPECIFICATIONS AND DRAWING.**

ORIGINALLY DUE BACK ON 1/29/2014, NO LATER THAN 11:00 AM

The following changes/modifications are hereby made to the solicitation documents:

- I. BIDDERS ATTENTION ARE CALLED TO: REQUEST FOR QUOTATION (RFQ) PAGE 4 OF 5.

DELETE: QUANTITY OF 87 AS ORIGINALLY STATED.
INSERT: REPLACEMENT QUANTITY OF 84.**
- II. DELETE: ANSWER #1 STATED IN ADDENDUM #1 DATED 1/17/2014 AND REPLACE IT WITH ANSWER #2 AS STATED BELOW.**
- III. THE QUESTIONS AND ANSWERS SHALL BE INCORPORATED INTO THE SUBJECT SPECIFICATION AS APPLICABLE.**
- IV. BIDDER'S QUESTIONS AND ANSWERS**

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidders does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the

PS11All

foregoing information, and that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

Question # 2	<p>Section A-A on drawing #E968 indicates that duct windows with bell fittings are required in the handhole walls. The elevation in the "Typical Detail Of Window & Siding Connection For Duct" shows the same requirement, but Section B-B in the same typical detail implies an oversized hole or knockout is required in the handhole walls with joint material and mastic and concrete encasement. Furthermore, note 18 on the same drawing states all four walls are to contain duct windows utilizing bell sizes per drawing E969. Is the bidder/vendor to provide holes (knockouts) in all four walls, or bell fittings cast in all four walls. If the requirement is to cast in the bell fittings in all four walls, provide the referenced drawing E969, or provide exact details of the size and quantity of bell fittings that are required in each of the four walls in each of the total 87 units that are required to be supplied in this solicitation.</p>
Answer # 2	<p>Bidders are instructed to review drawing #E969 date 11/08/2013 and the handholes should be provided with the conduit bell fittings casted in the walls,</p> <p>Type Description QUANTITY</p> <p>1 - 8 way - 4" Bell Fittings in Walls (All Sides) QUANTITY 49.</p> <p>2 - 6 way - 4" Bell Fittings in Walls (All Sides) QUANTITY 18.</p> <p>3 - 6 way - 4" Bell Fittings in Walls (North & South Sides) 4 way - 2" Bell Fittings in Walls (East & West Sides) QUANTITY 17.</p> <p>Total Quantity 84.</p>

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

KATHY LESLIE WHELAN
ASSISTANT DIRECTOR
COMMODITIES AND SERVICES DIVISION

BIDDER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
LARRY WAXMAN, WHO CAN BE REACHED AT (201) 395-3451 or at
Lwaxman@panynj.gov. - 36208 ADDENDUM 2 DATED 01/23/2014