

# THE PORT AUTHORITY OF NY & NJ

PROCUREMENT DEPARTMENT  
4 WORLD TRADE CENTER  
150 GREENWICH STREET, 21<sup>ST</sup> FL.  
NEW YORK, NY 10007

3/8/2016

## ADDENDUM # 3

To prospective Bidder(s) on Bid # 45143 for Air Filter Services for Heating, Ventilation, and Air Conditioning (HVAC) Systems at the Port Authority Bus Terminal (PABT)

Due back on 3/10/2016, no later than 11:00AM

### I. CHANGES/MODIFICATIONS

**The following changes/modifications are hereby made to the solicitation documents:**

- A. Delete the text under Part V, page 3, Section 4 entitled “Filter Specifications”, paragraph B in its entirety and replace it with:  
Roll filter shall be UL Class 1 consisting of an American Air Roll-A-Matic Type Core as manufactured by American Air Filter Corporation, Viskon-Aire Corporation or a Port Authority approved equal. All materials for roll filters, including filter media, shall be UL Class 1 Rated media face velocity shall be 500 fpm. The initial resistance of the clean media at 500 fpm shall not exceed 0.15”w.g. The average arrestance shall be at least 70 %. The filters will be run to a final resistance of 0.50”w.g. The filtering media shall be 65 feet long and shall be rolled and installed in a manner to permit the proper operation of the existing feed mechanisms without alteration. Media shall be 2 ½” fiberglass. Media must have sufficient strength to maintain its full width under the tension created as the roll advances.
- B. In Addendum #1, delete items “B”, “C” and “D” in their entirety and replace with the following:
  - i. Delete Part IV, Pricing Sheet, page 5 through 15 in their entirety  
And Replace them with the attachment entitled “Contractor’s Pricing Sheet – Exhibit A” Revised 3/7/2016
  - ii. In Part V, Section I entitled “Specific Definitions”, delete the following sentence “Regular Working Hours” means the hours between 7:00 a.m. to 3:00 p.m., Monday through Friday, excluding Holidays.  
And Replace it with:  
“Regular Working Hours” means the hours between 10:30 p.m. to 6:30 a.m., Sunday through Thursday, excluding Holidays.

- iii. In Part V, page 5, Section 7 entitled “Vacuuming “, delete the following sentence “All vacuuming shall be done between the hours of 7:00 a.m. to 3:00 p.m. on weekdays, unless otherwise specifically permitted or directed by the Manager.”

And replace it with the following:

“All vacuuming shall be done between the hours of 10:30 p.m. to 6:30 a.m., Sunday through Thursday, excluding Holidays, unless otherwise specifically permitted or directed by the Manager.”

## II. BIDDER'S QUESTIONS AND ANSWERS

The following information is available in response to questions submitted by prospective Bidders. The responses should not be deemed to answer all questions, which have been submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority has deemed to require additional information and/or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidders does not mean or imply, nor should it be deemed to mean or imply, any meaning, construction, or implication with respect to the terms.

The Port Authority makes no representations, warranties or guarantees that the information contained herein is accurate, complete or timely or that such information accurately represents the conditions that would be encountered during the performance of the Contract. The furnishing of such information by the Port Authority shall not create or be deemed to create any obligation or liability upon it for any reason whatsoever and each Bidder, by submitting its Bid, expressly agrees that it has not relied upon the foregoing information, and that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. Accordingly, nothing contained herein and no representation, statement or promise, of the Port Authority, its Commissioners, officers, agents, representatives, or employees, oral or in writing, shall impair or limit the effect of the warranties of the Bidder required by this Bid or Contract and the Bidder agrees that it shall not hold the Port Authority liable or responsible therefor in any manner whatsoever. The Questions and Answers numbering sequence will be continued sequentially in any forthcoming Addenda that may be issued.

<b><i>Question # 2</i></b>	Please direct me to the specs on roll filters.
<b><i>Answer # 2</i></b>	See section I above entitled “ <b>CHANGES/MODIFICATIONS</b> ”
<b><i>Question # 3</i></b>	Column E of pricing sheet revision 2/23/2016 shows Biocel VXL-SH. This model is made by American Air Filter. On page 16 of pricing sheet, note 2 specifies a Flanders filter. Can we quote based on either model?
<b><i>Answer # 3</i></b>	See section I above entitled “ <b>CHANGES/MODIFICATIONS</b> ”

This communication should be initialed by you and annexed to your Bid upon submission.

In case any Bidder fails to conform to these instructions, its Bid will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

SELENE ORTEGA, MANAGER  
COMMODITIES AND SERVICES  
PROCUREMENT DEPARTMENT

BIDDER'S FIRM NAME: \_\_\_\_\_

INITIALED: \_\_\_\_\_

DATE: \_\_\_\_\_

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO  
LUZ SANTANA, WHO CAN BE REACHED AT (212) 435-4625 OR AT  
LSANTANA@PANYNJ.GOV.

**CONTRACTOR'S PRICING SHEET  
EXHIBIT A**

<i>Line #</i>	<i>Unit ID</i>	<i>Location</i>	<i>Pleated Pre-Filter Size</i>	<i>Filters per Unit</i>	<i>2 Year Pleated Frequency</i>	<i>Unit Pre-Filter Pleated Price</i>	<i>2 Year Pre-Filter Pleated Price</i>	<i>Cell Filter Size</i>	<i>Biocel VXL-SH Part # (or approved equal)</i>	<i>Filters per Unit</i>	<i>Cell MERV</i>	<i>2 Year Cell Frequency</i>	<i>Unit Price Cell</i>	<i>2-Year Price Cell</i>	<i>Estimated 2 year Contract Price (Add Column G + N)</i>
1	AC-04	2nd FL. MER-2	24X24X2	12	24X			24X24X12	3027026-003	12	14	6X			
2	AC-04	2nd FL. MER-2	12X24X2	3	24X			12X24X12	3027026-001	3	14	6X			
3	AC-05	2nd FL.. MER-2	24X24X2	12	24X			24X24X12	3027026-003	12	14	6X			
4	AC-05	2nd FL. MER-2	12X24X2	3	24X			12X24X12	3027026-001	3	14	6X			
5	AHU-S24A-ACT5	2nd FL. MER-3	24X24X2	6	24X			24X24X12	3027026-003	6	14	6X			
6	AHU-S24A-ACT5	2nd FL. MER-3	12X24X2	2	24X			12X24X12	3027026-001	2	14	6X			
7	AHU-S24A-ACT6	2nd FL. MER-3	24X24X2	12	24X			24X24X12	3027026-003	12	14	6X			
8	AHU-SS4B-AC18	S/W Subway Level	24X24X2	8	24X			24X24X12	3027026-003	8	14	6X			
9	AHU-SS4B-AC18	S/W Subway Level	12X24X2	4	24X			12X24X12	3027026-001	4	14	6X			

**PART IV – 5**

**PART IV – SIGNATURE SHEET, NAME AND RESIDENCE OF PRINCIPALS SHEET AND PRICING SHEET(S)**

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
10	AHU-S22B-AC02	2nd FL. MER-2		24X24X2	8	24X				24X24X12	3027026-003	8	14	6X			
11	AHU-S22B-AC02	2nd FL. MER-2		12X24X2	6	24X				12X24X12	3027026-001	6	14	6X			
12	AHU-S22B-AC03	2nd FL. MER-2		24X24X2	12	24X				24X24X12	3027026-003	12	14	6X			
13	AHU-S22B-AC03	2nd FL. MER-2		12X24X2	3	24X				12X24X12	3027026-001	3	14	6X			
14	AHU-S22B-ACT3	2nd FL. MER-2		24X24X2	10	24X				24X24X12	3027026-003	10	14	6X			
15	AHU-S22B-ACT3	2nd FL. MER-2		12X24X2	5	24X				12X24X12	3027026-001	5	14	6X			
16	AHU-S22B-ACT4	2nd FL. MER-2		24X24X2	8	24X				24X24X12	3027026-003	8	14	6X			
17	AHU-SL30-AC08	S/W Lower Level		24X24X2 Carbon Pleated	8	24X				24X24X12	3027026-003	8	14	6X			
18	AHU-SL30-AC08	S/W Lower Level		12X24X2 Carbon Pleated	4	24X				12X24X12	3027026-001	4	14	6X			
19	AHU-S23A-P200	2nd FL. MER-3		12X24X2	4	24X				12X24X12	3027026-003	4	14	6X			

**PART IV – 6**

**PART IV – SIGNATURE SHEET, NAME AND RESIDENCE OF PRINCIPALS SHEET AND PRICING SHEET(S)**

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
20	AHU-S24A-P201/202	2nd FL. MER-3		20X24X2	4	24X				20X24X12	3027026-003	4	14	6X			
21	AHU-S24A-P201/202	2nd FL. MER-3		20X20X2	2	24X				20X20X12	3027026-001	2	14	6X			
22	AHU-S24A-P203/206	2nd FL. MER-3		20X24X2	4	24X				20X24X12	3027026-003	4	14	6X			
23	AHU-S24A-P203/206	2nd FL. MER-3		20X20X2	2	24X				20X20X12	3027026-001	2	14	6X			
24	AHU-S24A-P204/207	2nd FL. MER-3		20X24X2	4	24X				20X24X12	3027026-003	4	14	6X			
25	AHU-S24A-P204/207	2nd FL. MER-3		20X20X2	2	24X				20X20X12	3027026-001	2	14	6X			
26	AHU-S24-P205/208	2nd FL. MER-3		20X24X2	2	24X				20X24X12	3027026-003	2	14	6X			
27	AHU-S24-P205/208	2nd FL. MER-3		20X20X2	1	24X				20X20X12	3027026-001	1	14	6X			

**PART IV – 7**

**PART IV – SIGNATURE SHEET, NAME AND RESIDENCE OF PRINCIPALS SHEET AND PRICING SHEET(S)**

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
28	AHU-S24A-AC04	2nd FL. MER-3		12x24x2	4	24X				12x24x12	N/A	4	14	6X			
29	AHU-S24A-AC04	2nd FL. MER-3		24x24x2	12	24X				24x24x12	N/A	12	14	6X			
30	AHU-S24A-AC05	2nd FL. MER-3		12x24x2	4	24X				12x24x12	N/A	4	14	6X			
31	AHU-S24A-AC05	2nd FL. MER-3		24x24x2	8	24X				24x24x12	N/A	8	14	6X			
32	AHU-S24A-ACT5	2nd FL. MER-3		12x24x2	4	24X				12x24x12	N/A	4	14	6X			
33	AHU-S24A-AC05	2nd FL. MER-3		24x24x2	8	24X				24x24x12	N/A	8	14	6X			
34	AHU-S24A-ACT6	2nd FL. MER-3		12x24x2	4	24X				12x24x12	N/A	4	14	6X			
35	AHU-S24A-ACT6	2nd FL. MER-3		24x24x2	8	24X				24x24x12	N/A	8	14	6X			
36	AHU-SL4H-AC06	LL East MER		24X24X2	8	24X				24X24X12	N/A	8	14	6X			
37	AHU-SL4H-AC06	LL East MER		24X12X2	2	24X				24X12X12	N/A	2	14	6X			
38	AHU-S54B-HV05	5th FL. 30-31,U3-U4		24X20X2	2	24X				24X20X12	N/A	2	14	6X			

PART IV – 8

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
39	AHU-SS4B-AC18	Subway Level		24X24X2	8	24X				24X24X12	N/A	8	14	6X			
40	AHU-SS4B-AC18	Subway Level		20X24X2	2	24X				24X12X12	N/A	2	14	6X			
41	AHU-S23B-P210/214	2nd FL. MER-2		24X24X2	3	24X				24X24X12	N/A	3	14	6X			
42	AHU-S23B-P210/214	2nd FL. MER-2		20X24X2	3	24X				20X24X12	N/A	3	14	6X			
43	AHU-S23B-P211/220	2nd FL. MER-2		24X20X2	4	24X				24X20X12	N/A	4	14	6X			
44	AHU-S23B-P211/220	2nd FL. MER-2		24X12X2	2	24X				24X12X12	N/A	2	14	6X			
45	AHU-SL4H-AC06	LL East MER		24X24X2	8	24X				24X24X12	N/A	8	14	6X			
46	AHU-SL4H-AC06	LL East MER		24X24X2	2	24X				24X24X12	N/A	2	14	6X			
47	AHU-S23B-P212	2nd FL. MER-2		24X12X2	1	24X				24X12X12	N/A	1	14	6X			

PART IV – 9

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
48	AHU-S23B-P212	2nd FL. MER-2		24X20X2	2	24X				24X20X12	N/A	2	14	6X			
49	AHU-S23B-P213/21	2nd FL. MER-2		20X24X2	3	24X				20X24X12	N/A	3	14	6X			
50	AHU-S23B-P213/21	2nd FL. MER-2		24X24X2	3	24X				24X24X12	N/A	3	14	6X			
51	AHU-S22B-AC02	2nd FL. MER-2		5' Roll	1	20X											
52	AHU-S22B-AC03	2nd FL. MER-2		6' Roll	1	20X											
53	AHU-S22B-ACT3	2nd FL. MER-2		6' Roll	1	20X											
54	AHU-S22B-ACT4	2nd FL. MER-2		4' Roll	1	20X											
55	AHU-SL30-AC21	L.L. Col. 21-L		24X24x2	2	24X				24X24X12	N/A	2	8	6X			
56	AHU-SL30-AC21	L.L. Col. 21-L		12X24X2	1	24X				12X24X12	N/A	2	8	6X			
57	AHU-SL30-AC08	L.L. Col. 21-E		5' Roll	1	20X											

PART IV – 10

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
58	AHU-SB3A-AC01	L.L. Sub Basement		16X20X4	2	24X											
59	AHU-SB3A-AC02	L.L. Sub Basement		16X20X4	2	24X											
60	P-2	Inside on Door		25X20X1	1	24X											
61	P-2	Outside on door		24X47x1	1	24X											
62	A/C - 20	Gate 56		20X25X2	1	24X											
63	A/C - 28	Const. Office		24X24X2	1	24X				24X24X12	N/A	1	14	6X			
64	AHU-SL30-AC21	L.L. Col. 21-L		20X24X2	1	24X				24X20X12	N/A	1	14	6X			
65	AHU-SL30-AC21	L.L. Col. 21-L		12X24X2	1	24X				12X24X12	N/A	1	14	6X			
66	A/C - 29	TSH		20X20X2	2	24X				20X20X12	N/A	2	14	6X			
67	A/C - 27	Const. Conf. Rm.		12X20X1	1	24X											
68	A/C - 27	Const. Conf. Rm.		16X20X1	1	24X											
69	A/C-16	A/C Plant S/W 4th FL.		20X24X1	2	24X											
70	A/C-16	A/C Plant S/W 4th FL.		12X24X1	2	24X											

PART IV – 11

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
71	A/C-17	A/C Plant S/W 4th FL.		12X24X2	32	24X											
72	A/C-31	S/W 3rd FL..		16X25X2	2	24X											
73	P-1	TS Room		20X20X1	1	24X											
74	A/C-203	Det. Office		20X20X2	3	24X											
75	A/C-204	Det. Office		16X25X2	2	24X											
76	A/C-205	Det. Office		16X25X2	2	24X											
77	A/C-290	Sign Room		16X20X2	1	24X											
78	ACT-206	N/W Hallmark		16X20X2	2	24X											
79	ACT-214	USO		20X25X2	2	24X											
80	ACT – 215	Regional Alliance		20X20X2	3	24X											
81	ACT – 215	Regional Alliance		20X25X2	3	24X											
82	ACT-213	VRH Const. Office		20X25X2	2	24X											
83	ACT-216	42nd st. Conf. Room		20X25X2	3	24X											
84	A/C-201	N/W Old Hallmark		16X20X2	2	24X											
85	A/C-26	Mgr. Office 1st FL..		20X24X2	3	24X											
86	A/C-9	5th FL. Parking		16X20X2	4	36X											

PART IV – 12

Revised 3/7/2016

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
87	A/C-9	5th FL. Parking		16X25X2	8	36X											
88	A/C-10	5th FL. Parking		16X20X2	4	36X											
89	A/C-10	5th FL. Parking		16X25X2	8	36X											
90	A/C-11	5th FL. Parking		16X20X2	4	36X											
91	A/C-11	5th FL. Parking		16X25X2	8	36X											
92	A/C-12	5th FL. Parking		16X20X2	4	36X											
93	A/C-12	5th FL. Parking		16X25X2	8	36X											
94	A/C-13	5th FL. Parking		16X20X2	4	36X											
95	A/C-13	5th FL. Parking		16X25X2	8	36X											
96	A/C-14	S/W B-3 Basement		20X25X2	3	24X											
97	A/C-14	S/W B-3 Basement		12X24X2	5	24X											
98	A/C-15	S/W B-3 Basement		12X24X2	12	24X											
99	A/C-22	S/W B-3 Basement		12X24X2	15	24X											
100	HV-3	S/W B-3 Basement		20X25X2	6	24X											
101	A/C-23	S/W B-3 Basement		12X24X2	15	24X											
102	3' Rolls	Mer-1-2 N/W		N/A	N/A	20X											
103	4' Rolls	S/W MER1-2 3		N/A	N/A	20X											

PART IV – 13

PART IV – SIGNATURE SHEET, NAME AND RESIDENCE OF PRINCIPALS SHEET AND PRICING SHEET(S)

Rev. 6/12/15 (PA/PATH)

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MERV	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
104	4' Rolls	N/W A/C 3		N/A	N/A	20X											
105	5' Rolls	N/W A/C 1-2-6-7		N/A	N/A	20X											
106	6' Rolls	N/W Pent 1-2		N/A	N/A	20X											
107	6' Roll	S/W MER-2 A/C 11		N/A	N/A	20X											
108	2' Rolls	MERR-1		N/A	N/A	20X											
109	A/C-21	S/W L.L. Roadway		24X24X2	2	24X				24X24X12		2	14	6X			
110	A/C-21	S/W L.L. Roadway		24X12X2	2	24X				24X12X12		2	14	6X			
111	A/C-1	Telephone Room		29.5X28.5X4	1	24X											
112	A/C-2	Telephone room		29.5X28.5X4	1	24X											
113	A/C -3	B-3 Computer Rm		29.5X28.5X4	1	24X											
114	A/C-4	B-3 Computer Rm		29.5 X 28.5 X 4	1	24X											
115	A/C-24	9th Ave. Lobby		16 X 20 X 2	4	24X											
116	A/C-25	9th Ave. Lobby		16X25X2	2	24X											
117	A/C-1	M/C Evap OCC		29.5X28.5X2	1	24X											
118	A/C-2	M/C Evap OCC		29.5X28.5X2	1	24X											
119	OCC	M/C Cond OCC		16X25X2	1	24X											

PART IV – 14

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
<i>Line #</i>	<i>Unit ID</i>	<i>Location</i>		<i>Pleated Pre-Filter Size</i>	<i>Filters per Unit</i>	<i>2 Year Pleated Frequency</i>	<i>Unit Price Pleated</i>	<i>2 Year Pre-Filter Pleated Price</i>		<i>Cell Filter Size</i>	<i>Biocel VXL-SH Part # (or approved equal)</i>	<i>Filters per Unit</i>	<i>Cell MERV</i>	<i>2 Year Cell Frequency</i>	<i>Unit Price Cell</i>	<i>2-Year Price Cell</i>	<i>Estimated 2 year Contract Price (Add Column G + N)</i>
120	Info Booth	S/W		12X12X1	1	24X											
121	Info Booth	S/W		12X20X1	1	24X											
122	Info Booth	N/W		12X12X1	1	24X											
123	Info Booth	N/W		12X20X1	1	24X											
124	Video room	Fresh Air Plenum		16X20X2	4	24X											
125	P-1	Elev Rm Ring Panel		20X20X1	1	24X											
126	P-2 & P-3	Elev Rm Ring Panel		20X25X1	1	24X											
127	P-2 & P-3	Elev Rm Ring Panel		16X25X1	3	24X											
128	P-6 & P7	Elev Rm Ring Panel		20X24X1	1	24X											
129	MER # 1	2nd Floor S/W		16X25X1	8	24X											

PART IV – 15

	A	B		C	D	E	F	G		H	I	J	K	L	M	N	O
Line #	Unit ID	Location		Pleated Pre-Filter Size	Filters per Unit	2 Year Pleated Frequency	Unit Price Pleated	2 Year Pre-Filter Pleated Price		Cell Filter Size	Biocel VXL-SH Part # (or approved equal)	Filters per Unit	Cell MER V	2 Year Cell Frequency	Unit Price Cell	2-Year Price Cell	Estimated 2 year Contract Price (Add Column G + N)
130	MER # 2	2nd FL. S/W		20X25X1	7	24X					N/A						
131	MER # 3	2nd FL. S/W		16X25X1	8	24X					N/A						
132	AHU-SB1B-AC22	B-3		20X25X2	1	24X					N/A						
133	AHU-SB1C-AC23	B-3		20X25X2	1	24X					N/A						
<b>TOTAL ESTIMATED TWO-YEAR CONTRACT PRICE</b>																	
(Add Line Item 1 through 133)																	\$

Notes:

1. All filters shall be UL Class1. Pre-filters 2” thick, merv8/30% or Port Authority approved equal.
2. Final filters 12” thick merv14/90-95% or Port Authority or approved equal.
3. All carbon filters shall be 12” thick, charcoal 75% Viledon, carbopleat or Port Authority approved equal (are not Class 1 due to its carbon content)
4. All filter quantities type and dimensions must be verified in the field

Unit price shall be an all-inclusive price, including but not limited to the Contractor’s cost for all labor, repairs, maintenance parts and materials, testing, supervision, travel time, tolls, and overhead profit. The Port Authority has the right to add or delete filters.

**PART IV – 16**