

THE PORT AUTHORITY OF NY & NJ

LGA-124.881 - Rehabilitation of Taxilane 0

QUESTIONS FROM BIDDERS

Updated: 10/09/2026

QUES #	QUESTION	RESPONSE
1	Please refer to the specification for Item P-101: Part 101-4.3 states that Excavation, 14 Inches Below Existing Grade will be paid for the number of cubic yards (CY) however, Part 101-5.1 states that Item P-101-5.3 will be measured per square yard (SY). Please clarify the unit of measurement for Item P-101-5.3.	The unit of measurement for Item P-101-5.3 shall be cubic yards (CY). An addendum will be issued to correct P-101-5.3 under Payment of Items.
2	Please clarify whether the manhole frame and cover for the Manufactured treatment device and Diversion manhole are included in Item – D-751-5.1 Manhole Frame and Cover - Aircraft rated.	Manhole frame and cover for the Manufactured Treatment device and Diversion Manhole will be under item D-751-5.1. Will revise quantity to 8 ea to account for the (4) existing manholes frame and cover, (2) diversion manholes frame and cover, and (2) MTD frame and cover.