Torres Rojas, Genara

From: ann.givens@nbcuni.com
Sent: Monday, November 03, 2014 2:33 PM
To: Duffy, Daniel; American, Heavyn-Leigh
Cc: Torres Rojas, Genara; Van Duyne, Sheree
Subject: Freedom of Information Online Request Form

Information:

First Name: Ann
Last Name: Givens
Company: NBC NY
Mailing Address 1: 30 Rockefeller Plaza
Mailing Address 2: Seventh Floor
City: New York
State: NY
Zip Code: 10112
Email Address: ann.givens@nbcuni.com
Phone: 917-434-0736
Required copies of the records: Yes

List of specific record(s):
Under the provisions of the New York Freedom of Information Law, Article 6 of the Public Officers Law, I hereby request records: - Any and all records or logs of smoke and fire alarms going off at LaGuardia Airport since Jan. 1, 2014, including any investigation into why the alarm sounded, the results of that investigation and any action that was taken. - Maintenance records on all smoke and fire alarms at LaGuardia Airports dating back to Jan. 1, 2011. - Any complaints to Port Authority involving smoke or fire alarms since January 1. 2011.

THE PORT AUTHORITY OF NY & NJ

FOI Administrator

January 21, 2014

Ms. Ann Givens
NBC NY
30 Rockefeller Plaza, 7th Floor
New York, NY 10112

Re: Freedom of Information Reference No. 15456

Dear Ms. Givens:

This is in response to your November 3, 2014 request, which has been processed under the Port Authority's Freedom of Information Code (the "Code") for copies "records or logs of smoke and fire alarms going off at LaGuardia Airport since Jan. 1, 2014, including any investigation into why the alarm sounded, the results of that investigation and any action that was taken. - Maintenance records on all smoke and fire alarms at LaGuardia Airports dating back to Jan. 1, 2011. - Any complaints to Port Authority involving smoke or fire alarms since January 1. 2011."

Material responsive to your request and available under the Code can be found on the Port Authority's website at http://www.panynj.gov/corporate-information/foi/15456-O.pdf. Paper copies of the available records are available upon request.

Please refer to the above FOI reference number in any future correspondence relating to your request.

Very truly yours,

Daniel D. Duffy
FOI Administrator

4 World Trade Center, 18th Floor
150 Greenwich Street
New York, NY 10006
T: 212 435 3642 F: 212 435 7555

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1423L- FAA, Chad Dunkin	advises Fire Alarm testing being conducted at new FAA ATCT.

Log Entered	1/01/2014 19:04 PM	Entered By	Rosemary Millan
Event Date/Time	1/01/2014 14:23 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

Term D fire alarms went off. This was a result of a sprinkler head mishap in the east end of Term C. ABM has system in by-pass and will advise when repair complete.

1700L- Delta, Kevin, advises fire alarm system is back on line.

Log Entered	1/03/2014 21:02 PM	Entered By	Rosemary Millan
Event Date/Time	1/03/2014 21:02 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0218L- Water flow alarm activated for CTB west UAL baggage room.

CHRP, 71, JM, 1079 responded.

PA Ops sent out Audio/Visual message on alarm investigation.

Active water flow condition observed inside bag room; water coming down from hot air curtain area above UAL baggage room roll up door. Part of broken sprinkler head pipe observed on floor.

CHRP secured associated water valve and water flow stopped.

Sprinkler pipe had burst due to extreme cold temps inside the bag room.

0219L- Allied Barton contacted for request of 1 Fire watch guard

0226L- UAL facilities notified and responded.

0300L- Fire watch guard posted until further notice.
****

0240L Terminal D fire alarm water flow WF 1FL mech room 109
0243L- Contact made with Delta maintenance they are investigating alarm.
0443L- Delta mtc advises they are currently working on the fire alarm system.
****

0300L Water flow alarm activated AAL gate D10 MER 1. 71. AAL facilities responded and negative actual condition observed. CHRP investigating alarm triggering.

Log Entered	1/04/2014 4:02 AM	Entered By	Rosemary Millan
Event Date/Time	1/04/2014 2:18 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0900 hrs. - ABM advises fire alarm testing is being conducted in terminals C and D.

1358 hrs. - ABM advises fire alarm testing is complete.

Log Entered	1/04/2014 17:36 PM	Entered By	Minerva Colon
Event Date/Time	1/04/2014 17:36 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1453 hrs. - AAL Hgr. #3 - WF. Bldg. #5 - PS. American Bldg. Mtce. (Harry) notified.

1509 hrs. - AAL alarm cleared.

Log Entered	1/04/2014 20:14 PM	Entered By	Minerva Colon
Event Date/Time	1/04/2014 20:14 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1741 hrs. - Hgr. 2 WF Deluge Panel F/A.

1743 hrs. - CH&RP and UAL Ops (John) notified and responding.

1746 hrs. - UAL Ops advises their building maintenance is on scene and water is present.

1750 hrs. - Mechanical 2 (Elliott) is on scene along with PAPD.

1758 hrs. - CH&RP advise water has been secured. Fire watch will be needed at Hgr. 2 and at the wedge building between hangars 2 & 4.

1830 hrs. - UAL building maintenance (Glen Marcisak) notified for fire watch for Hangar 2.

1833 hrs. - AAL building maintenance (Michael Trotta) notified for wedge building fire watch.

UAL and AAL advise they were briefed by J. Elliott.

Log Entered	1/04/2014 20:17 PM	Entered By	Minerva Colon
Event Date/Time	1/04/2014 20:17 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0345L - ABM in Terminal D advises fire alarm system in bypass for scheduled inspections.
PAPD notified.

Log Entered	1/05/2014 5:21 AM	Entered By	Yolanda Marrero
Event Date/Time	1/05/2014 5:21 AM		

FIRE ALARMS

1941- A fire alarm showed at new pump house on CC screen
CHRP advised and responding.
Responded to H-4. LARGE leak on south wall.
CHRP, AAL, PAPD and OPS 90 advised.
CHRP w/ M. Ward and AAL Mt. Responded.
Shut off valves inside did not work.
Ward and crew went in front of H- 4 and shut off street valve.

Water to H-4 off.
ASA for Fire Watch and Security placed in H-4.
Doors in H-2 o/s. All persons directed to BR-11.
HBE advised and will come in early to assess damage.

AG, JM, 100, 93JL ,71C advised.

Log Entered	1/05/2014 20:04 PM	Entered By	Joe Carney
Event Date/Time	1/05/2014 20:04 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE WATCH

0800L 3 Fire watch Barton Firewatch guards posted in Hgr 4, bldg 17, bldg 18 and hgr 2 areas.
Met with CHRP J. Elliott.
Firewatch is ufn

Log Entered	1/06/2014 9:22 AM	Entered By	Rosemary Millan
Event Date/Time	1/06/2014 9:22 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2217L - Fire alarms activated "CTB West Fire alarm" "CTB WW FA 1st & 23nd FL RM 3636A" "WF Driy sys, CTB Arrv.". PA Elect., PA CHRP and PAPD notified.
"CC" activating 1st audio message.
2232L - PA CHRP, Murphy, advises "dry system" valve was found open and was secured.
PAPD briefed. "CC" activating "false alarm" audio message.
2238L - System reset.

2327L - Parking Garage fire alarm "ROR 4 FL" activated.
72 & PAPD responding. PA Elect. Shop notified.
2331L - PAPD & 72 on scene, negative condition.
2358L - System reset.

Log Entered	1/06/2014 4:45 AM	Entered By	Yolanda Marrero
Event Date/Time	1/06/2014 4:45 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0000L - AMB performing fire alarms test at Terminal C. PAPD notified.
0437L - Testing completed.

Log Entered	1/07/2014 2:06 AM	Entered By	Yolanda Marrero
Event Date/Time	1/07/2014 2:06 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1113L Delat 1st floor fire alarm triggered ; Delta was testing and forgot to advise. PAPD notified
0616L Gate Gourment DD Fire alarm; false alarm cooking.

Log Entered	1/08/2014 13:50 PM	Entered By	Rosemary Millan
Event Date/Time	1/08/2014 13:50 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1723 hrs. - Fire alarms activated - CTB East Smoke Detector - Slide Door. PAPD, CH&RP, & 1079 notified and responding.

1724 hrs. - CC issued patron announcement.

1738 hrs. - Negative condition found. 1079 reset fire alarms. CC issued patron announcement.

Log Entered	1/08/2014 18:00 PM	Entered By	Minerva Colon
Event Date/Time	1/08/2014 18:00 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1507 hrs. - CH&RP (Terry) advises fire alarm testing will be conducted at new fire pump station.

1748 hrs. - CH&RP advises fire alarm testing complete.

Log Entered	1/08/2014 19:52 PM	Entered By	Minerva Colon
Event Date/Time	1/08/2014 19:52 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0810L Hgr 11 fire alarm testing by PA Electric shop, Jim.
0840L- Testing completed.

0830L- FAA Paulo advises testing being conducted at new ATCT
0932L- FAA completed testing.

0840L- Hgr 7 fire alam testing.
0945L- Testing completed.

0945L- Cooling towers testing by PA Electric.
1027L- Testing completed.

1210L ABM, Miguel, advises Delta Fire Panel Terminal D being inspected by fire craft.
1300L- ABM, Kevin, contacted and advises Inspection complete system is back online
1320L -ABM, Miguel, advises Delta Fire Panel Terminal D back offline.

1250L Voice mail left for ABM requesting more detail on construction.
1251L Delta Ops contacted requesting more information on construction; unable to reach ABM.

Log Entered	1/09/2014 12:45 PM	Entered By	Rosemary Millan
Event Date/Time	1/09/2014 12:45 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1458L - Cleantech Fire Watch in Hgr. #4 reports a large flow of water coming from pipe along the building inside the hangar.

AAL Facilities Maint, CH&RP, 90 notified and responding.

Upon arrival the water was flowing from inside the hangar onto the ramp and VSR. 90 & 98 notified.

Arrangements made with PA Maint. (Structural 7) to have Vac All truck and chem truck respond.

98 issued VORTEX to all airlines to use caution on "ZA".

1600L - CHRP, G. Frattali, advises both pipes secured, only residual water dripping.

1614L - PA Maint. Vac All and chem truck on scene with Struct. 7. 98 & 78 on scene with equipment treating the ramp.

Check of inside Hgr. 4 shows ground wet no ponding.

1630L - Mechanical 1 reports high pressure water to Hgr. 4 secured, Pump Station reset.

Firewatch remains in place.

Log Entered	1/09/2014 20:34 PM	Entered By	Yolanda Marrero
Event Date/Time	1/09/2014 20:34 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2255L- Delta ABM advises they will have their alarms in bypass mode for testing.

Log Entered	1/10/2014 22:56 PM	Entered By	Rosemary Millan
Event Date/Time	1/10/2014 22:55 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1444- Fire alarm from 3rd floor set off by worker for CHRP working on dry system.
1450- System reset.

Log Entered	1/11/2014 14:44 PM	Entered By	Joe Carney
Event Date/Time	1/11/2014 14:44 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0816L- CHRP, Peter, conducting fire & sprinkler testing at bldg 39, bldg 84 and auto shop.
0835L- CHRP completed testing.

0835L -CHRP conducting fire alarm testing.

Log Entered	1/14/2014 12:58 PM	Entered By	Rosemary Millan
Event Date/Time	1/14/2014 20:16 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0938L- FAA is conducting fire alarm testing at new ATCT.

Log Entered	1/15/2014 10:33 AM	Entered By	Rosemary Millan
Event Date/Time	1/15/2014 9:38 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

Fire Marshall and RE21 doing fire alarm testing at Hangar 7North.
0230- Test complete.

Log Entered	1/16/2014 1:23 AM	Entered By	Joe Carney
Event Date/Time	1/16/2014 1:23 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

ABM doing fire alarm testing at Term D.

Log Entered	1/16/2014 1:24 AM	Entered By	Joe Carney
Event Date/Time	1/16/2014 1:24 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0140- Checkpoint C.
PA Mt. Is doing work involving cutting of metal.
This and dust set off alarm.

Log Entered	1/16/2014 1:44 AM	Entered By	Joe Carney
Event Date/Time	1/16/2014 1:44 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0805L - FAA, Carmelo, testing firealarms at the ATCT.
0849L - Testing completed.

Log Entered	1/17/2014 13:39 PM	Entered By	Yolanda Marrero
Event Date/Time	1/17/2014 13:39 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2319- Term D in by-pass for alarm testing per ABM.
0448- System restored.

0010- P2 garage reduced power for electric check.
0131- System restored.

Log Entered	1/18/2014 1:57 AM	Entered By	Joe Carney
Event Date/Time	1/18/2014 1:57 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2339- ABM testing fire alarm system at Term D.

0452- system restored.

Log Entered	1/21/2014 4:54 AM	Entered By	Joe Carney
Event Date/Time	1/21/2014 4:54 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1834L Fire alarm activated UAL DD A/C East. Responded with PAPD faint odor of electrical burning at UAL Departures.
PA 1079 and CHRP notified. Ops CC sent out advisory announcement.

1840L Odor Dissipating.

1900L Odor has dissipated. PA 1079 reset boards. CHRP reset fans in building. PAPD, 71 securing. Ops CC sent out the closing announcement.

2230 Water flow alarm activated Air Canada CTB east. 71 CHRP PAPD responded and negative condition found, CHRP and 1079 provided resets.

2250L Fire alarm activated UAL DD A/C East. Responded with JM and PAPD faint odor of electrical burning at UAL Departures again. Negative condition. Concourse C and gate area inspected.
1079 R. Eng met with UAL mtc to locate possible cause of fire alarm coming from UAL fan room on third floor CTB. Negative results were found in the fan room Further investigations
at Gate C10 area if alarm triggers again.

PA Ops CC sent out all advisory announcements.

Log Entered	1/21/2014 19:13 PM	Entered By	Rosemary Millan
Event Date/Time	1/21/2014 19:13 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1817- ABM doing testing at Term C. Sprinkler in by-pass.

Log Entered	1/21/2014 19:17 PM	Entered By	Joe Carney
Event Date/Time	1/21/2014 19:17 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1453L - Firealarms activated "DAL TC XL3 FA", ABM, Lovell, notified, 71 responding.

PAPD Fire Marshall advised.

1455L - Terminal C (shuttle side) TSA checkpoint closed. Sprinkler pipe burst, negative condition. No injuries reported. One PTZ in vicinity of fire sprinkler head, HBE, G. Vickers notified.

Delta, Jeff Yanni, and Delta reps on scene. TSA Mgr., PAPD and ESU on scene.

Upon arrival, ABM staff commenced cleanup and capping of sprinkler pipe affected. Fire Marshall on scene advises he will remain with ABM until work is completed and will advise if Delta needs a fire watch.

As per TSA, Kevin Dowling, TSA screening point will remain closed for approximately 24 hours for cleanup. TSA briefed and will have extra staffing at the main checkpoint, six lanes open. No backups observed, terminal activity light.

Sgt. Goldberg on scene

1750L - PAPD Fire Marshall A. Baicich advises no fire watch necessary.

ATTACHMENTS

Term. C Shuttle Checkpoint (jpg)

Log Entered	1/22/2014 16:01 PM	Entered By	Yolanda Marrero
Event Date/Time	1/22/2014 16:01 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2021L - Fire alarms activated "Gate D1 SUB PNL ADM Club ALM".

1079 & CHRP notified.

AAL Bldg. Maint. Advised and responding to meet PA Electricians by Gate D1.

Log Entered	1/22/2014 20:51 PM	Entered By	Yolanda Marrero
Event Date/Time	1/22/2014 20:51 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1755L - Firealarms activated at DAL new in-line baggage CTX room, fire sprinkler pipe burst.

Upon arrival Delta employees and ABM had secured water supply and in process of cleanup.

2000L - Bag Room Supervisor Rich Vitzthum advises sprinkler head has been capped and fire watch on post.

TSA, Kevin Dowling, advises no impact to TSA equipment. Equipment is running but not been utilized until cleanup is completed.

Log Entered	1/22/2014 20:56 PM	Entered By	Yolanda Marrero
Event Date/Time	1/22/2014 20:56 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2305L Terminal C fire alarms in bypass mode. PAPD notified, VRH work.

Log Entered	1/23/2014 0:28 AM	Entered By	Rosemary Millan
Event Date/Time	1/22/2014 23:05 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2021L - Fire alarms activated "Gate D1 SUB PNL ADM Club ALM".

1079 & CHRP notified.

AAL Bldg. Maint. Advised and responding to meet PA Electricians by Gate D1.

2130L - PA Electricians advise troubled alarm in bypass, AAL posting fire watch guard at panel and to notify PA Electric Shop when problem has been corrected.

==========

01/23/14

1035L - Fire alarms activated "Gate D1 SUB PNL ADM Club ALM WF". PA Electric Shop responding. "CC" issued first audio message.

Met with AAL Bldg. Maint, PA Elect Shop in Concourse D. Negative condition. "CC" issued false audio message.

1130L - CHRP, J. Elliott, secured water flow by Gate D2. AAL, P. Baldasano, notified by PA Electric Shop and PAPD Fire Marshall system is on bypass again and needs a fire watch at the panel.

AAL, P. Baldasano, advised to notify PA Electric Shop once repairs are made to have panel restored.

1230L - Voicemail left for P. Baldasano to confirm fire watch in place.

Log Entered	1/23/2014 11:48 AM	Entered By	Yolanda Marrero
Event Date/Time	1/23/2014 11:48 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0835L - CHRP, Terry, conducting fire alarms testing in the west zone (Hertz, Avis, Flight Saftey, old post office, Delta Shuttle and fuel farm).

1150L - Fire alarms testing completed at the Fuel Farm.

Log Entered	1/23/2014 12:05 PM	Entered By	Yolanda Marrero
Event Date/Time	1/23/2014 12:05 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1420- Kevin from ABM is draining Term C sprinkler lines for repair.
PAPD Fire Marshall advised.
Fire Watch in place.
This is UFN.

1520- Term D has a firewatch as well due to freezing temperatures.

Log Entered	1/23/2014 14:23 PM	Entered By	Joe Carney
Event Date/Time	1/23/2014 14:23 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1541- Tim from CHRP doing alarm testing at new Pump Station.

Log Entered	1/23/2014 15:41 PM	Entered By	Joe Carney
Event Date/Time	1/23/2014 15:41 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2021L - Fire alarms activated "Gate D1 SUB PNL ADM Club ALM".

1079 & CHRP notified.

AAL Bldg. Maint. Advised and responding to meet PA Electricians by Gate D1.

2130L - PA Electricians advise troubled alarm in bypass, AAL posting fire watch guard at panel and to notify PA Electric Shop when problem has been corrected.

==========
01/23/14

1035L - Fire alarms activated "Gate D1 SUB PNL ADM Club ALM WF". PA Electric Shop responding. "CC" issued first audio message.

Met with AAL Bldg. Maint, PA Elect Shop in Concourse D. Negative condition. "CC" issued false audio message.

1130L - CHRP, J. Elliott, secured water flow by Gate D2. AAL, P. Baldasano, notified by PA Electric Shop and PAPD Fire Marshall system is on bypass again and needs a fire watch at the panel.

AAL, P. Baldasano, advised to notify PA Electric Shop once repairs are made to have panel restored.

1230L - Voicemail left for P. Baldasano to confirm fire watch in place.
==========
1/23/14
1530- Spoke with P. Baldasano who acknowledged that he will have a FW on site tonight UFN till repair made.
1630- FW placed.

Log Entered	1/23/2014 15:42 PM	Entered By	Joe Carney
Event Date/Time	1/23/2014 15:42 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2230L MPD Ops mgr Julio advises Fire alarm testing to be conducted tonight with PA Fire Marshall (AB)

0010L Fire Alam testing commencing.
0242L Fire Alarm testing completed. 1079 provided reset of fireboards.

Log Entered	1/24/2014 3:41 AM	Entered By	Rosemary Millan
Event Date/Time	1/24/2014 3:41 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0800L - CHRP, Terry, testing alarms in the CTB.
1300L - Testing completed.

Log Entered	1/24/2014 10:18 AM	Entered By	Yolanda Marrero
Event Date/Time	1/24/2014 10:18 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1400- ATCT conducting alarm testing.
1439- Test complete.

Log Entered	1/24/2014 14:28 PM	Entered By	Joe Carney
Event Date/Time	1/24/2014 14:28 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1701- Term C arrivals alarm system.
Call to ABM.
ABM advises that this was a pull station malfunction.
ABM had a second malfunction.

Log Entered	1/24/2014 19:01 PM	Entered By	Joe Carney
Event Date/Time	1/24/2014 19:01 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2130- False alarm at H-5B.

AAL Mt responded with PAPD.

AAL advised they had a recent problem with this.

Log Entered	1/26/2014 22:05 PM	Entered By	Joe Carney
Event Date/Time	1/26/2014 22:05 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0040L ABM conducting fire alarm testing at Terminal D until 0230L ; system in bypass.

Log Entered	1/27/2014 0:51 AM	Entered By	Rosemary Millan
Event Date/Time	1/27/2014 0:40 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2130- False alarm at H-5B.

AAL Mt responded with PAPD.

AAL advised they had a recent problem with this.

0440L Air Canada, Toni, advises Fire alarm activated at hgr H5B; loud audible.
0443L AAL facilities notified.

0859- H-5B has alarm going off again.
AAL facilities advised.

Log Entered	1/27/2014 8:58 AM	Entered By	Joe Carney
Event Date/Time	1/27/2014 8:58 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0822- CHRP conducting alarm testing in CTB.

Log Entered	1/27/2014 8:59 AM	Entered By	Joe Carney
Event Date/Time	1/27/2014 8:59 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2100- Fire Alarm for AAL admirals Club.

PA electric responded.

AAL had a frozen pipe and system was alarming.
PA Electric attempting to isolate and by-pass.

Log Entered	1/27/2014 21:45 PM	Entered By	Joe Carney
Event Date/Time	1/27/2014 21:45 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2100- Fire Alarm for AAL admirals Club.

PA electric responded.

AAL had a frozen pipe and system was alarming.
PA Electric attempting to isolate and by-pass.

01/28/14
2200L PA Electrical advises gate D1 Admirals club area fire protection is partially disabled. AAL has Clean Tech providing firewacth until further notice.

Log Entered	1/28/2014 4:15 AM	Entered By	Rosemary Millan
Event Date/Time	1/28/2014 4:15 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0843L - CHRP, Terry, testing fire alarms in Terminal D.

0854L - Elect Shop, Steve, testing alarms in Hgr. 7N.

Log Entered	1/28/2014 11:56 AM	Entered By	Yolanda Marrero
Event Date/Time	1/28/2014 11:56 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1400- Fire alarm in 3636A room. Alarm was in AAL baggage room and the result of a smoke detector that had a sensor blocked by dust from the chemical used to prevent ice build up.
1450- System returned to normal.

1531- CHRP testing sprinklers in H5A.

Log Entered	1/28/2014 15:28 PM	Entered By	Joe Carney
Event Date/Time	1/28/2014 15:28 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1450- Term C-shuttle side fire alarm system back on line, per ABM.

Log Entered	1/28/2014 15:54 PM	Entered By	Joe Carney
Event Date/Time	1/28/2014 15:54 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1000L - FAA, Carmelo, testing fire alarms in the ATCT.
1145L - Testing completed.

Log Entered	1/29/2014 11:47 AM	Entered By	Yolanda Marrero
Event Date/Time	1/29/2014 11:47 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

Paul B. from AAL doing alarm testing in H-1/3/5. System in by-pass.

Log Entered	1/29/2014 15:07 PM	Entered By	Joe Carney
Event Date/Time	1/29/2014 15:07 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0810L CHRP Pete advises fire alarm testing at Hgr 1,3,5, 5A: PAPD notified.
1242L CHRP testing completed.

1100L ABM terminal C has fire alarm system in bypass mode;PAPD
1240L Terminal C system back on line. PAPD notified.

Log Entered	1/30/2014 8:38 AM	Entered By	Rosemary Millan
Event Date/Time	1/30/2014 8:38 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1515- CHRP conducting alarm testing at HP Pump Station.
1704- Test complete.

1530- Electric Shop conducting alarm testing at H- 7.
1804- Test complete.

Log Entered	1/30/2014 20:03 PM	Entered By	Joe Carney
Event Date/Time	1/30/2014 20:03 PM		

FIRE ALARMS - Entered By: Joe Carney

Related Item(s): <NONE> GO

Modification(s): <NONE> GO

Date/Time Entered: 2/1/201401:11

Event Date Time: 02/01/2014 01:11

Entry Last Updated: 02/01/2014 02:31 Joe Carney

Entry Closed:
Add to SMS

Print

Save

Form Event Routing

CTB alarm system in by-pass for testing.
R. Eng on duty.

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1159 hrs. - Fire Alarm activated - Hgr. 4 fire alarmm Deluge Value #6 Waterflow. CH&RP and AAL Bldg. Mtce notified.

1205 hrs. - AAL Bldg. Mtce. advise negative condition. Fire alarm not active - Fire watch is in place in Hgr. 4. PAPD notified.

Log Entered	2/01/2014 13:14 PM	Entered By	Minerva Colon
Event Date/Time	2/01/2014 13:14 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0730- TSA break room set off overhead fire alarm due to toast.
PA Electric and CHRP reset.

Log Entered	2/03/2014 7:54 AM	Entered By	Joe Carney
Event Date/Time	2/03/2014 7:54 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1542- ABM had a alarm at Term C.
1613- resolved.

Log Entered	2/04/2014 16:32 PM	Entered By	Joe Carney
Event Date/Time	2/04/2014 16:32 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0909- Struc 3 reports NYFD responding H-7/MAT with 2 pieces of equipment-unknown call.
72 directed to respond and investigate.

100 reports that H-7 pull box was used. CC did not have alarm.
1079 asked to respond.

PAPD apprehended a homeless gentleman who was witnessed pulling alarm.
PAPD request ambulance for gent, possible 48.

72 reports FD- Companies 263/117 standing by for Electric response.

0917- All equipment clear.

Log Entered	2/05/2014 9:00 AM	Entered By	Joe Carney
Event Date/Time	2/05/2014 9:00 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1232 hrs. - Fire alarms activated: SD CTB Arrivals slide door Cont. Air; SD CTB Continental Baggage. PAPD, CH&RP, & Electric shop notified.

1233 hrs. - CC issued Audio announcement.

1236 hrs. - 71, PAPD, and Mechanical 1 on scene. Negative condition found. CC issued Audio announcement.

1242 hrs. - 1079 on scene. Two sensors needed to be reset - 1 by BR 13 and one by small bag door.

1255 hrs. - Electricians advise fire alarms B/I/S. Mechanical 1 notified.

Log Entered	2/06/2014 15:11 PM	Entered By	Minerva Colon
Event Date/Time	2/06/2014 15:11 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0749 hrs. - TSA Ops (Linda) advises alarm ringing in concourse C bag room.
No alarms ringing anywhere else in CTB. OCC Fire alarm panel shows negative condition.

0753 hrs. - Electric Shop notified. Advise they have no alarm on their board.

0805 hrs. - ABM advises fire alarm ringing in their office room 3925. Electric shop notified. R. Eng advises he is checking CTB.

0810 hrs. - CC issued message about fire alarms.

0811 hrs. - Ops and arrivals level strobes activated.

0818 hrs. - Fire alarm activated in center food court. CC advises alarms are not on fire alarm panel.

0824 hrs. - TSA called again about alarms and advised we are investigating.

0829 hrs. - Alarms have been reset.

0852 hrs. - Electric Shop continues investigating cause and solution.

Log Entered	2/06/2014 16:43 PM	Entered By	Minerva Colon
Event Date/Time	2/06/2014 16:43 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1845L Terminal D "SD" Prime Tavern alarm activated.
1846L ABM notified and are investigating.
1903L ABM advises false alarm due to smoke; possible kitchen cooking.

Log Entered	2/06/2014 19:09 PM	Entered By	Rosemary Millan
Event Date/Time	2/06/2014 18:45 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1500L Lou, FAA conducting fire alarm testing at new ATCT.
1530L Fire alarm testing at new ATCT completed.

Log Entered	2/07/2014 21:38 PM	Entered By	Rosemary Millan
Event Date/Time	2/07/2014 15:00 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0732 hrs. - ABM (Anthony) advises fire alarm testing in Terminal D. Alarm system on bypass.

Log Entered	2/11/2014 14:01 PM	Entered By	Minerva Colon
Event Date/Time	2/11/2014 14:01 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1444L CHRP Terry advises they are testing at new pump station.
1655L New pump station testing completed.

1624L CHRP George advises testing all CTB fire alarms; no audibles.

Log Entered	2/11/2014 17:20 PM	Entered By	Rosemary Millan
Event Date/Time	2/11/2014 14:44 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

2310L - Firealarms activated "SD CTB EAST, Continental baggage". Responded with 1079 and CHRP.

"CC" issuing investigation audio message.

2320L - Negative condition, "CC" issuing audio message.

2330L - 1079 reset system, "SD" found activated in the bagroom due to numberous baggage carts entering the area to park overnight.

Log Entered	2/13/2014 3:02 AM	Entered By	Yolanda Marrero
Event Date/Time	2/13/2014 3:02 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0809 hrs. - Fire alarms activated. CTB West FA 1st & 2nd fl; Rm 3636A; Fan rm 2 & 8. PAPD, 1079, & CH&RP notified.

0810 hrs. - OCC issued audio announcement.

0835 hrs. - Negative condition found. Electric and CH&RP are troubleshooting problem. PAPD notified. Once resolved, 1079 will notify.

0837 hrs. - OCC issued audio announcement - investigation complete. Alarms reset.

1100 hrs. - 1079 (G. Weekly) continue troubleshooting problem.

1205 hrs. - 1079 advises unable to trace sprinkler head problem and fire watch will be required for AAL baggage room BR 2 & BR 3 (belt "B & C").
Allied Barton TS Gibbons notified. AAL notified.

Log Entered	2/16/2014 11:40 AM	Entered By	Minerva Colon
Event Date/Time	2/16/2014 11:40 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0530L Allied Barton T/S advises Hgr 5A guard repsorts fire alarm indicating fire alarm for Hgr 11

0532L PA1079, Tom, notified at Hgr 11 and they are investigating.

Log Entered	2/17/2014 5:34 AM	Entered By	Rosemary Millan
Event Date/Time	2/17/2014 5:34 AM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

0809 hrs. - Fire alarms activated. CTB West FA 1st & 2nd fl; Rm 3636A; Fan rm 2 & 8. PAPD, 1079, & CH&RP notified.

0810 hrs. - OCC issued audio announcement.

0835 hrs. - Negative condition found. Electric and CH&RP are troubleshooting problem. PAPD notified. Once resolved, 1079 will notify.

0837 hrs. - OCC issued audio announcement - investigation complete. Alarms reset.

1100 hrs. - 1079 (G. Weekly) continue troubleshooting problem.

1205 hrs. - 1079 advises unable to trace sprinkler head problem and fire watch will be required for AAL baggage room BR 2 & BR 3 (belt "B & C").
Allied Barton TS Gibbons notified. AAL notified.

****
02-18-14 @ 1430 hrs.

Contacted Electric shop (Kennedy) who advises he will check into problem.

1445 hrs. - Electric shop advises this is AAL Bldg. Mtce. responsibility. They will assist AAL if needed. AAL Bldg. Mtce. (476-4011) notified and sending staff over to check sprinkler and smoke heads. Request assistance from PA. 1079 notified.

1510 hrs. - AAL notified we are securing our fire watch guard. Fire watch is their responsibility.

1635 hrs. - Electric shop advises fire alarms have been reset. AAL bldg. maintenance have completed checking/replacing/cleaning sprinkler heads/smoke detectors.

Log Entered	2/18/2014 15:17 PM	Entered By	Minerva Colon
Event Date/Time	2/18/2014 15:17 PM		

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

Airport Operations

FIRE ALARMS

1540 hrs. - Aviation Safeguard reports alarm activated AAL hangar 5, room 505. AAL bldg. mtce. (Scott) notified and staff will respond.

1610 hrs. - Alarm reset.

Log Entered	2/18/2014 15:43 PM	Entered By	Minerva Colon
Event Date/Time	2/18/2014 15:44 PM		

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072030	788169	CO	TEST FIRE ALARMS DEVICES - CTB WEST	307	101	ACTIVE		TS	5/9/2013	11X0A0230703512100001	64	20
LGA	3072031	788171	CO	TEST FIRE ALARMS DEVICES - CTB EAST	307	101	ACTIVE		TS	5/9/2013	11X0A0230703512100001	64	20
LGA	3072032	788172	CO	TEST FIRE ALARMS DEVICES - HANGAR 7	307	101	ACTIVE		TS	5/9/2013	11X0A0230703512100001	32	40
LGA	3072033	788173	CO	TEST FIRE ALARMS DEVICES - HANGAR 11	307	101	ACTIVE		TS	5/9/2013	11X0A0230703512100001	32	0
LGA	3072034	788174	CO	TEST FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	ACTIVE		TS	5/9/2013	11X0A0230703512100001	16	0
LGA	3072035	788175	CO	TEST FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	ACTIVE		TS	5/9/2013	11X0A0230703512100001	16	0
LGA	3072040	836560	CO	TEST FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	ACTIVE		C1	10/21/2014	11X0A0230703512100001	48	27.5
LGA	3072044	776758	CO	TEST FIRE ALARMS DEVICES - WEST END SUBSTATION	307	101	ACTIVE		TS	1/30/2013	11X0A0230703S12100001	16	0
LGA	3072048	776685	CO	TEST FIRE ALARMS DEVICES - BUILDINGS NOS. 82 AND 83	307	101	ACTIVE		TS	1/15/2013	11X0A0230703512100001	32	0
LGA	30720S0	788177	CO	INSPECT FIRE ALARMS DEVICES - CTB WEST	307	101	CLOSED	7/31/2013	IR	5/10/2013	11X0A0230703512100001	16	0
LGA		712991	CO	FIRE ALARM REPAIR	307	101	CLOSED	1/5/2012	RP	1/3/2011	11X0A0230703512100001	560	2154
LGA		727908	CO	REPAIR A/C UINT IN FIRE ALARM STORAGE ROOM	309	401	CLOSED	1/24/2012	RP	6/13/2011	11X0A0230903445100001	16	8.5
LGA		745869	CO	FIRE ALARM REPAIR	307	101	CLOSED	1/8/2013	RP	1/1/2012	11X0A0230703512100001	560	1858
LGA		750727	CO	TEST FIRE ALARMS DEVICES - BUILDING 28	307	101	CLOSED	9/11/2013	TS	3/27/2012	11X0A0230703512100001	32	80
LGA		755879	CO	SUPPORT ASSET MGMT FIRE ALARMS INVENTORY	307	101	CLOSED	2/10/2014	AO	5/7/2012	11X0A0230703512100001	96	20
LGA		763831	CO	PROVIDE FIRE ALARMS SIGNAL FEED FOR PIV @ AMF	307	101	CLOSED	9/25/2012	NC	8/23/2012	11X0A0230703512100001	24	8
LGA		766259	CO	RELOCATE FIRE ALARMS DEVICES @ PL2	307	101	CLOSED	10/18/2012	RE	9/11/2012	11X0A0230703537100001	32	11
LGA		769274	CO	ASSIST ELECTRICAL WITH TROUBLESHOOTING FIRE ALARMS IN PL2	309	401	CLOSED	12/2/2012	TS	10/2/2012	11X0A0230903437100001	4	4
LGA		776603	CO	FIRE ALARM REPAIR	307	101	CLOSED	1/14/2014	RP	1/3/2013	11X0A0230703512100001	560	1110
LGA		785470	CO	REPLACE FIRE ALARMS PANELS BATTERIES AS PER CH&RP LIST	307	101	CLOSED	2/10/2014	RE	4/20/2013	11X0A0230703512200001	16	8
LGA		790861	CO	TEST FIRE ALARMS DEVICES - HIGH PRESSURE PUMP STATION	307	101	ACTIVE		TS	6/4/2013	11X0A0230703512100001	2	54
LGA		793707	CO	CTB FIRE ALARM TESTING HV1	309	401	CLOSED	8/13/2013	TS	7/12/2013	11X0A0230903436000001	4	8
LGA		799337	CO	TEST FIRE ALARMS DEVICES - MARINE AIR TERMINAL	307	101	ACTIVE		C1	9/21/2013	11X0A0230703512100001	16	28
LGA		799338	CO	TEST FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	ACTIVE		C1	9/21/2013	11X0A0230703512100001	16	8
LGA		799339	CO	TEST FIRE ALARMS DEVICES - HANGAR 5A	307	101	CANCEL	9/21/2013	C1	9/21/2013	11X0A0230703512100001	16	0
LGA		799340	CO	TEST FIRE ALARMS DEVICES - HIGH PRESSURE PUMP STATION	307	101	CANCEL	9/21/2013	C1	9/21/2013	11X0A0230703512100001	2	0
LGA		809975	CO	FIRE ALARMS REPAIRS	307	101	ACTIVE		RP	1/18/2014	11X0A0230703512100001	640	1145.5
LGA		810004	CO	INSTALL HORN AND STROBE FOR FIRE ALARM HGR 7	307	101	CLOSED	7/31/2014	RP	1/25/2014	11X0A0230703543300001	36	31
LGA		833730	EM	RESPOND TO WATER FLOW FIRE ALARM, COLING TOWER	309	401	CLOSED	10/2/2014	RS	9/15/2014	11X0A0230903436000001	0	2
LGA	3072030	738689	PM	TEST FIRE ALARMS DEVICES - CTB WEST	307	101	CANCEL	1/26/2013	TS	1/9/2012	11X0A0230703512100001	64	0
LGA	3072030	743491	PM	TEST FIRE ALARMS DEVICES - CTB WEST	307	101	CLOSED	2/13/2013	TS	1/7/2013	11X0A0230703512100001	64	16
LGA	3072030	774236	PM	TEST FIRE ALARMS DEVICES - CTB WEST	307	101	CLOSED	4/8/2014	C1	1/6/2014	11X0A0230703512100001	64	4
LGA	3072031	738690	PM	TEST FIRE ALARMS DEVICES - CTB EAST	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	64	0
LGA	3072031	743492	PM	TEST FIRE ALARMS DEVICES - CTB EAST	307	101	CANCEL	4/30/2013	TS	1/7/2013	11X0A0230703512100001	64	0
LGA	3072031	774237	PM	TEST FIRE ALARMS DEVICES - CTB EAST	307	101	CANCEL	6/9/2014	C1	1/6/2014	11X0A0230703512100001	64	0
LGA	3072032	738691	PM	TEST FIRE ALARMS DEVICES - HANGAR 7	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	32	0
LGA	3072032	743493	PM	TEST FIRE ALARMS DEVICES - HANGAR 7	307	101	CANCEL	3/11/2013	TS	1/7/2013	11X0A0230703512100001	32	0
LGA	3072032	774238	PM	TEST FIRE ALARMS DEVICES - HANGAR 7	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	32	0
LGA	3072033	738692	PM	TEST FIRE ALARMS DEVICES - HANGAR 11	307	101	CANCEL	7/14/2012	TS	1/9/2012	11X0A0230703512100001	32	0
LGA	3072033	743494	PM	TEST FIRE ALARMS DEVICES - HANGAR 11	307	101	CANCEL	3/19/2013	TS	1/7/2013	11X0A0230703512100001	32	0
LGA	3072033	774239	PM	TEST FIRE ALARMS DEVICES - HANGAR 11	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	32	0
LGA	3072034	740986	PM	TEST FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	16	0
LGA	3072034	743495	PM	TEST FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	CANCEL	3/20/2013	TS	1/7/2013	11X0A0230703512100001	16	0
LGA	3072034	774240	PM	TEST FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	16	0
LGA	3072035	740987	PM	TEST FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	16	0

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072035	743496	PM	TEST FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	CLOSED	3/11/2013	TS	1/7/2013	11X0A0230703512100001	16	16
LGA	3072035	774241	PM	TEST FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	16	0
LGA	3072036	740988	PM	TEST FIRE ALARMS DEVICES - PARKING GARAGE	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	32	0
LGA	3072036	743497	PM	TEST FIRE ALARMS DEVICES - PARKING GARAGE	307	101	CANCEL	10/17/2013	TS	1/7/2013	11X0A0230703512100001	32	0
LGA	3072036	774242	PM	TEST FIRE ALARMS DEVICES - PARKING GARAGE	307	101	CLOSED	8/23/2014	C1	1/6/2014	11X0A0230703512100001	32	16
LGA	3072037	740989	PM	TEST FIRE ALARMS DEVICES - HANGAR 5A	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	16	0
LGA	3072037	743498	PM	TEST FIRE ALARMS DEVICES - HANGAR 5A	307	101	CANCEL	10/17/2013	TS	1/7/2013	11X0A0230703512100001	16	0
LGA	3072037	774243	PM	TEST FIRE ALARMS DEVICES - HANGAR 5A	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	16	0
LGA	3072038	740990	PM	TEST FIRE ALARMS DEVICES - DELTA TAXI CHUTE	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	16	0
LGA	3072038	743499	PM	TEST FIRE ALARMS DEVICES - DELTA TAXI CHUTE	307	101	CANCEL	10/17/2013	TS	1/7/2013	11X0A0230703512100001	16	0
LGA	3072038	774244	PM	TEST FIRE ALARMS DEVICES - DELTA TAXI CHUTE	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	16	0
LGA	3072039	740991	PM	TEST FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	16	0
LGA	3072039	743500	PM	TEST FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	CANCEL	4/30/2013	TS	1/7/2013	11X0A0230703512100001	16	0
LGA	3072039	774245	PM	TEST FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	16	0
LGA	3072040	740992	PM	TEST FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	48	0
LGA	3072040	743501	PM	TEST FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	CLOSED	7/31/2014	TS	1/7/2013	11X0A0230703512100001	48	2
LGA	3072040	774246	PM	TEST FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	CLOSED	7/31/2014	C1	1/6/2014	11X0A0230703512100001	48	22
LGA	3072041	740993	PM	TEST FIRE ALARMS DEVICES - MARINE AIR TERMINAL	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	16	0
LGA	3072041	743502	PM	TEST FIRE ALARMS DEVICES - MARINE AIR TERMINAL	307	101	CANCEL	7/31/2013	TS	1/7/2013	11X0A0230703512100001	16	0
LGA	3072041	774247	PM	TEST FIRE ALARMS DEVICES - MARINE AIR TERMINAL	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	16	0
LGA	3072042	740994	PM	TEST FIRE ALARMS DEVICES - POLICE EMERGENCY GARAGE	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	16	0
LGA	3072042	743503	PM	TEST FIRE ALARMS DEVICES - POLICE EMERGENCY GARAGE	307	101	ACTIVE		TS	1/7/2013	11X0A0230703512100001	16	0
LGA	3072042	774248	PM	TEST FIRE ALARMS DEVICES - POLICE EMERGENCY GARAGE	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	16	0
LGA	3072043	740995	PM	TEST FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	2	0
LGA	3072043	743504	PM	TEST FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	ACTIVE		TS	1/7/2013	11X0A0230703512100001	2	0
LGA	3072043	774249	PM	TEST FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	2	0
LGA	3072044	745903	PM	TEST FIRE ALARMS DEVICES - WEST END SUBSTATION	307	101	CLOSED	1/25/2012	TS	1/6/2012	11X0A0230703512100001	16	3
LGA	3072044	746085	PM	TEST FIRE ALARMS DEVICES - WEST END SUBSTATION	307	101	CANCEL	1/26/2013	TS	1/11/2013	11X0A0230703512100001	16	0
LGA	3072044	774250	PM	TEST FIRE ALARMS DEVICES - WEST END SUBSTATION	307	101	CLOSED	1/28/2014	C1	1/10/2014	11X0A0230703512100001	16	16
LGA	3072045	745904	PM	TEST FIRE ALARMS DEVICES - HIGH PRESSURE PUMP STATION	307	101	CLOSED	1/25/2012	TS	1/6/2012	11X0A0230703512100001	2	11
LGA	3072045	746086	PM	TEST FIRE ALARMS DEVICES - HIGH PRESSURE PUMP STATION	307	101	CANCEL	1/26/2013	TS	1/11/2013	11X0A0230703512100001	2	0
LGA	3072045	774251	PM	TEST FIRE ALARMS DEVICES - HIGH PRESSURE PUMP STATION	307	101	CANCEL	1/28/2014	C1	1/10/2014	11X0A0230703512100001	2	0
LGA	3072046	745924	PM	TEST FIRE ALARMS DEVICES - BUILDING 39 PA WELD SHOP	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703512100001	8	0
LGA	3072046	746087	PM	TEST FIRE ALARMS DEVICES - BUILDING 39 PA WELD SHOP	307	101	ACTIVE		TS	1/14/2013	11X0A0230703512100001	8	0
LGA	3072046	774252	PM	TEST FIRE ALARMS DEVICES - BUILDING 39 PA WELD SHOP	307	101	CLOSED	1/28/2014	C1	1/13/2014	11X0A0230703512100001	8	16
LGA	3072047	753474	PM	TEST FIRE ALARMS DEVICES - BUILDING 28	307	101	ACTIVE		TS	1/7/2013	11X0A0230703512100001	32	0
LGA	3072047	774253	PM	TEST FIRE ALARMS DEVICES - BUILDING 28	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	32	0
LGA	3072048	776859	PM	TEST FIRE ALARMS DEVICES - BUILDINGS NO. 87	307	101	ACTIVE		C1	1/6/2014	11X0A0230703512100001	32	0
LGA	3072050	740996	PM	INSPECT FIRE ALARMS DEVICES - CTB WEST	307	101	CLOSED	2/1/2013	IR	1/2/2012	11X0A0230703512100001	16	0
LGA	3072050	740997	PM	INSPECT FIRE ALARMS DEVICES - CTB WEST	307	101	CLOSED	2/1/2013	IR	7/2/2012	11X0A0230703512100001	16	0
LGA	3072050	740998	PM	INSPECT FIRE ALARMS DEVICES - CTB WEST	307	101	CLOSED	3/11/2013	IR	12/31/2012	11X0A0230703512100001	16	4
LGA	3072050	758798	PM	INSPECT FIRE ALARMS DEVICES - CTB WEST	307	101	CLOSED	10/29/2013	IR	7/1/2013	11X0A0230703512100001	120	10
LGA	3072050	771845	PM	INSPECT FIRE ALARMS DEVICES - CTB WEST	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	120	16
LGA	3072050	788297	PM	INSPECT FIRE ALARMS DEVICES - CTB WEST	307	101	CLOSED	3/5/2014	C1	6/30/2014	11X0A0230703512100001	120	8
LGA	3072052	741002	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 7	307	101	CLOSED	2/1/2013	IR	1/2/2012	11X0A0230703512100001	8	0
LGA	3072052	741003	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 7	307	101	CLOSED	2/1/2013	IR	7/2/2012	11X0A0230703512100001	8	0
LGA	3072052	741004	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 7	307	101	CANCEL	4/30/2013	IR	12/31/2012	11X0A0230703512100001	8	0

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	30720S2	758800	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 7	307	101	CLOSED	6/25/2013	IR	7/1/2013	11X0A0230703S12100001	8	8
LGA	30720S2	788448	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 7	307	101	ACTIVE		C1	12/30/2013	11X0A0230703S12100001	8	0
LGA	3072052	771847	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 7	307	101	CANCEL	10/17/2013	C1	12/30/2013	11X0A0230703S12100001	8	0
LGA	30720S2	80218S	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 7	307	101	ACTIVE		C1	6/30/2014	11X0A0230703S12100001	8	0
LGA	3072053	74100S	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 11	307	101	CLOSED	2/1/2013	TS	1/2/2012	11X0A0230703S12100001	8	0
LGA	3072053	741006	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 11	307	101	CLOSED	2/1/2013	TS	7/2/2012	11X0A0230703S12100001	8	0
LGA	3072053	741007	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 11	307	101	CLOSED	4/30/2013	TS	12/31/2012	11X0A0230703S12100001	8	0
LGA	30720S3	758801	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 11	307	101	ACTIVE		TS	7/1/2013	11X0A0230703S12100001	8	0
LGA	30720S3	771848	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 11	307	101	ACTIVE		C1	12/30/2013	11X0A0230703S12100001	8	0
LGA	30720S3	788449	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 11	307	101	ACTIVE		C1	6/30/2014	11X0A0230703S12100001	8	0
LGA	3072054	741008	PM	INSP FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	CLOSED	2/1/2013	TS	1/9/2012	11X0A0230703S12100001	8	0
LGA	30720S4	741009	PM	INSPECT FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	CLOSED	2/1/2013	TS	7/2/2012	11X0A0230703S12100001	8	0
LGA	3072054	743S0S	PM	INSPECT FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703S12100001	8	0
LGA	30720S4	758802	PM	INSPECT FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	ACTIVE		TS	7/1/2013	11X0A0230703S12100001	8	0
LGA	3072054	771849	PM	INSPECT FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	ACTIVE		C1	12/30/2013	11X0A0230703S12100001	8	0
LGA	3072054	788450	PM	INSPECT FIRE ALARMS DEVICES - BUILDING 84 PA AUTO SHOP	307	101	ACTIVE		C1	6/30/2014	11X0A0230703S12100001	8	0
LGA	3072055	741010	PM	INSPECT FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	CLOSED	2/1/2013	TS	1/2/2012	11X0A0230703S12100001	4	0
LGA	3072055	741011	PM	INSPECT FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	CLOSED	2/1/2013	TS	7/2/2012	11X0A0230703S12100001	4	0
LGA	3072055	741012	PM	INSPECT FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703S12100001	4	0
LGA	3072055	7S8803	PM	INSPECT FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	ACTIVE		TS	7/1/2013	11X0A0230703S12100001	4	0
LGA	30720S5	771850	PM	INSPECT FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	ACTIVE		C1	12/30/2013	11X0A0230703S12100001	4	0
LGA	30720S5	788451	PM	INSPECT FIRE ALARMS DEVICES - FIRE PUMP STATION BLDG. 20	307	101	ACTIVE		C1	6/30/2014	11X0A0230703S12100001	4	0
LGA	3072056	741013	PM	INSPECT FIRE ALARMS DEVICES - PARKING GARAGE	307	101	CLOSED	2/1/2013	TS	1/2/2012	11X0A0230703S12100001	8	0
LGA	30720S6	741014	PM	INSPECT FIRE ALARMS DEVICES - PARKING GARAGE	307	101	CLOSED	2/1/2013	TS	7/2/2012	11X0A0230703S12100001	8	0
LGA	3072056	741015	PM	INSPECT FIRE ALARMS DEVICES - PARKING GARAGE	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703S12100001	8	0
LGA	3072056	7S8804	PM	INSPECT FIRE ALARMS DEVICES - PARKING GARAGE	307	101	ACTIVE		TS	7/1/2013	11X0A0230703S12100001	8	0
LGA	3072056	7718S1	PM	INSPECT FIRE ALARMS DEVICES - PARKING GARAGE	307	101	ACTIVE		C1	12/30/2013	11X0A0230703S12100001	8	0
LGA	3072056	788452	PM	INSPECT FIRE ALARMS DEVICES - PARKING GARAGE	307	101	CLOSED	3/5/2014	C1	6/30/2014	11X0A0230703S12100001	8	2
LGA	30720S7	741016	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 5A	307	101	CLOSED	2/1/2013	TS	1/2/2012	11X0A0230703S12100001	8	0
LGA	3072057	741017	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 5A	307	101	CLOSED	2/1/2013	TS	7/2/2012	11X0A0230703S12100001	8	0
LGA	3072057	741018	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 5A	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703S12100001	8	0
LGA	30720S7	758805	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 5A	307	101	ACTIVE		TS	7/1/2013	11X0A0230703S12100001	8	0
LGA	3072057	771852	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 5A	307	101	ACTIVE		C1	12/30/2013	11X0A0230703S12100001	8	0
LGA	3072057	788453	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 5A	307	101	ACTIVE		C1	6/30/2014	11X0A0230703S12100001	8	0
LGA	30720S8	741019	PM	INSPECT FIRE ALARMS DEVICES - DELTA TAXI CHUTE	307	101	CLOSED	2/1/2013	TS	1/2/2012	11X0A0230703S12100001	4	0
LGA	30720S8	741020	PM	INSPECT FIRE ALARMS DEVICES - DELTA TAXI CHUTE	307	101	CLOSED	2/1/2013	TS	7/2/2012	11X0A0230703S12100001	4	0
LGA	3072058	741021	PM	INSPECT FIRE ALARMS DEVICES - DELTA TAXI CHUTE	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703S12100001	4	0
LGA	30720S8	758806	PM	INSPECT FIRE ALARMS DEVICES - DELTA TAXI CHUTE	307	101	ACTIVE		TS	7/1/2013	11X0A0230703S12100001	4	0
LGA	3072058	771853	PM	INSPECT FIRE ALARMS DEVICES - DELTA TAXI CHUTE	307	101	ACTIVE		C1	12/30/2013	11X0A0230703S12100001	4	0
LGA	3072058	788454	PM	INSPECT FIRE ALARMS DEVICES - DELTA TAXI CHUTE	307	101	ACTIVE		C1	6/30/2014	11X0A0230703S12100001	4	0
LGA	30720S9	741022	PM	INSPECT FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	CLOSED	2/1/2013	TS	1/2/2012	11X0A0230703S12100001	16	0
LGA	3072059	741023	PM	INSPECT FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	CLOSED	2/1/2013	TS	7/2/2012	11X0A0230703S12100001	16	0
LGA	30720S9	741024	PM	INSPECT FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703S12100001	16	0
LGA	3072059	758807	PM	INSPECT FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	ACTIVE		TS	7/1/2013	11X0A0230703S12100001	16	0
LGA	3072059	771854	PM	INSPECT FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	ACTIVE		C1	12/30/2013	11X0A0230703S12100001	16	0
LGA	3072059	788455	PM	INSPECT FIRE ALARMS DEVICES - WEST FIELD LIGHTING VAULT	307	101	ACTIVE		C1	6/30/2014	11X0A0230703S12100001	16	0
LGA	3072060	741025	PM	INSPECT FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	CLOSED	2/1/2013	IR	1/2/2012	11X0A0230703S12100001	16	0

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072060	741026	PM	INSPECT FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	CLOSED	2/1/2013	IR	7/2/2012	11X0A0230703512100001	16	0
LGA	3072060	741027	PM	INSPECT FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	CLOSED	5/28/2013	IR	12/31/2012	11X0A0230703512100001	16	16
LGA	3072060	7S8808	PM	INSPECT FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	ACTIVE		IR	7/1/2013	11X0A0230703512100001	16	0
LGA	3072060	7718SS	PM	INSPECT FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	16	0
LGA	3072060	7884S6	PM	INSPECT FIRE ALARMS DEVICES - ARFF COMPLEX	307	101	CLOSED	8/23/2014	C1	6/30/2014	11X0A0230703512100001	16	16
LGA	3072061	741028	PM	INSPECT FIRE ALARMS DEVICES - MARINE AIR TERMINAL	307	101	CLOSED	2/1/2013	TS	1/2/2012	11X0A0230703512100001	8	0
LGA	3072061	741029	PM	INSPECT FIRE ALARMS DEVICES - MARINE AIR TERMINAL.	307	101	CLOSED	2/1/2013	TS	7/2/2012	11X0A0230703512100001	8	0
LGA	3072061	741030	PM	INSPECT FIRE ALARMS DEVICES - MARINE AIR TERMINAL	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703512100001	8	0
LGA	3072061	758809	PM	INSPECT FIRE ALARMS DEVICES - MARINE AIR TERMINAL	307	101	CLOSED	11/16/2013	TS	7/1/2013	11X0A0230703512100001	8	2
LGA	3072061	7718S6	PM	INSPECT FIRE ALARMS DEVICES - MARINE AIR TERMINAL	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	8	0
LGA	3072061	788457	PM	INSPECT FIRE ALARMS DEVICES - MARINE AIR TERMINAL	307	101	ACTIVE		C1	6/30/2014	11X0A0230703512100001	8	0
LGA	3072062	741031	PM	INSPECT FIRE ALARMS DEVICES - POLICE EMERGENCY GARAGE	307	101	CLOSED	4/30/2013	TS	1/2/2012	11X0A0230703512100001	8	0
LGA	3072062	741032	PM	INSPECT FIRE ALARMS DEVICES - POLICE EMERGENCY GARAGE	307	101	CLOSED	4/30/2013	TS	7/2/2012	11X0A0230703512100001	8	0
LGA	3072062	741033	PM	INSPECT FIRE ALARMS DEVICES - POLICE EMERGENCY GARAGE	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703512100001	8	0
LGA	3072062	758810	PM	INSPECT FIRE ALARMS DEVICES - POLICE EMERGENCY GARAGE	307	101	ACTIVE		TS	7/1/2013	11X0A0230703512100001	8	0
LGA	3072062	771857	PM	INSPECT FIRE ALARMS DEVICES - POLICE EMERGENCY GARAGE	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	8	0
LGA	3072062	788458	PM	INSPECT FIRE ALARMS DEVICES - POLICE EMERGENCY GARAGE	307	101	ACTIVE		C1	6/30/2014	11X0A0230703512100001	8	0
LGA	3072063	741034	PM	INSPECT FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	CLOSED	4/30/2013	TS	1/2/2012	11X0A0230703512100001	2	0
LGA	3072063	741035	PM	INSPECT FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	CLOSED	4/30/2013	TS	7/2/2012	11X0A0230703512100001	2	0
LGA	3072063	741036	PM	INSPECT FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703512100001	2	0
LGA	3072063	758811	PM	INSPECT FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	ACTIVE		TS	7/1/2013	11X0A0230703512100001	2	0
LGA	3072063	771858	PM	INSPECT FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	2	0
LGA	3072063	7884S9	PM	INSPECT FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	ACTIVE		C1	6/30/2014	11X0A0230703512100001	2	0
LGA	3072064	746088	PM	INSPECT FIRE ALARMS DEVICES - WEST END SUBSTATION	307	101	CANCEL	7/14/2012	TS	7/2/2012	11X0A0230703512100001	2	0
LGA	3072064	746089	PM	INSPECT FIRE ALARMS DEVICES - WEST END SUBSTATION	307	101	CLOSED	7/9/2013	TS	12/31/2012	11X0A0230703512100001	2	0
LGA	3072064	758812	PM	INSPECT FIRE ALARMS DEVICES - WEST END SUBSTATION	307	101	ACTIVE		TS	7/1/2013	11X0A0230703512100001	2	0
LGA	3072064	7718S9	PM	INSPECT FIRE ALARMS DEVICES - WEST END SUBSTATION	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	2	0
LGA	3072064	788460	PM	INSPECT FIRE ALARMS DEVICES - WEST END SUBSTATION	307	101	ACTIVE		C1	6/30/2014	11X0A0230703512100001	2	0
LGA	3072065	746090	PM	INSPECT FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	CLOSED	4/30/2013	TS	7/2/2012	11X0A0230703512100001	16	0
LGA	3072065	746091	PM	INSPECT FIRE ALARMS DEVICES - DIKE PUMP HOUSE 2	307	101	CLOSED	7/31/2013	TS	12/31/2012	11X0A0230703512100001	16	0
LGA	3072065	758813	PM	INSPECT FIRE ALARMS DEVICES - HIGH PRESSURE PUMP STATION	307	101	ACTIVE		TS	7/1/2013	11X0A0230703512100001	16	0
LGA	3072065	771860	PM	INSPECT FIRE ALARMS DEVICES - HIGH PRESSURE PUMP STATION	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	16	0
LGA	3072065	788461	PM	INSPECT FIRE ALARMS DEVICES - HIGH PRESSURE PUMP STATION	307	101	ACTIVE		C1	6/30/2014	11X0A0230703512100001	16	0
LGA	3072066	746219	PM	INSP FIRE ALARMS DEVICES - BUILDING 39 PA WELD SHOP	307	101	CLOSED	4/30/2013	TS	7/2/2012	11X0A0230703512100001	8	0
LGA	3072066	746220	PM	INSP FIRE ALARMS DEVICES - BUILDING 39 PA WELD SHOP	307	101	CLOSED	7/31/2013	TS	12/31/2012	11X0A0230703512100001	8	0
LGA	3072066	758814	PM	INSP FIRE ALARMS DEVICES - BUILDING 39 PA WELD SHOP	307	101	ACTIVE		TS	7/1/2013	11X0A0230703512100001	8	0
LGA	3072066	771861	PM	INSP FIRE ALARMS DEVICES - BUILDING 39 PA WELD SHOP	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	8	0
LGA	3072066	788462	PM	INSP FIRE ALARMS DEVICES - BUILDING 39 PA WELD SHOP	307	101	ACTIVE		C1	6/30/2014	11X0A0230703512100001	8	0
LGA	3072067	750992	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 11	307	101	CLOSED	4/30/2013	TS	7/2/2012	11X0A0230703512100001	8	0
LGA	3072067	750993	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 11	307	101	CLOSED	7/31/2013	TS	12/31/2012	11X0A0230703512100001	8	0
LGA	3072067	758815	PM	INSPECT FIRE ALARMS DEVICES - BUILDING 28	307	101	ACTIVE		TS	7/1/2013	11X0A0230703512100001	8	0
LGA	3072067	771862	PM	INSPECT FIRE ALARMS DEVICES - BUILDING 28	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	8	0
LGA	3072067	788463	PM	INSPECT FIRE ALARMS DEVICES - BUILDING 28	307	101	ACTIVE		C1	6/30/2014	11X0A0230703512100001	8	0
LGA	3072068	776860	PM	INSPECT FIRE ALARMS DEVICES - BUILDINGS NO. 82 AND 83	307	101	ACTIVE		TS	7/1/2013	11X0A0230703512100001	8	0
LGA	3072068	776861	PM	INSPECT FIRE ALARMS DEVICES - BUILDINGS NO. 87	307	101	ACTIVE		C1	12/30/2013	11X0A0230703512100001	8	0
LGA	3072068	788464	PM	INSPECT FIRE ALARMS DEVICES - BUILDINGS NO. 87	307	101	ACTIVE		C1	6/30/2014	11X0A0230703512100001	8	0
LGA	3072073	812478	PM	INSPECT FIRE ALARMS DEVICES - HANGAR 11	307	101	ACTIVE		C1	6/30/2014	11X0A0230703512100001	8	0

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072108	703212	PM	MAINTAIN FIRE ALARM PANELS	307	101	SUM	9/22/2011	CE	9/5/2011	11X0A0230703512100001	24	2
LGA	3072108	733638	PM	MAINTAIN FIRE ALARM PANELS	307	101	CLOSED	9/19/2012	CE	9/3/2012	11X0A0230703512100001	24	0
LGA	3072108	764019	PM	MAINTAIN FIRE ALARM PANELS	307	101	CLO5ED	7/10/2013	CE	9/2/2013	11X0A0230703512100001	24	0
LGA	3072109	682559	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/3/2011	11X0A0230703512100001	2	0
LGA	3072109	682S60	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/10/2011	11X0A0230703512100001	2	0
LGA	3072109	682561	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/17/2011	11X0A0230703512100001	2	1
LGA	3072109	682562	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/31/2011	RP	1/24/2011	11X0A0230703512100001	2	0
LGA	3072109	682563	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	1/31/2011	11X0A0230703512100001	2	2
LGA	3072109	685400	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/7/2011	11X0A0230703512100001	2	10
LGA	3072109	68S401	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/14/2011	11X0A0230703512100001	2	1
LGA	3072109	685402	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/21/2011	11X0A0230703512100001	2	0
LGA	3072109	685403	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/2/2011	RP	2/28/2011	11X0A0230703512100001	2	2
LGA	3072109	687930	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/7/2011	11X0A0230703512100001	2	2
LGA	3072109	687931	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/14/2011	11X0A0230703512100001	2	2
LGA	3072109	687932	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/24/2011	RP	3/21/2011	11X0A0230703512100001	2	1
LGA	3072109	687933	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/9/2011	RP	3/28/2011	11X0A0230703512100001	2	2
LGA	3072109	690482	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	4/26/2011	RP	4/4/2011	11X0A0230703512100001	2	0
LGA	3072109	690483	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/11/2011	11X0A0230703512100001	2	2
LGA	3072109	690484	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/18/2011	11X0A0230703512100001	2	2
LGA	3072109	690485	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/23/2011	RP	4/25/2011	11X0A0230703512100001	2	0
LGA	3072109	692879	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	5/2/2011	11X0A0230703512100001	2	1
LGA	3072109	692880	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/9/2011	11X0A0230703512100001	2	0
LGA	3072109	692881	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/16/2011	11X0A0230703512100001	2	0
LGA	3072109	692882	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/23/2011	11X0A0230703512100001	2	0
LGA	3072109	692883	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/17/2011	RP	5/30/2011	11X0A0230703512100001	2	0
LGA	3072109	695449	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/17/2011	RP	6/6/2011	11X0A0230703512100001	2	0
LGA	3072109	695450	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	6/13/2011	11X0A0230703512100001	2	1
LGA	3072109	695451	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/20/2011	11X0A0230703512100001	2	1
LGA	3072109	695452	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	6/27/2011	11X0A0230703512100001	2	0
LGA	3072109	698043	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/4/2011	11X0A0230703512100001	2	1
LGA	3072109	698044	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/11/2011	11X0A0230703512100001	2	0
LGA	3072109	698045	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/18/2011	11X0A0230703512100001	2	2
LGA	3072109	698046	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/25/2011	11X0A0230703512100001	2	2
LGA	3072109	700575	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/1/2011	11X0A0230703512100001	2	2
LGA	3072109	700576	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	8/26/2011	RP	8/8/2011	11X0A0230703512100001	2	0
LGA	3072109	700577	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/15/2011	11X0A0230703512100001	2	2
LGA	3072109	700578	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/22/2011	11X0A0230703512100001	2	0
LGA	3072109	700579	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	8/29/2011	11X0A0230703512100001	2	1
LGA	3072109	703213	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/5/2011	11X0A0230703512100001	2	2
LGA	3072109	703214	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/12/2011	11X0A0230703512100001	2	2
LGA	3072109	703215	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	9/19/2011	11X0A0230703512100001	2	0
LGA	3072109	703216	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/26/2011	11X0A0230703512100001	2	1
LGA	3072109	705851	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/3/2011	11X0A0230703512100001	2	2
LGA	3072109	705852	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/10/2011	11X0A0230703512100001	2	0
LGA	3072109	70S853	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/17/2011	11X0A0230703512100001	2	2
LGA	3072109	705854	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/24/2011	11X0A0230703512100001	2	2
LGA	3072109	70S855	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/31/2011	11X0A0230703512100001	2	0

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072109	708447	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	11/7/2011	11X0A0230703S12100001	2	0
LGA	3072109	708448	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/14/2011	11X0A0230703S12100001	2	2
LGA	3072109	708449	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	12/5/2011	RP	11/21/2011	11X0A0230703S12100001	2	0
LGA	3072109	708450	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/28/2011	11X0A0230703S12100001	2	2
LGA	3072109	710818	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/4/2012	RP	12/5/2011	11X0A0230703S12100001	2	2
LGA	3072109	710819	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/4/2012	RP	12/12/2011	11X0A0230703S12100001	2	0
LGA	3072109	710820	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/19/2011	11X0A0230703S12100001	2	2
LGA	3072109	710821	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/26/2011	11X0A0230703S12100001	2	2
LGA	3072109	713166	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	1/2/2012	11X0A0230703S12100001	2	0
LGA	3072109	713167	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/25/2012	RP	1/9/2012	11X0A0230703S12100001	2	2
LGA	3072110	682564	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/4/2011	11X0A0230703S12100001	2	0
LGA	3072110	682565	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/14/2011	RP	1/11/2011	11X0A0230703S12100001	2	1
LGA	3072110	682566	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/18/2011	11X0A0230703S12100001	2	1
LGA	3072110	682567	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/31/2011	RP	1/25/2011	11X0A0230703S12100001	2	0
LGA	3072110	685404	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/1/2011	11X0A0230703S12100001	2	2
LGA	3072110	685405	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/8/2011	11X0A0230703S12100001	2	2
LGA	3072110	685406	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/15/2011	11X0A0230703S12100001	2	1
LGA	3072110	685407	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/22/2011	11X0A0230703S12100001	2	2
LGA	3072110	687934	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/1/2011	11X0A0230703S12100001	2	2
LGA	3072110	687935	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	3/22/2011	RP	3/8/2011	11X0A0230703S12100001	2	0
LGA	3072110	687936	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/15/2011	11X0A0230703S12100001	2	2
LGA	3072110	687937	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/24/2011	RP	3/22/2011	11X0A0230703S12100001	2	2
LGA	3072110	687938	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/9/2011	RP	3/29/2011	11X0A0230703S12100001	2	2
LGA	3072110	690486	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	4/26/2011	RP	4/5/2011	11X0A0230703S12100001	2	0
LGA	3072110	690487	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/12/2011	11X0A0230703S12100001	2	0
LGA	3072110	690488	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	4/26/2011	RP	4/19/2011	11X0A0230703S12100001	2	0
LGA	3072110	690489	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	4/26/2011	11X0A0230703S12100001	2	2
LGA	3072110	692884	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	5/3/2011	11X0A0230703S12100001	2	2
LGA	3072110	692885	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/25/2011	RP	5/10/2011	11X0A0230703S12100001	2	1
LGA	3072110	692886	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/25/2011	RP	5/17/2011	11X0A0230703S12100001	2	2
LGA	3072110	692887	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	5/24/2011	11X0A0230703S12100001	2	1
LGA	3072110	692888	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/17/2011	RP	5/31/2011	11X0A0230703S12100001	2	0
LGA	3072110	695453	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	6/7/2011	11X0A0230703S12100001	2	2
LGA	3072110	695454	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/14/2011	11X0A0230703S12100001	2	2
LGA	3072110	695455	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/21/2011	11X0A0230703S12100001	2	2
LGA	3072110	695456	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	6/28/2011	11X0A0230703S12100001	2	2
LGA	3072110	698047	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/5/2011	11X0A0230703S12100001	2	0
LGA	3072110	698048	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/12/2011	11X0A0230703S12100001	2	0
LGA	3072110	698049	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/19/2011	11X0A0230703S12100001	2	2
LGA	3072110	698050	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/26/2011	11X0A0230703S12100001	2	2
LGA	3072110	700580	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/2/2011	11X0A0230703S12100001	2	2
LGA	3072110	700581	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/9/2011	11X0A0230703S12100001	2	2
LGA	3072110	700582	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/16/2011	11X0A0230703S12100001	2	2
LGA	3072110	700583	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/23/2011	11X0A0230703S12100001	2	0
LGA	3072110	700584	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	8/30/2011	11X0A0230703S12100001	2	1
LGA	3072110	703217	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/6/2011	11X0A0230703S12100001	2	2
LGA	3072110	703218	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/13/2011	11X0A0230703S12100001	2	1

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072110	703219	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/20/2011	11X0A0230703512100001	2	2
LGA	3072110	703220	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/27/2011	11X0A0230703512100001	2	1
LGA	3072110	705856	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/4/2011	11X0A0230703512100001	2	2
LGA	3072110	705857	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/11/2011	11X0A0230703512100001	2	2
LGA	3072110	705858	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/18/2011	11X0A0230703512100001	2	2
LGA	3072110	705859	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/25/2011	11X0A0230703512100001	2	1
LGA	3072110	708451	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	11/1/2011	11X0A0230703512100001	2	2
LGA	3072110	708452	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	11/8/2011	11X0A0230703512100001	2	2
LGA	3072110	708453	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	12/5/2011	RP	11/15/2011	11X0A0230703512100001	2	0
LGA	3072110	708454	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/22/2011	11X0A0230703512100001	2	0
LGA	3072110	708455	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/29/2011	11X0A0230703512100001	2	1
LGA	3072110	710822	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/4/2012	RP	12/6/2011	11X0A0230703512100001	2	4
LGA	3072110	710823	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/4/2012	RP	12/13/2011	11X0A0230703512100001	2	2
LGA	3072110	710824	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/20/2011	11X0A0230703512100001	2	2
LGA	3072110	710825	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/5/2012	RP	12/27/2011	11X0A0230703512100001	2	0
LGA	3072110	713171	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/25/2012	RP	1/3/2012	11X0A0230703512100001	2	2
LGA	3072110	713172	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/25/2012	RP	1/10/2012	11X0A0230703512100001	2	2
LGA	3072111	682568	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	1/14/2011	RP	1/5/2011	11X0A0230703512100001	2	0
LGA	3072111	682569	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	1/19/2011	RP	1/12/2011	11X0A0230703512100001	2	2
LGA	3072111	682570	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	1/31/2011	RP	1/19/2011	11X0A0230703512100001	2	2
LGA	3072111	682571	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	2/28/2011	RP	1/26/2011	11X0A0230703512100001	2	0
LGA	3072111	685408	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	2/28/2011	RP	2/2/2011	11X0A0230703512100001	2	2
LGA	3072111	685409	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	2/28/2011	RP	2/9/2011	11X0A0230703512100001	2	1
LGA	3072111	685410	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	2/28/2011	RP	2/16/2011	11X0A0230703512100001	2	0
LGA	3072111	685411	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	3/1/2011	RP	2/23/2011	11X0A0230703512100001	2	2
LGA	3072111	687939	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	3/22/2011	RP	3/2/2011	11X0A0230703512100001	2	0
LGA	3072111	687940	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	3/22/2011	RP	3/9/2011	11X0A0230703512100001	2	0
LGA	3072111	687941	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	3/22/2011	RP	3/16/2011	11X0A0230703512100001	2	2
LGA	3072111	687942	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	4/9/2011	RP	3/23/2011	11X0A0230703512100001	2	2
LGA	3072111	687943	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	4/9/2011	RP	3/30/2011	11X0A0230703512100001	2	0
LGA	3072111	690490	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	4/26/2011	RP	4/6/2011	11X0A0230703512100001	2	2
LGA	3072111	690491	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	4/26/2011	RP	4/13/2011	11X0A0230703512100001	2	3
LGA	3072111	690492	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	4/26/2011	RP	4/20/2011	11X0A0230703512100001	2	2
LGA	3072111	690493	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	5/23/2011	RP	4/27/2011	11X0A0230703512100001	2	2
LGA	3072111	692889	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	5/23/2011	RP	5/4/2011	11X0A0230703512100001	2	2
LGA	3072111	692890	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	5/25/2011	RP	5/11/2011	11X0A0230703512100001	2	0
LGA	3072111	692891	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	5/25/2011	RP	5/18/2011	11X0A0230703512100001	2	2
LGA	3072111	692892	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	6/17/2011	RP	5/25/2011	11X0A0230703512100001	2	0
LGA	3072111	695457	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	6/17/2011	RP	6/1/2011	11X0A0230703512100001	2	2.5
LGA	3072111	695458	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	6/17/2011	RP	6/8/2011	11X0A0230703512100001	2	2
LGA	3072111	695459	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	6/29/2011	RP	6/15/2011	11X0A0230703512100001	2	2
LGA	3072111	695460	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	6/29/2011	RP	6/22/2011	11X0A0230703512100001	2	0
LGA	3072111	695461	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	7/19/2011	RP	6/29/2011	11X0A0230703512100001	2	0
LGA	3072111	698051	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	7/19/2011	RP	7/6/2011	11X0A0230703512100001	2	2
LGA	3072111	698052	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	7/19/2011	RP	7/13/2011	11X0A0230703512100001	2	0
LGA	3072111	698053	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	8/19/2011	RP	7/20/2011	11X0A0230703512100001	2	2
LGA	3072111	698054	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	8/19/2011	RP	7/27/2011	11X0A0230703512100001	2	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072111	700585	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	8/26/2011	RP	8/3/2011	11X0A0230703512100001	2	0
LGA	3072111	700586	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	8/26/2011	RP	8/10/2011	11X0A0230703512100001	2	2
LGA	3072111	700587	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	8/26/2011	RP	8/17/2011	11X0A0230703512100001	2	2
LGA	3072111	700588	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	8/26/2011	RP	8/24/2011	11X0A0230703512100001	2	0
LGA	3072111	700589	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	9/22/2011	RP	8/31/2011	11X0A0230703512100001	2	2
LGA	3072111	703221	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	9/22/2011	RP	9/7/2011	11X0A0230703512100001	2	2
LGA	3072111	703222	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	9/22/2011	RP	9/14/2011	11X0A0230703512100001	2	0
LGA	3072111	703223	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	10/14/2011	RP	9/21/2011	11X0A0230703512100001	2	2
LGA	3072111	703224	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	10/14/2011	RP	9/28/2011	11X0A0230703512100001	2	1
LGA	3072111	705860	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	11/10/2011	RP	10/5/2011	11X0A0230703512100001	2	0
LGA	3072111	705861	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	11/10/2011	RP	10/12/2011	11X0A0230703512100001	2	2
LGA	3072111	705862	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	11/10/2011	RP	10/19/2011	11X0A0230703512100001	2	2
LGA	3072111	705863	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANSUM	11/10/2011	RP	10/26/2011	11X0A0230703512100001	2	0
LGA	3072111	708456	PM	CHECK FIRE ALARM FULL BOXES	307	101	SUM	11/10/2011	RP	11/2/2011	11X0A0230703512100001	2	2
LGA	3072111	708457	PM	CHECK FIRE ALARM FULL BOXES	307	101	CLOSED	12/5/2011	RP	11/9/2011	11X0A0230703512100001	2	2
LGA	3072111	708458	PM	CHECK FIRE ALARM FULL BOXES	307	101	CLOSED	12/5/2011	RP	11/16/2011	11X0A0230703512100001	2	0
LGA	3072111	708459	PM	CHECK FIRE ALARM FULL BOXES	307	101	CLOSED	12/5/2011	RP	11/23/2011	11X0A0230703512100001	2	2
LGA	3072111	708460	PM	CHECK FIRE ALARM FULL BOXES	307	101	CLOSED	12/5/2011	RP	11/30/2011	11X0A0230703512100001	2	2
LGA	3072111	710826	PM	CHECK FIRE ALARM FULL BOXES	307	101	CANCEL	1/4/2012	RP	12/7/2011	11X0A0230703512100001	2	0
LGA	3072111	710827	PM	CHECK FIRE ALARM FULL BOXES	307	101	CLOSED	1/4/2012	RP	12/14/2011	11X0A0230703512100001	2	2
LGA	3072111	710828	PM	CHECK FIRE ALARM FULL BOXES	307	101	CLOSED	1/5/2012	RP	12/21/2011	11X0A0230703512100001	2	2
LGA	3072111	710829	PM	CHECK FIRE ALARM FULL BOXES	307	101	CLOSED	1/5/2012	RP	12/28/2011	11X0A0230703512100001	2	0
LGA	3072111	713176	PM	CHECK FIRE ALARM FULL BOXES	307	101	CLOSED	1/25/2012	RP	1/4/2012	11X0A0230703512100001	2	1
LGA	3072112	682572	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/6/2011	11X0A0230703512100001	2	0
LGA	3072112	682573	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/13/2011	11X0A0230703512100001	2	2
LGA	3072112	682574	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/31/2011	RP	1/20/2011	11X0A0230703512100001	2	0
LGA	3072112	682575	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	1/27/2011	11X0A0230703512100001	2	0
LGA	3072112	685412	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/3/2011	11X0A0230703512100001	2	2
LGA	3072112	685413	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/10/2011	11X0A0230703512100001	2	0
LGA	3072112	685414	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/17/2011	11X0A0230703512100001	2	0
LGA	3072112	685415	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/1/2011	RP	2/24/2011	11X0A0230703512100001	2	2
LGA	3072112	687944	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/3/2011	11X0A0230703512100001	2	2
LGA	3072112	687945	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/10/2011	11X0A0230703512100001	2	1
LGA	3072112	687946	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/17/2011	11X0A0230703512100001	2	1
LGA	3072112	687947	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/9/2011	RP	3/24/2011	11X0A0230703512100001	2	2
LGA	3072112	687948	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	4/9/2011	RP	3/31/2011	11X0A0230703512100001	2	0
LGA	3072112	690494	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/7/2011	11X0A0230703512100001	2	2
LGA	3072112	690495	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/14/2011	11X0A0230703512100001	2	1
LGA	3072112	690496	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/21/2011	11X0A0230703512100001	2	1
LGA	3072112	690497	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	4/28/2011	11X0A0230703512100001	2	2
LGA	3072112	692893	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	5/5/2011	11X0A0230703512100001	2	2
LGA	3072112	692894	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/12/2011	11X0A0230703512100001	2	0
LGA	3072112	692895	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/25/2011	RP	5/19/2011	11X0A0230703512100001	2	2
LGA	3072112	692896	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	5/26/2011	11X0A0230703512100001	2	2
LGA	3072112	695462	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/17/2011	RP	6/2/2011	11X0A0230703512100001	2	0
LGA	3072112	695463	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	6/9/2011	11X0A0230703512100001	2	1
LGA	3072112	695464	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/16/2011	11X0A0230703512100001	2	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072112	695465	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/29/2011	RP	6/23/2011	11X0A0230703512100001	2	0
LGA	3072112	695466	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	6/30/2011	11X0A0230703512100001	2	2
LGA	3072112	698055	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/7/2011	11X0A0230703512100001	2	2
LGA	3072112	698056	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/14/2011	11X0A0230703512100001	2	0
LGA	3072112	698057	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/21/2011	11X0A0230703512100001	2	2
LGA	3072112	698058	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/28/2011	11X0A0230703512100001	2	2
LGA	3072112	700590	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	8/26/2011	RP	8/4/2011	11X0A0230703512100001	2	0
LGA	3072112	700591	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	8/26/2011	RP	8/11/2011	11X0A0230703512100001	2	0
LGA	3072112	700592	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/18/2011	11X0A0230703512100001	2	2
LGA	3072112	700593	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	8/25/2011	11X0A0230703512100001	2	0
LGA	3072112	703225	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/1/2011	11X0A0230703512100001	2	1
LGA	3072112	703226	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/8/2011	11X0A0230703512100001	2	2
LGA	3072112	703227	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	9/15/2011	11X0A0230703512100001	2	0
LGA	3072112	703228	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/22/2011	11X0A0230703512100001	2	2
LGA	3072112	703229	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/29/2011	11X0A0230703512100001	2	1
LGA	3072112	705864	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/6/2011	11X0A0230703512100001	2	0
LGA	3072112	705865	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/13/2011	11X0A0230703512100001	2	2
LGA	3072112	705866	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/20/2011	11X0A0230703512100001	2	2
LGA	3072112	705867	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/27/2011	11X0A0230703512100001	2	0
LGA	3072112	708461	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	11/3/2011	11X0A0230703512100001	2	2
LGA	3072112	708462	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/10/2011	11X0A0230703512100001	2	2
LGA	3072112	708463	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	12/5/2011	RP	11/17/2011	11X0A0230703512100001	2	0
LGA	3072112	708464	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/24/2011	11X0A0230703512100001	2	2
LGA	3072112	710830	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	12/1/2011	11X0A0230703512100001	2	2
LGA	3072112	710831	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/4/2012	RP	12/8/2011	11X0A0230703512100001	2	0
LGA	3072112	710832	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/4/2012	RP	12/15/2011	11X0A0230703512100001	2	0
LGA	3072112	710833	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/22/2011	11X0A0230703512100001	2	2
LGA	3072112	710834	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/5/2012	RP	12/29/2011	11X0A0230703512100001	2	0
LGA	3072112	713180	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/25/2012	RP	1/5/2012	11X0A0230703512100001	2	1
LGA	3072113	682576	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/7/2011	11X0A0230703512100001	2	0
LGA	3072113	682577	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/31/2011	RP	1/14/2011	11X0A0230703512100001	2	0
LGA	3072113	682578	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/31/2011	RP	1/21/2011	11X0A0230703512100001	2	0
LGA	3072113	682579	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	1/28/2011	11X0A0230703512100001	2	0
LGA	3072113	685416	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/4/2011	11X0A0230703512100001	2	2
LGA	3072113	685417	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/11/2011	11X0A0230703512100001	2	0
LGA	3072113	685418	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/18/2011	11X0A0230703512100001	2	0
LGA	3072113	685419	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/1/2011	RP	2/25/2011	11X0A0230703512100001	2	2
LGA	3072113	687949	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	3/22/2011	RP	3/4/2011	11X0A0230703512100001	2	0
LGA	3072113	687950	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/11/2011	11X0A0230703512100001	2	2
LGA	3072113	687951	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/18/2011	11X0A0230703512100001	2	1
LGA	3072113	687952	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/9/2011	RP	3/25/2011	11X0A0230703512100001	2	2
LGA	3072113	690498	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	4/9/2011	RP	4/1/2011	11X0A0230703512100001	2	0
LGA	3072113	690499	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/8/2011	11X0A0230703512100001	2	2
LGA	3072113	690500	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/15/2011	11X0A0230703512100001	2	1
LGA	3072113	690501	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/23/2011	RP	4/22/2011	11X0A0230703512100001	2	0
LGA	3072113	690502	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	4/29/2011	11X0A0230703512100001	2	1
LGA	3072113	692897	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	5/6/2011	11X0A0230703512100001	2	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072113	692898	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/13/2011	11X0A0230703512100001	2	0
LGA	3072113	692899	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/25/2011	RP	5/20/2011	11X0A0230703512100001	2	2
LGA	3072113	692900	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	5/27/2011	11X0A0230703512100001	2	2
LGA	3072113	695467	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	6/3/2011	11X0A0230703512100001	2	2
LGA	3072113	695468	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	6/10/2011	11X0A0230703512100001	2	2
LGA	3072113	695469	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/17/2011	11X0A0230703512100001	2	1
LGA	3072113	695470	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/29/2011	RP	6/24/2011	11X0A0230703512100001	2	0
LGA	3072113	698059	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/1/2011	11X0A0230703512100001	2	0
LGA	3072113	698060	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/8/2011	11X0A0230703512100001	2	4
LGA	3072113	698061	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/15/2011	11X0A0230703512100001	2	0
LGA	3072113	698062	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/22/2011	11X0A0230703512100001	2	2
LGA	3072113	698063	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/29/2011	11X0A0230703512100001	2	2
LGA	3072113	700594	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	8/26/2011	RP	8/5/2011	11X0A0230703512100001	2	0
LGA	3072113	700595	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/12/2011	11X0A0230703512100001	2	2
LGA	3072113	700596	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/19/2011	11X0A0230703512100001	2	1
LGA	3072113	700597	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	8/26/2011	11X0A0230703512100001	2	2
LGA	3072113	703230	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/2/2011	11X0A0230703512100001	2	2
LGA	3072113	703231	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/9/2011	11X0A0230703512100001	2	2
LGA	3072113	703232	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	9/16/2011	11X0A0230703512100001	2	0
LGA	3072113	703233	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/23/2011	11X0A0230703512100001	2	2
LGA	3072113	703234	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/30/2011	11X0A0230703512100001	2	2
LGA	3072113	705868	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/7/2011	11X0A0230703512100001	2	2
LGA	3072113	705869	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/14/2011	11X0A0230703512100001	2	2
LGA	3072113	705870	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/21/2011	11X0A0230703512100001	2	2
LGA	3072113	705871	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/28/2011	11X0A0230703512100001	2	0
LGA	3072113	708465	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	11/4/2011	11X0A0230703512100001	2	1
LGA	3072113	708466	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/11/2011	11X0A0230703512100001	2	2
LGA	3072113	708467	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/18/2011	11X0A0230703512100001	2	3.5
LGA	3072113	708468	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/25/2011	11X0A0230703512100001	2	2
LGA	3072113	710835	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/6/2011	RP	12/2/2011	11X0A0230703512100001	2	12
LGA	3072113	710836	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/4/2012	RP	12/9/2011	11X0A0230703512100001	2	2
LGA	3072113	710837	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/16/2011	11X0A0230703512100001	2	2
LGA	3072113	710838	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/23/2011	11X0A0230703512100001	2	2
LGA	3072113	710839	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/5/2012	RP	12/30/2011	11X0A0230703512100001	2	0
LGA	3072113	713184	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/25/2012	RP	1/6/2012	11X0A0230703512100001	2	2
LGA	3072113	715679	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	3/19/2012	RP	2/24/2012	11X0A0230703512100001	2	0
LGA	3072114	682580	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/1/2011	11X0A0230703512100001	2	0
LGA	3072114	682581	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/8/2011	11X0A0230703512100001	2	0
LGA	3072114	682582	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/15/2011	11X0A0230703512100001	2	2
LGA	3072114	682583	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/22/2011	11X0A0230703512100001	2	4
LGA	3072114	682584	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	1/29/2011	11X0A0230703512100001	2	0
LGA	3072114	685420	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/5/2011	11X0A0230703512100001	2	0
LGA	3072114	685421	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/12/2011	11X0A0230703512100001	2	0
LGA	3072114	685422	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/19/2011	11X0A0230703512100001	2	0
LGA	3072114	685423	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/1/2011	RP	2/26/2011	11X0A0230703512100001	2	2
LGA	3072114	687953	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	3/22/2011	RP	3/5/2011	11X0A0230703512100001	2	0
LGA	3072114	687954	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/12/2011	11X0A0230703512100001	2	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072114	6879SS	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/24/2011	RP	3/19/2011	11X0A0230703512100001	2	0
LGA	3072114	6879S6	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/9/2011	RP	3/26/2011	11X0A0230703512100001	2	2
LGA	3072114	690503	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	4/9/2011	RP	4/2/2011	11X0A0230703512100001	2	0
LGA	3072114	690S04	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/9/2011	11X0A0230703512100001	2	9
LGA	3072114	690S05	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/16/2011	11X0A0230703512100001	2	4
LGA	3072114	690506	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/23/2011	RP	4/23/2011	11X0A0230703512100001	2	0
LGA	3072114	690507	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	4/30/2011	11X0A0230703512100001	2	2
LGA	3072114	692901	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	5/7/2011	11X0A0230703512100001	2	3
LGA	3072114	692902	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/25/2011	RP	5/14/2011	11X0A0230703512100001	2	1
LGA	3072114	692903	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/25/2011	RP	5/21/2011	11X0A0230703512100001	2	1
LGA	3072114	692904	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	5/28/2011	11X0A0230703512100001	2	1
LGA	3072114	69S471	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/17/2011	RP	6/4/2011	11X0A0230703512100001	2	0
LGA	3072114	695472	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	6/11/2011	11X0A0230703S12100001	2	3
LGA	3072114	695473	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/18/2011	11X0A0230703512100001	2	1
LGA	3072114	695474	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/29/2011	RP	6/25/2011	11X0A0230703512100001	2	0
LGA	3072114	698064	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/2/2011	11X0A0230703512100001	2	0
LGA	3072114	698065	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/9/2011	11X0A0230703512100001	2	2
LGA	3072114	698066	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/16/2011	11X0A0230703512100001	2	0
LGA	3072114	698067	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/23/2011	11X0A0230703512100001	2	2
LGA	3072114	698068	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/30/2011	11X0A0230703512100001	2	1
LGA	3072114	700598	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	8/26/2011	RP	8/6/2011	11X0A0230703512100001	2	0
LGA	3072114	700599	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/13/2011	11X0A0230703512100001	2	2
LGA	3072114	700600	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/20/2011	11X0A0230703512100001	2	1
LGA	3072114	700601	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	8/27/2011	11X0A0230703512100001	2	0
LGA	3072114	703235	PM	CHECK FIRE ALARM PULL BOXES	307	101	5UM	9/22/2011	RP	9/3/2011	11X0A0230703512100001	2	2
LGA	3072114	703236	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/10/2011	11X0A0230703512100001	2	2
LGA	3072114	703237	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	9/17/2011	11X0A0230703512100001	2	0
LGA	3072114	703238	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/24/2011	11X0A0230703S12100001	2	2
LGA	3072114	705872	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	10/1/2011	11X0A0230703512100001	2	2
LGA	3072114	705873	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/8/2011	11X0A0230703512100001	2	10
LGA	3072114	705874	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/15/2011	11X0A0230703512100001	2	2
LGA	3072114	705875	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/22/2011	11X0A0230703512100001	2	2
LGA	3072114	705876	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/29/2011	11X0A0230703512100001	2	0
LGA	3072114	708469	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	11/5/2011	11X0A0230703512100001	2	4
LGA	3072114	708470	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/12/2011	11X0A0230703512100001	2	1
LGA	3072114	708471	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/19/2011	11X0A0230703512100001	2	0
LGA	3072114	708472	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/26/2011	11X0A0230703512100001	2	0
LGA	3072114	710840	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/6/2011	RP	12/3/2011	11X0A0230703512100001	2	2
LGA	3072114	710841	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/4/2012	RP	12/10/2011	11X0A0230703512100001	2	0
LGA	3072114	710842	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/17/2011	11X0A0230703512100001	2	2
LGA	3072114	710843	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/24/2011	11X0A0230703512100001	2	1
LGA	3072114	710844	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/31/2011	11X0A0230703512100001	2	1
LGA	3072114	713188	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/25/2012	RP	1/7/2012	11X0A0230703512100001	2	2
LGA	3072115	682585	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/14/2011	RP	1/2/2011	11X0A0230703512100001	2	2
LGA	3072115	682586	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/9/2011	11X0A0230703512100001	2	0
LGA	3072115	682587	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/16/2011	11X0A0230703512100001	2	2
LGA	3072115	682588	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/23/2011	11X0A0230703512100001	2	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072115	682589	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	1/30/2011	11X0A0230703512100001	2	2
LGA	3072115	685424	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/6/2011	11X0A0230703512100001	2	2
LGA	3072115	685425	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/13/2011	11X0A0230703512100001	2	1
LGA	3072115	685426	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/20/2011	11X0A0230703512100001	2	0
LGA	3072115	685427	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/1/2011	RP	2/27/2011	11X0A0230703512100001	2	1
LGA	3072115	687957	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/6/2011	11X0A0230703512100001	2	10
LGA	3072115	687958	PM	CHECK FIRE ALARM PULL BOXES	307	101	5UM	3/22/2011	RP	3/13/2011	11X0A0230703512100001	2	2
LGA	3072115	687959	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/24/2011	RP	3/20/2011	11X0A0230703512100001	2	2
LGA	3072115	687960	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/9/2011	RP	3/27/2011	11X0A0230703512100001	2	2
LGA	3072115	690508	PM	CHECK FIRE ALARM PULL BOXE5	307	101	CANSUM	4/26/2011	RP	4/3/2011	11X0A0230703512100001	2	0
LGA	3072115	690509	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/10/2011	11X0A0230703512100001	2	1
LGA	3072115	690510	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/17/2011	11X0A0230703512100001	2	2
LGA	3072115	690511	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	4/24/2011	11X0A0230703512100001	2	2
LGA	3072115	692905	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	5/1/2011	11X0A0230703512100001	2	2
LGA	3072115	692906	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/25/2011	RP	5/8/2011	11X0A0230703512100001	2	2
LGA	3072115	692907	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/15/2011	11X0A0230703512100001	2	0
LGA	3072115	692908	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/22/2011	11X0A0230703512100001	2	0
LGA	3072115	692909	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	5/29/2011	11X0A0230703512100001	2	1
LGA	3072115	695475	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/17/2011	RP	6/5/2011	11X0A0230703512100001	2	0
LGA	3072115	695476	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	6/12/2011	11X0A0230703512100001	2	2
LGA	3072115	695477	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/19/2011	11X0A0230703512100001	2	1
LGA	3072115	695478	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/26/2011	11X0A0230703512100001	2	0
LGA	3072115	698069	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/3/2011	11X0A0230703512100001	2	2
LGA	3072115	698070	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/10/2011	11X0A0230703512100001	2	2
LGA	3072115	698071	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/17/2011	11X0A0230703512100001	2	0
LGA	3072115	698072	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/24/2011	11X0A0230703512100001	2	1
LGA	3072115	698073	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/31/2011	11X0A0230703512100001	2	0
LGA	3072115	700602	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	8/26/2011	RP	8/7/2011	11X0A0230703512100001	2	0
LGA	3072115	700603	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/14/2011	11X0A0230703512100001	2	1
LGA	3072115	700604	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/21/2011	11X0A0230703512100001	2	1
LGA	3072115	700605	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	8/28/2011	11X0A0230703512100001	2	0
LGA	3072115	703239	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/4/2011	11X0A0230703512100001	2	2
LGA	3072115	703240	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/11/2011	11X0A0230703512100001	2	2
LGA	3072115	703241	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	9/18/2011	11X0A0230703512100001	2	0
LGA	3072115	703242	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/25/2011	11X0A0230703512100001	2	0
LGA	3072115	705877	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	10/2/2011	11X0A0230703512100001	2	2
LGA	3072115	705878	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/9/2011	11X0A0230703512100001	2	0
LGA	307211S	705879	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/16/2011	11X0A0230703512100001	2	2
LGA	3072115	705880	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/23/2011	11X0A0230703512100001	2	2
LGA	3072115	705881	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/30/2011	11X0A0230703512100001	2	0
LGA	3072115	708473	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	11/6/2011	11X0A0230703512100001	2	0
LGA	3072115	708474	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/13/2011	11X0A0230703512100001	2	1
LGA	3072115	708475	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	12/5/2011	RP	11/20/2011	11X0A0230703512100001	2	0
LGA	3072115	708476	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/27/2011	11X0A0230703512100001	2	1
LGA	3072115	710845	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/6/2011	RP	12/4/2011	11X0A0230703512100001	2	1
LGA	3072115	710846	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/4/2012	RP	12/11/2011	11X0A0230703512100001	2	0
LGA	3072115	710847	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/18/2011	11X0A0230703512100001	2	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072115	710848	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/25/2011	11X0A0230703S12100001	2	1
LGA	3072115	713192	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/5/2012	RP	1/1/2012	11X0A0230703S12100001	2	0
LGA	3072115	713193	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/25/2012	RP	1/8/2012	11X0A0230703S12100001	2	2
LGA	3072116	682S90	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/1/2011	11X0A0230703S12100001	4	0
LGA	3072116	682S91	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/14/2011	RP	1/2/2011	11X0A0230703512100001	4	2
LGA	3072116	682S92	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/8/2011	11X0A0230703512100001	4	0
LGA	3072116	682S93	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	1/14/2011	RP	1/9/2011	11X0A0230703512100001	4	0
LGA	3072116	682594	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/15/2011	11X0A0230703512100001	4	2
LGA	3072116	682S95	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/16/2011	11X0A0230703512100001	4	2
LGA	3072116	682596	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/22/2011	11X0A0230703512100001	4	2
LGA	3072116	682597	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	1/31/2011	RP	1/23/2011	11X0A0230703512100001	4	2
LGA	3072116	682598	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	1/29/2011	11X0A0230703512100001	4	0
LGA	3072116	682599	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	1/30/2011	11X0A0230703512100001	4	2
LGA	3072116	685428	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/5/2011	11X0A0230703S12100001	4	0
LGA	3072116	685429	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/6/2011	11X0A0230703S12100001	4	2
LGA	3072116	685430	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/12/2011	11X0A0230703512100001	4	1
LGA	3072116	685431	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	2/28/2011	RP	2/13/2011	11X0A0230703512100001	4	1
LGA	3072116	685432	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/19/2011	11X0A0230703512100001	4	0
LGA	3072116	685433	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	2/28/2011	RP	2/20/2011	11X0A0230703512100001	4	0
LGA	3072116	685434	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/1/2011	RP	2/26/2011	11X0A0230703512100001	4	2
LGA	3072116	685435	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/1/2011	RP	2/27/2011	11X0A0230703512100001	4	1
LGA	3072116	687961	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/5/2011	11X0A0230703512100001	4	2
LGA	3072116	687962	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/6/2011	11X0A0230703512100001	4	2
LGA	3072116	687963	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/12/2011	11X0A0230703512100001	4	2
LGA	3072116	687964	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/22/2011	RP	3/13/2011	11X0A0230703512100001	4	2
LGA	3072116	687965	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/24/2011	RP	3/19/2011	11X0A0230703512100001	4	0
LGA	3072116	687966	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	3/24/2011	RP	3/20/2011	11X0A0230703S12100001	4	2
LGA	3072116	687967	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/9/2011	RP	3/26/2011	11X0A0230703512100001	4	2
LGA	3072116	687968	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/9/2011	RP	3/27/2011	11X0A0230703512100001	4	2
LGA	3072116	690512	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	4/9/2011	RP	4/2/2011	11X0A0230703512100001	4	0
LGA	3072116	690513	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	4/26/2011	RP	4/3/2011	11X0A0230703512100001	4	0
LGA	3072116	690514	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/9/2011	11X0A0230703512100001	4	1
LGA	3072116	690515	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/10/2011	11X0A0230703512100001	4	1
LGA	3072116	690516	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/16/2011	11X0A0230703512100001	4	4
LGA	3072116	690517	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	4/26/2011	RP	4/17/2011	11X0A0230703512100001	4	2
LGA	3072116	690518	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/23/2011	RP	4/23/2011	11X0A0230703512100001	4	0
LGA	3072116	690519	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	4/24/2011	11X0A0230703512100001	4	2
LGA	3072116	690520	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	4/30/2011	11X0A0230703512100001	4	1
LGA	3072116	692910	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	5/1/2011	11X0A0230703512100001	4	2
LGA	3072116	692911	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/23/2011	RP	5/7/2011	11X0A0230703512100001	4	2
LGA	3072116	692912	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/25/2011	RP	5/8/2011	11X0A0230703512100001	4	2
LGA	3072116	692913	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	5/25/2011	RP	5/14/2011	11X0A0230703S12100001	4	1
LGA	3072116	692914	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/15/2011	11X0A0230703512100001	4	0
LGA	3072116	692915	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/21/2011	11X0A0230703512100001	4	0
LGA	3072116	692916	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	5/25/2011	RP	5/22/2011	11X0A0230703512100001	4	0
LGA	3072116	692917	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	5/28/2011	11X0A0230703512100001	4	1.5
LGA	3072116	692918	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	5/29/2011	11X0A0230703512100001	4	1

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO. TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072116	695479	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/17/2011	RP	6/4/2011	11X0A0230703512100001	4	0
LGA	3072116	695480	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/17/2011	RP	6/5/2011	11X0A0230703512100001	4	0
LGA	3072116	695481	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	6/11/2011	11X0A0230703512100001	4	2
LGA	3072116	695482	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/17/2011	RP	6/12/2011	11X0A0230703512100001	4	2
LGA	3072116	695483	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/18/2011	11X0A0230703512100001	4	1
LGA	3072116	695484	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/19/2011	11X0A0230703512100001	4	1
LGA	3072116	695485	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	6/29/2011	RP	6/25/2011	11X0A0230703512100001	4	0
LGA	3072116	695486	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	6/29/2011	RP	6/26/2011	11X0A0230703512100001	4	0
LGA	3072116	698074	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/2/2011	11X0A0230703512100001	4	0
LGA	3072116	698075	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/3/2011	11X0A0230703512100001	4	2
LGA	3072116	698076	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/9/2011	11X0A0230703512100001	4	2
LGA	3072116	698077	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	7/19/2011	RP	7/10/2011	11X0A0230703512100001	4	2
LGA	3072116	698078	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/16/2011	11X0A0230703512100001	4	0
LGA	3072116	698079	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	7/19/2011	RP	7/17/2011	11X0A0230703512100001	4	0
LGA	3072116	698080	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/23/2011	11X0A0230703512100001	4	2
LGA	3072116	698081	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/24/2011	11X0A0230703512100001	4	2
LGA	3072116	698082	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/30/2011	11X0A0230703512100001	4	1
LGA	3072116	698083	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/19/2011	RP	7/31/2011	11X0A0230703512100001	4	0
LGA	3072116	700606	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	8/26/2011	RP	8/6/2011	11X0A0230703512100001	4	0
LGA	3072116	700607	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	8/26/2011	RP	8/7/2011	11X0A0230703512100001	4	0
LGA	3072116	700608	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/13/2011	11X0A0230703512100001	4	2
LGA	3072116	700609	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/14/2011	11X0A0230703512100001	4	1
LGA	3072116	700610	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	8/26/2011	RP	8/20/2011	11X0A0230703512100001	4	0
LGA	3072116	700611	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	8/26/2011	RP	8/21/2011	11X0A0230703512100001	4	1
LGA	3072116	700612	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	8/27/2011	11X0A0230703512100001	4	4
LGA	3072116	700613	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	8/28/2011	11X0A0230703512100001	4	0
LGA	3072116	703243	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/3/2011	11X0A0230703512100001	4	2
LGA	3072116	703244	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/4/2011	11X0A0230703512100001	4	10
LGA	3072116	703245	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/10/2011	11X0A0230703512100001	4	2
LGA	3072116	703246	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	9/22/2011	RP	9/11/2011	11X0A0230703512100001	4	2
LGA	3072116	703247	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	9/17/2011	11X0A0230703512100001	4	0
LGA	3072116	703248	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	9/22/2011	RP	9/18/2011	11X0A0230703512100001	4	0
LGA	3072116	703249	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/24/2011	11X0A0230703512100001	4	2
LGA	3072116	703250	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	9/25/2011	11X0A0230703512100001	4	0
LGA	3072116	705882	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	10/1/2011	11X0A0230703512100001	4	2
LGA	3072116	705883	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	10/14/2011	RP	10/2/2011	11X0A0230703512100001	4	2
LGA	3072116	705884	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/8/2011	11X0A0230703512100001	4	4
LGA	3072116	705885	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/9/2011	11X0A0230703512100001	4	0
LGA	3072116	705886	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/15/2011	11X0A0230703512100001	4	2
LGA	3072116	705887	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/16/2011	11X0A0230703512100001	4	2
LGA	3072116	705888	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/22/2011	11X0A0230703512100001	4	2
LGA	3072116	705889	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	10/23/2011	11X0A0230703512100001	4	2
LGA	3072116	705890	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/29/2011	11X0A0230703512100001	4	0
LGA	3072116	705891	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	RP	10/30/2011	11X0A0230703512100001	4	0
LGA	3072116	708477	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	11/5/2011	11X0A0230703512100001	4	2
LGA	3072116	708478	PM	CHECK FIRE ALARM PULL BOXES	307	101	SUM	11/10/2011	RP	11/6/2011	11X0A0230703512100001	4	0
LGA	3072116	708479	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/12/2011	11X0A0230703512100001	4	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072116	708480	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/13/2011	11X0A0230703512100001	4	2
LGA	3072116	708481	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/19/2011	11X0A0230703512100001	4	0
LGA	3072116	708482	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	12/5/2011	RP	11/20/2011	11X0A0230703512100001	4	0
LGA	3072116	708483	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/26/2011	11X0A0230703512100001	4	0
LGA	3072116	708484	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/5/2011	RP	11/27/2011	11X0A0230703512100001	4	2
LGA	3072116	710849	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/6/2011	RP	12/3/2011	11X0A0230703512100001	4	2
LGA	3072116	710850	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	12/6/2011	RP	12/4/2011	11X0A0230703512100001	4	1.5
LGA	3072116	710851	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/4/2012	RP	12/10/2011	11X0A0230703512100001	4	0
LGA	3072116	710852	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/4/2012	RP	12/11/2011	11X0A0230703512100001	4	0
LGA	3072116	710853	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/17/2011	11X0A0230703512100001	4	2
LGA	3072116	710854	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/5/2012	RP	12/18/2011	11X0A0230703512100001	4	0
LGA	3072116	710855	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/24/2011	11X0A0230703512100001	4	1
LGA	3072116	710856	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/25/2011	11X0A0230703512100001	4	1
LGA	3072116	710857	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/5/2012	RP	12/31/2011	11X0A0230703512100001	4	0
LGA	3072116	713197	PM	CHECK FIRE ALARM PULL BOXES	307	101	CANCEL	1/5/2012	RP	1/1/2012	11X0A0230703512100001	4	0
LGA	3072116	713198	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/25/2012	RP	1/7/2012	11X0A0230703512100001	4	2
LGA	3072116	713199	PM	CHECK FIRE ALARM PULL BOXES	307	101	CLOSED	1/25/2012	RP	1/8/2012	11X0A0230703512100001	4	2
LGA	3072117	705892	PM	MAINTAIN FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	CE	10/3/2011	11X0A0230703512100001	8	0
LGA	3072118	705893	PM	MAINTAIN FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	AS	10/3/2011	11X0A0230703512100001	2	0
LGA	3072120	705894	PM	MAINTAIN FIRE ALARM PULL BOXES	307	101	CANSUM	11/10/2011	CE	10/3/2011	11X0A0230703512100001	8	0
LGA	3072128	690585	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	4/26/2011	TS	4/6/2011	11X0A0230703512100001	8	0
LGA	3072128	705961	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	11/10/2011	TS	10/5/2011	11X0A0230703512100001	8	0
LGA	3072129	690586	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	4/26/2011	TI	4/5/2011	11X0A0230703512100001	8	4
LGA	3072129	705962	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	11/10/2011	TI	10/4/2011	11X0A0230703512100001	8	4
LGA	3072131	682667	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	1/14/2011	TS	1/7/2011	11X0A0230703512100001	8	12
LGA	3072131	682668	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	1/31/2011	TS	1/14/2011	11X0A0230703512100001	8	12
LGA	3072131	682669	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	1/31/2011	TS	1/21/2011	11X0A0230703512100001	8	0
LGA	3072131	682670	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	2/28/2011	TS	1/28/2011	11X0A0230703512100001	8	12
LGA	3072131	685496	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	2/28/2011	TS	2/4/2011	11X0A0230703512100001	8	4
LGA	3072131	685497	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	2/28/2011	TS	2/11/2011	11X0A0230703512100001	8	12
LGA	3072131	685498	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	2/28/2011	TS	2/18/2011	11X0A0230703512100001	8	4
LGA	3072131	685499	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	3/1/2011	TS	2/25/2011	11X0A0230703512100001	8	4
LGA	3072131	688036	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	3/22/2011	TS	3/4/2011	11X0A0230703512100001	8	12
LGA	3072131	688037	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	3/22/2011	TS	3/11/2011	11X0A0230703512100001	8	12
LGA	3072131	688038	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	3/22/2011	TS	3/18/2011	11X0A0230703512100001	8	0
LGA	3072131	688039	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	4/9/2011	TS	3/25/2011	11X0A0230703512100001	8	12
LGA	3072131	690588	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	4/9/2011	TS	4/1/2011	11X0A0230703512100001	8	0
LGA	3072131	690589	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	4/26/2011	TS	4/8/2011	11X0A0230703512100001	8	0
LGA	3072131	690590	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	4/26/2011	TS	4/15/2011	11X0A0230703512100001	8	0
LGA	3072131	690591	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	5/23/2011	TS	4/22/2011	11X0A0230703512100001	8	12
LGA	3072131	690592	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	5/23/2011	TS	4/29/2011	11X0A0230703512100001	8	12
LGA	3072131	692985	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	5/23/2011	TS	5/6/2011	11X0A0230703512100001	8	0
LGA	3072131	692986	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	5/25/2011	TS	5/13/2011	11X0A0230703512100001	8	10
LGA	3072131	692987	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	5/25/2011	TS	5/20/2011	11X0A0230703512100001	8	3
LGA	3072131	692988	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	6/17/2011	TS	5/27/2011	11X0A0230703512100001	8	0
LGA	3072131	695552	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	6/17/2011	TS	6/3/2011	11X0A0230703512100001	8	2
LGA	3072131	695553	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	6/17/2011	TS	6/10/2011	11X0A0230703512100001	8	12

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072131	69SSS4	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	6/29/2011	TS	6/17/2011	11X0A0230703S12100001	8	4
LGA	3072131	69SSSS	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	6/29/2011	TS	6/24/2011	11X0A0230703S12100001	8	0
LGA	3072131	6981S0	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	7/19/2011	TS	7/1/2011	11X0A0230703S12100001	8	0
LGA	3072131	698151	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	7/19/2011	TS	7/8/2011	11X0A0230703S12100001	8	2
LGA	3072131	698152	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	7/19/2011	TS	7/15/2011	11X0A0230703S12100001	8	12
LGA	3072131	698153	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	8/19/2011	TS	7/22/2011	11X0A0230703S12100001	8	2
LGA	3072131	698154	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	8/19/2011	TS	7/29/2011	11X0A0230703S12100001	8	0
LGA	3072131	700680	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	8/26/2011	TS	8/5/2011	11X0A0230703512100001	8	12
LGA	3072131	700681	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	8/26/2011	TS	8/12/2011	11X0A0230703512100001	8	2
LGA	3072131	700682	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	8/26/2011	TS	8/19/2011	11X0A0230703512100001	8	4
LGA	3072131	700683	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	9/22/2011	TS	8/26/2011	11X0A0230703512100001	8	4
LGA	3072131	703316	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	9/22/2011	TS	9/2/2011	11X0A0230703512100001	8	4
LGA	3072131	703317	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	9/22/2011	TS	9/9/2011	11X0A0230703512100001	8	0
LGA	3072131	703318	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	9/22/2011	TS	9/16/2011	11X0A0230703512100001	8	16
LGA	3072131	703319	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	10/14/2011	TS	9/23/2011	11X0A0230703512100001	8	0
LGA	3072131	703320	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	10/14/2011	TS	9/30/2011	11X0A0230703512100001	8	12
LGA	3072131	705964	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	11/10/2011	TS	10/7/2011	11X0A0230703512100001	8	12
LGA	3072131	705965	PM	FIRE ALARM PULL BOX TEST	307	101	SUM	11/10/2011	TS	10/14/2011	11X0A0230703512100001	8	14
LGA	3072131	705966	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	11/10/2011	TS	10/21/2011	11X0A0230703512100001	8	0
LGA	3072131	705967	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	11/10/2011	TS	10/28/2011	11X0A0230703512100001	8	0
LGA	3072131	708550	PM	FIRE ALARM PULL BOX TEST	307	101	CANSUM	11/10/2011	TS	11/4/2011	11X0A0230703512100001	8	0
LGA	3072131	708551	PM	FIRE ALARM PULL BOX TEST	307	101	CLOSED	12/5/2011	TS	11/11/2011	11X0A0230703512100001	8	2
LGA	3072131	708552	PM	FIRE ALARM PULL BOX TEST	307	101	CLOSED	12/5/2011	TS	11/18/2011	11X0A0230703512100001	8	4
LGA	3072131	708553	PM	FIRE ALARM PULL BOX TEST	307	101	CANCEL	12/5/2011	TS	11/25/2011	11X0A0230703512100001	8	0
LGA	3072131	710925	PM	FIRE ALARM PULL BOX TEST	307	101	CLOSED	12/6/2011	TS	12/2/2011	11X0A0230703512100001	8	4
LGA	3072131	710926	PM	FIRE ALARM PULL BOX TEST	307	101	CLOSED	1/4/2012	TS	12/9/2011	11X0A0230703512100001	8	12
LGA	3072131	710927	PM	FIRE ALARM PULL BOX TEST	307	101	CANCEL	1/5/2012	TS	12/16/2011	11X0A0230703512100001	8	0
LGA	3072131	710928	PM	FIRE ALARM PULL BOX TEST	307	101	CANCEL	1/5/2012	TS	12/23/2011	11X0A0230703512100001	8	0
LGA	3072131	710929	PM	FIRE ALARM PULL BOX TEST	307	101	CANCEL	1/5/2012	TS	12/30/2011	11X0A0230703512100001	8	0
LGA	3072131	713273	PM	FIRE ALARM PULL BOX TEST	307	101	CANCEL	1/25/2012	TS	1/6/2012	11X0A0230703512100001	8	0
LGA	3072133	682671	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANSUM	1/14/2011	IN	1/3/2011	11X0A0230703512100001	2	0
LGA	3072133	682672	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANSUM	2/28/2011	IN	1/31/2011	11X0A0230703512100001	2	0
LGA	3072133	688040	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANSUM	3/22/2011	IN	3/7/2011	11X0A0230703512100001	2	0
LGA	3072133	690593	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANSUM	4/26/2011	IN	4/4/2011	11X0A0230703512100001	2	0
LGA	3072133	692989	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANSUM	5/25/2011	IN	5/9/2011	11X0A0230703512100001	2	0
LGA	3072133	695556	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANSUM	6/17/2011	IN	6/6/2011	11X0A0230703512100001	2	0
LGA	3072133	698155	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANSUM	7/19/2011	IN	7/4/2011	11X0A0230703512100001	2	0
LGA	3072133	700684	PM	CHECK PEG FIRE ALARM BOARD	307	101	SUM	8/26/2011	IN	8/8/2011	11X0A0230703512100001	2	2
LGA	3072133	703321	PM	CHECK PEG FIRE ALARM BOARD	307	101	SUM	9/22/2011	IN	9/5/2011	11X0A0230703512100001	2	3
LGA	3072133	705968	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANSUM	11/10/2011	IN	10/3/2011	11X0A0230703512100001	2	0
LGA	3072133	708554	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANSUM	11/10/2011	IN	11/7/2011	11X0A0230703512100001	2	0
LGA	3072133	710930	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANCEL	1/4/2012	IN	12/5/2011	11X0A0230703512100001	2	0
LGA	3072133	713277	PM	CHECK PEG FIRE ALARM BOARD	307	101	CANCEL	1/5/2012	IN	1/2/2012	11X0A0230703512100001	2	0
LGA	3072134	758962	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/5/2013	IN	7/19/2013	11X0A0230703512100001	3	2
LGA	3072134	758963	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/5/2013	IN	7/22/2013	11X0A0230703512100001	3	2
LGA	3072134	758964	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/5/2013	IN	7/24/2013	11X0A0230703512100001	3	2
LGA	3072134	758965	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/5/2013	IN	7/26/2013	11X0A0230703512100001	3	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072134	758966	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/5/2013	IN	7/29/2013	11X0A0230703512100001	3	2
LGA	3072134	758967	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/5/2013	IN	7/31/2013	11X0A0230703512100001	3	2
LGA	3072134	761568	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/2/2013	11X0A0230703512100001	3	2
LGA	3072134	761569	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/5/2013	11X0A0230703512100001	3	2
LGA	3072134	761570	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/7/2013	11X0A0230703512100001	3	2
LGA	3072134	761571	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/9/2013	11X0A0230703512100001	3	1
LGA	3072134	761572	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/12/2013	11X0A0230703512100001	3	1
LGA	3072134	761573	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/14/2013	11X0A0230703512100001	3	2
LGA	3072134	761574	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/16/2013	11X0A0230703512100001	3	2
LGA	3072134	761575	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/19/2013	11X0A0230703512100001	3	2
LGA	3072134	761576	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/21/2013	11X0A0230703512100001	3	2
LGA	3072134	761577	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/23/2013	11X0A0230703512100001	3	2
LGA	3072134	761578	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/11/2013	IN	8/26/2013	11X0A0230703512100001	3	1
LGA	3072134	761579	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/17/2013	IN	8/28/2013	11X0A0230703512100001	3	2
LGA	3072134	761580	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/17/2013	IN	8/30/2013	11X0A0230703512100001	3	2
LGA	3072134	764084	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/17/2013	IN	9/2/2013	11X0A0230703512100001	3	2
LGA	3072134	764085	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/17/2013	IN	9/4/2013	11X0A0230703512100001	3	1
LGA	3072134	764086	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/17/2013	IN	9/6/2013	11X0A0230703512100001	3	2
LGA	3072134	764087	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/17/2013	IN	9/9/2013	11X0A0230703512100001	3	2
LGA	3072134	764088	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/17/2013	IN	9/11/2013	11X0A0230703512100001	3	2
LGA	3072134	764089	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/17/2013	C1	9/13/2013	11X0A0230703512100001	3	4
LGA	3072134	764090	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/17/2013	C1	9/16/2013	11X0A0230703512100001	3	2
LGA	3072134	764091	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/17/2013	C1	9/18/2013	11X0A0230703512100001	3	2
LGA	3072134	764092	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	10/17/2013	C1	9/20/2013	11X0A0230703512100001	3	0
LGA	3072134	764093	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	10/17/2013	C1	9/23/2013	11X0A0230703512100001	3	0
LGA	3072134	764094	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	10/17/2013	C1	9/25/2013	11X0A0230703512100001	3	0
LGA	3072134	764095	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/17/2013	C1	9/27/2013	11X0A0230703512100001	3	1
LGA	3072134	764096	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/17/2013	C1	9/30/2013	11X0A0230703512100001	3	1
LGA	3072134	767091	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/24/2013	C1	10/2/2013	11X0A0230703512100001	3	2
LGA	3072134	767092	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/24/2013	C1	10/4/2013	11X0A0230703512100001	3	1.5
LGA	3072134	767093	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/24/2013	C1	10/7/2013	11X0A0230703512100001	3	1
LGA	3072134	767094	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/24/2013	C1	10/9/2013	11X0A0230703512100001	3	2
LGA	3072134	767095	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/24/2013	C1	10/11/2013	11X0A0230703512100001	3	2
LGA	3072134	767096	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/24/2013	C1	10/14/2013	11X0A0230703512100001	3	2
LGA	3072134	767097	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/24/2013	C1	10/16/2013	11X0A0230703512100001	3	2
LGA	3072134	767098	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	10/29/2013	C1	10/18/2013	11X0A0230703512100001	3	0
LGA	3072134	767099	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/29/2013	C1	10/21/2013	11X0A0230703512100001	3	2
LGA	3072134	767100	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/29/2013	C1	10/23/2013	11X0A0230703512100001	3	3.5
LGA	3072134	767101	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/29/2013	C1	10/25/2013	11X0A0230703512100001	3	1
LGA	3072134	767102	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	11/16/2013	C1	10/28/2013	11X0A0230703512100001	3	2
LGA	3072134	767103	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	11/16/2013	C1	10/30/2013	11X0A0230703512100001	3	4
LGA	3072134	769637	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	11/16/2013	C1	11/1/2013	11X0A0230703512100001	3	2
LGA	3072134	769638	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	11/16/2013	C1	11/4/2013	11X0A0230703512100001	3	0
LGA	3072134	769639	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	11/16/2013	C1	11/6/2013	11X0A0230703512100001	3	2
LGA	3072134	769640	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/5/2013	C1	11/8/2013	11X0A0230703512100001	3	2
LGA	3072134	769641	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/5/2013	C1	11/11/2013	11X0A0230703512100001	3	1
LGA	3072134	769642	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/5/2013	C1	11/13/2013	11X0A0230703512100001	3	1

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072134	769643	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	12/5/2013	C1	11/15/2013	11X0A0230703512100001	3	0
LGA	3072134	769644	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/5/2013	C1	11/18/2013	11X0A0230703512100001	3	2
LGA	3072134	769645	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/10/2013	C1	11/20/2013	11X0A0230703512100001	3	1
LGA	3072134	769646	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	12/10/2013	C1	11/22/2013	11X0A0230703512100001	3	0
LGA	3072134	769647	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/10/2013	C1	11/25/2013	11X0A0230703512100001	3	2
LGA	3072134	769648	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/10/2013	C1	11/27/2013	11X0A0230703512100001	3	2
LGA	3072134	769649	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/10/2013	C1	11/29/2013	11X0A0230703512100001	3	2
LGA	3072134	772000	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/10/2013	C1	12/2/2013	11X0A0230703512100001	3	4
LGA	3072134	772001	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/10/2013	C1	12/4/2013	11X0A0230703512100001	3	2
LGA	3072134	772002	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/10/2013	C1	12/6/2013	11X0A0230703512100001	3	1
LGA	3072134	772003	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/27/2013	C1	12/9/2013	11X0A0230703512100001	3	2
LGA	3072134	772004	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/27/2013	C1	12/11/2013	11X0A0230703512100001	3	1
LGA	3072134	772005	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/27/2013	C1	12/13/2013	11X0A0230703512100001	3	1
LGA	3072134	772006	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/27/2013	C1	12/16/2013	11X0A0230703512100001	3	1
LGA	3072134	772007	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/27/2013	C1	12/18/2013	11X0A0230703512100001	3	2
LGA	3072134	772008	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	12/27/2013	C1	12/20/2013	11X0A0230703512100001	3	2
LGA	3072134	772009	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/14/2014	C1	12/23/2013	11X0A0230703512100001	3	2
LGA	3072134	772010	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/14/2014	C1	12/25/2013	11X0A0230703512100001	3	2
LGA	3072134	772011	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/14/2014	C1	12/27/2013	11X0A0230703512100001	3	2
LGA	3072134	772012	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/14/2014	C1	12/30/2013	11X0A0230703512100001	3	1
LGA	3072134	774393	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/14/2014	C1	1/1/2014	11X0A0230703512100001	3	2
LGA	3072134	774394	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/14/2014	C1	1/3/2014	11X0A0230703512100001	3	0
LGA	3072134	774395	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/23/2014	C1	1/6/2014	11X0A0230703512100001	3	2
LGA	3072134	774396	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/28/2014	C1	1/8/2014	11X0A0230703512100001	3	2
LGA	3072134	774397	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/28/2014	C1	1/10/2014	11X0A0230703512100001	3	2
LGA	3072134	774398	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/28/2014	C1	1/13/2014	11X0A0230703512100001	3	3
LGA	3072134	774399	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/28/2014	C1	1/15/2014	11X0A0230703512100001	3	2
LGA	3072134	774400	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	1/28/2014	C1	1/17/2014	11X0A0230703512100001	3	1
LGA	3072134	774401	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	2/10/2014	C1	1/20/2014	11X0A0230703512100001	3	1
LGA	3072134	774402	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	2/10/2014	C1	1/22/2014	11X0A0230703512100001	3	1
LGA	3072134	774403	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	2/10/2014	C1	1/24/2014	11X0A0230703512100001	3	2
LGA	3072134	774404	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	2/10/2014	C1	1/27/2014	11X0A0230703512100001	3	2
LGA	3072134	774405	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	2/10/2014	C1	1/29/2014	11X0A0230703512100001	3	0
LGA	3072134	774406	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	2/10/2014	C1	1/31/2014	11X0A0230703512100001	3	4
LGA	3072134	776986	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	2/10/2014	C1	2/3/2014	11X0A0230703512100001	3	4
LGA	3072134	776987	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/5/2014	11X0A0230703512100001	3	1
LGA	3072134	776988	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/7/2014	11X0A0230703512100001	3	2
LGA	3072134	776989	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/10/2014	11X0A0230703512100001	3	1
LGA	3072134	776990	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/12/2014	11X0A0230703512100001	3	1
LGA	3072134	776991	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/14/2014	11X0A0230703512100001	3	0
LGA	3072134	776992	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	3/5/2014	C1	2/17/2014	11X0A0230703512100001	3	0
LGA	3072134	776993	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/19/2014	11X0A0230703512100001	3	2
LGA	3072134	776994	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/21/2014	11X0A0230703512100001	3	3
LGA	3072134	776995	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/24/2014	11X0A0230703512100001	3	1
LGA	3072134	776996	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/26/2014	11X0A0230703512100001	3	3
LGA	3072134	776997	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/5/2014	C1	2/28/2014	11X0A0230703512100001	3	2
LGA	3072134	780775	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/22/2014	C1	3/3/2014	11X0A0230703512100001	3	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072134	780776	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/22/2014	C1	3/5/2014	11X0A0230703512100001	3	2
LGA	3072134	780777	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/22/2014	C1	3/7/2014	11X0A0230703512100001	3	2
LGA	3072134	780778	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/22/2014	C1	3/10/2014	11X0A0230703512100001	3	1
LGA	3072134	780779	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/22/2014	C1	3/12/2014	11X0A0230703512100001	3	2
LGA	3072134	780780	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	3/22/2014	C1	3/14/2014	11X0A0230703512100001	3	2
LGA	3072134	780781	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	4/8/2014	C1	3/17/2014	11X0A0230703512100001	3	0
LGA	3072134	780782	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	4/8/2014	C1	3/19/2014	11X0A0230703512100001	3	2
LGA	3072134	780783	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	4/8/2014	C1	3/21/2014	11X0A0230703512100001	3	2
LGA	3072134	780784	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	4/8/2014	C1	3/24/2014	11X0A0230703512100001	3	2
LGA	3072134	780785	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	4/8/2014	C1	3/26/2014	11X0A0230703512100001	3	2
LGA	3072134	780786	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	4/8/2014	C1	3/28/2014	11X0A0230703512100001	3	2
LGA	3072134	780787	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	4/8/2014	C1	3/31/2014	11X0A0230703512100001	3	1
LGA	3072134	783068	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/2/2014	11X0A0230703512100001	3	2
LGA	3072134	783069	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/4/2014	11X0A0230703512100001	3	3
LGA	3072134	783070	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/7/2014	11X0A0230703512100001	3	3
LGA	3072134	783071	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/9/2014	11X0A0230703512100001	3	2
LGA	3072134	783072	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/11/2014	11X0A0230703512100001	3	2
LGA	3072134	783073	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/14/2014	11X0A0230703512100001	3	2
LGA	3072134	783074	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/16/2014	11X0A0230703512100001	3	1
LGA	3072134	783075	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/18/2014	11X0A0230703512100001	3	2
LGA	3072134	783076	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/21/2014	11X0A0230703512100001	3	2
LGA	3072134	783077	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/23/2014	11X0A0230703512100001	3	2
LGA	3072134	783078	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	5/12/2014	C1	4/25/2014	11X0A0230703512100001	3	0
LGA	3072134	783079	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/12/2014	C1	4/28/2014	11X0A0230703512100001	3	1
LGA	3072134	783080	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	5/12/2014	C1	4/30/2014	11X0A0230703512100001	3	0
LGA	3072134	785784	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/15/2014	C1	5/2/2014	11X0A0230703512100001	3	2
LGA	3072134	785785	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/15/2014	C1	5/5/2014	11X0A0230703512100001	3	1
LGA	3072134	785786	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/15/2014	C1	5/7/2014	11X0A0230703512100001	3	2
LGA	3072134	785787	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/19/2014	C1	5/9/2014	11X0A0230703512100001	3	2
LGA	3072134	785788	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/29/2014	C1	5/12/2014	11X0A0230703512100001	3	1
LGA	3072134	785789	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	6/9/2014	C1	5/14/2014	11X0A0230703512100001	3	2
LGA	3072134	785790	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	5/29/2014	C1	5/16/2014	11X0A0230703512100001	3	2
LGA	3072134	785791	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	6/9/2014	C1	5/19/2014	11X0A0230703512100001	3	2
LGA	3072134	785792	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	6/9/2014	C1	5/21/2014	11X0A0230703512100001	3	2
LGA	3072134	785793	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	6/9/2014	C1	5/23/2014	11X0A0230703512100001	3	2
LGA	3072134	785794	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	6/9/2014	C1	5/26/2014	11X0A0230703512100001	3	2
LGA	3072134	785795	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	6/10/2014	C1	5/28/2014	11X0A0230703512100001	3	2
LGA	3072134	785796	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	6/10/2014	C1	5/30/2014	11X0A0230703512100001	3	0
LGA	3072134	788597	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	6/10/2014	C1	6/2/2014	11X0A0230703512100001	3	1
LGA	3072134	788598	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	6/10/2014	C1	6/4/2014	11X0A0230703512100001	3	0
LGA	3072134	788599	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	6/10/2014	C1	6/6/2014	11X0A0230703512100001	3	3
LGA	3072134	788600	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	6/26/2014	C1	6/9/2014	11X0A0230703512100001	3	1
LGA	3072134	788601	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/11/2014	C1	6/11/2014	11X0A0230703512100001	3	0
LGA	3072134	788602	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/11/2014	C1	6/13/2014	11X0A0230703512100001	3	2
LGA	3072134	788603	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	7/11/2014	C1	6/16/2014	11X0A0230703512100001	3	0
LGA	3072134	788604	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	7/11/2014	C1	6/18/2014	11X0A0230703512100001	3	0
LGA	3072134	788605	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/11/2014	C1	6/20/2014	11X0A0230703512100001	3	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072134	788606	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/11/2014	C1	6/23/2014	11X0A0230703512100001	3	2
LGA	3072134	788607	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/11/2014	C1	6/25/2014	11X0A0230703S12100001	3	2
LGA	3072134	788608	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/11/2014	C1	6/27/2014	11X0A0230703S12100001	3	2
LGA	3072134	788609	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/11/2014	C1	6/30/2014	11X0A0230703512100001	3	2
LGA	3072134	791296	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/11/2014	C1	7/2/2014	11X0A0230703512100001	3	1
LGA	3072134	791297	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/11/2014	C1	7/4/2014	11X0A0230703512100001	3	2
LGA	3072134	791298	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/31/2014	C1	7/7/2014	11X0A0230703512100001	3	1
LGA	3072134	791299	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/31/2014	C1	7/9/2014	11X0A0230703S12100001	3	2
LGA	3072134	791300	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/31/2014	C1	7/11/2014	11X0A0230703512100001	3	2
LGA	3072134	791301	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/31/2014	C1	7/14/2014	11X0A0230703S12100001	3	1
LGA	3072134	791302	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/31/2014	C1	7/16/2014	11X0A0230703512100001	3	2
LGA	3072134	791303	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/31/2014	C1	7/18/2014	11X0A0230703512100001	3	1
LGA	3072134	791304	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	ACTIVE	7/31/2014	C1	7/21/2014	11X0A0230703512100001	3	1
LGA	3072134	79130S	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	7/31/2014	C1	7/23/2014	11X0A0230703512100001	3	1
LGA	3072134	791306	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	7/25/2014	11X0A0230703S12100001	3	2
LGA	3072134	791307	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	7/28/2014	11X0A0230703S12100001	3	2
LGA	3072134	791308	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	7/30/2014	11X0A0230703S12100001	3	1
LGA	3072134	793903	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	8/1/2014	11X0A0230703512100001	3	2
LGA	3072134	793904	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	8/4/2014	11X0A0230703512100001	3	1
LGA	3072134	793905	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	8/6/2014	11X0A0230703S12100001	3	2
LGA	3072134	793906	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	8/8/2014	11X0A0230703S12100001	3	1.5
LGA	3072134	793907	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	8/11/2014	11X0A0230703S12100001	3	2
LGA	3072134	793908	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	8/13/2014	11X0A0230703S12100001	3	4
LGA	3072134	793909	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	8/23/2014	C1	8/15/2014	11X0A0230703S12100001	3	2
LGA	3072134	793910	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/15/2014	C1	8/18/2014	11X0A0230703512100001	3	1
LGA	3072134	793911	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/15/2014	C1	8/20/2014	11X0A0230703512100001	3	1.5
LGA	3072134	793912	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/15/2014	C1	8/22/2014	11X0A0230703512100001	3	1
LGA	3072134	793913	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/15/2014	C1	8/25/2014	11X0A0230703S12100001	3	0
LGA	3072134	793914	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	9/15/2014	C1	8/27/2014	11X0A0230703512100001	3	0
LGA	3072134	79391S	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/15/2014	C1	8/29/2014	11X0A0230703S12100001	3	3
LGA	3072134	796722	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/15/2014	C1	9/1/2014	11X0A0230703S12100001	3	1
LGA	3072134	796723	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/16/2014	C1	9/3/2014	11X0A0230703S12100001	3	2
LGA	3072134	796724	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/19/2014	C1	9/5/2014	11X0A0230703512100001	3	4
LGA	3072134	796725	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/19/2014	C1	9/8/2014	11X0A0230703S12100001	3	2
LGA	3072134	796726	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/19/2014	C1	9/10/2014	11X0A0230703512100001	3	2
LGA	3072134	796727	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	9/19/2014	C1	9/12/2014	11X0A0230703512100001	3	2
LGA	3072134	796728	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CLOSED	10/4/2014	C1	9/15/2014	11X0A0230703512100001	3	2
LGA	3072134	796729	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	9/17/2014	11X0A0230703512100001	3	2
LGA	3072134	796730	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	9/19/2014	11X0A0230703512100001	3	4
LGA	3072134	796731	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	9/22/2014	11X0A0230703512100001	3	2
LGA	3072134	796732	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	9/24/2014	11X0A0230703512100001	3	2
LGA	3072134	796733	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	9/26/2014	11X0A0230703512100001	3	2
LGA	3072134	796734	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	9/29/2014	11X0A0230703512100001	3	2
LGA	3072134	799637	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	10/1/2014	11X0A0230703512100001	3	1
LGA	3072134	799638	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	10/3/2014	11X0A0230703S12100001	3	2
LGA	3072134	799639	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	10/18/2014	C1	10/6/2014	11X0A0230703512100001	3	0
LGA	3072134	799640	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	10/18/2014	C1	10/8/2014	11X0A0230703512100001	3	0

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072134	799641	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	10/10/2014	11X0A0230703512100001	3	1
LGA	3072134	799642	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	10/18/2014	C1	10/13/2014	11X0A0230703512100001	3	1
LGA	3072134	799643	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	11/10/2014	C1	10/15/2014	11X0A0230703512100001	3	0
LGA	3072134	799644	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	11/10/2014	C1	10/17/2014	11X0A0230703512100001	3	1
LGA	3072134	799645	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	11/10/2014	C1	10/20/2014	11X0A0230703512100001	3	2
LGA	3072134	799646	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	11/10/2014	C1	10/22/2014	11X0A0230703512100001	3	4
LGA	3072134	799647	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	11/10/2014	C1	10/24/2014	11X0A0230703512100001	3	2
LGA	3072134	799648	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	11/10/2014	C1	10/27/2014	11X0A0230703512100001	3	2
LGA	3072134	799649	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	11/10/2014	C1	10/29/2014	11X0A0230703512100001	3	1
LGA	3072134	799650	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	CANCEL	11/10/2014	C1	10/31/2014	11X0A0230703512100001	3	0
LGA	3072134	802415	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	COMPLT	11/10/2014	C1	11/3/2014	11X0A0230703512100001	3	1.5
LGA	3072134	802416	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	ACTIVE		C1	11/5/2014	11X0A0230703512100001	3	2
LGA	3072134	802417	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	ACTIVE		C1	11/7/2014	11X0A0230703512100001	3	2
LGA	3072134	802418	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	ACTIVE		C1	11/10/2014	11X0A0230703512100001	3	0
LGA	3072134	802419	PM	CHECK FIRE ALARMS BATTERIES AS PER LIST	307	101	ACTIVE		C1	11/12/2014	11X0A0230703512100001	3	0
LGA	3072135	682686	PM	FIRE ALARM ZONE TEST	307	101	SUM	1/14/2011	TS	1/7/2011	11X0A0230703512100001	8	4
LGA	3072135	682687	PM	FIRE ALARM ZONE TEST	307	101	SUM	1/31/2011	TS	1/14/2011	11X0A0230703512100001	8	4
LGA	3072135	682688	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	1/31/2011	TS	1/21/2011	11X0A0230703512100001	8	0
LGA	3072135	682689	PM	FIRE ALARM ZONE TEST	307	101	SUM	2/28/2011	TS	1/28/2011	11X0A0230703512100001	8	4
LGA	3072135	68SS12	PM	FIRE ALARM ZONE TEST	307	101	SUM	2/28/2011	TS	2/4/2011	11X0A0230703512100001	8	12
LGA	3072135	685513	PM	FIRE ALARM ZONE TEST	307	101	SUM	2/28/2011	TS	2/11/2011	11X0A0230703512100001	8	4
LGA	3072135	685514	PM	FIRE ALARM ZONE TEST	307	101	SUM	2/28/2011	TS	2/18/2011	11X0A0230703512100001	8	4
LGA	3072135	685515	PM	FIRE ALARM ZONE TEST	307	101	SUM	3/1/2011	TS	2/25/2011	11X0A0230703512100001	8	4
LGA	3072135	688054	PM	FIRE ALARM ZONE TEST	307	101	SUM	3/22/2011	TS	3/4/2011	11X0A0230703512100001	8	4
LGA	3072135	688055	PM	FIRE ALARM ZONE TEST	307	101	SUM	3/22/2011	TS	3/11/2011	11X0A0230703512100001	8	4
LGA	3072135	6880S6	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	3/22/2011	TS	3/18/2011	11X0A0230703512100001	8	0
LGA	3072135	688057	PM	FIRE ALARM ZONE TEST	307	101	SUM	4/9/2011	TS	3/25/2011	11X0A0230703512100001	8	4
LGA	3072135	690607	PM	FIRE ALARM ZONE TE5T	307	101	SUM	4/9/2011	TS	4/1/2011	11X0A0230703512100001	8	4
LGA	3072135	690608	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	4/26/2011	TS	4/8/2011	11X0A0230703512100001	8	0
LGA	3072135	690609	PM	FIRE ALARM ZONE TEST	307	101	SUM	4/26/2011	TS	4/15/2011	11X0A0230703512100001	8	4
LGA	3072135	690610	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	5/23/2011	TS	4/22/2011	11X0A0230703512100001	8	0
LGA	3072135	690611	PM	FIRE ALARM ZONE TEST	307	101	SUM	5/23/2011	TS	4/29/2011	11X0A0230703512100001	8	4
LGA	3072135	693003	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	5/23/2011	TS	5/6/2011	11X0A0230703512100001	8	0
LGA	3072135	693004	PM	FIRE ALARM ZONE TEST	307	101	SUM	5/25/2011	TS	5/13/2011	11X0A0230703512100001	8	2
LGA	3072135	693005	PM	FIRE ALARM ZONE TEST	307	101	SUM	5/25/2011	TS	5/20/2011	11X0A0230703512100001	8	3
LGA	3072135	693006	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	6/17/2011	TS	5/27/2011	11X0A0230703512100001	8	0
LGA	3072135	695570	PM	FIRE ALARM ZONE TEST	307	101	SUM	6/17/2011	TS	6/3/2011	11X0A0230703512100001	8	2
LGA	3072135	695571	PM	FIRE ALARM ZONE TEST	307	101	SUM	6/17/2011	TS	6/10/2011	11X0A0230703512100001	8	4
LGA	3072135	695572	PM	FIRE ALARM ZONE TEST	307	101	SUM	6/29/2011	TS	6/17/2011	11X0A0230703512100001	8	12
LGA	3072135	695573	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	6/29/2011	TS	6/24/2011	11X0A0230703512100001	8	0
LGA	3072135	698169	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	7/19/2011	TS	7/1/2011	11X0A0230703512100001	8	0
LGA	3072135	698170	PM	FIRE ALARM ZONE TEST	307	101	SUM	7/19/2011	TS	7/8/2011	11X0A0230703512100001	8	2
LGA	3072135	698171	PM	FIRE ALARM ZONE TEST	307	101	SUM	7/19/2011	TS	7/15/2011	11X0A0230703512100001	8	8
LGA	3072135	698172	PM	FIRE ALARM ZONE TEST	307	101	SUM	8/19/2011	TS	7/22/2011	11X0A0230703512100001	8	10
LGA	3072135	698173	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	8/19/2011	TS	7/29/2011	11X0A0230703512100001	8	0
LGA	3072135	700699	PM	FIRE ALARM ZONE TEST	307	101	SUM	8/26/2011	TS	8/5/2011	11X0A0230703512100001	8	9.5
LGA	3072135	700700	PM	FIRE ALARM ZONE TEST	307	101	SUM	8/26/2011	TS	8/12/2011	11X0A0230703512100001	8	2

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072135	700701	PM	FIRE ALARM ZONE TEST	307	101	SUM	8/26/2011	TS	8/19/2011	11X0A0230703512100001	8	4
LGA	3072135	700702	PM	FIRE ALARM ZONE TEST	307	101	SUM	9/22/2011	TS	8/26/2011	11X0A0230703512100001	8	4
LGA	3072135	703335	PM	FIRE ALARM ZONE TEST	307	101	SUM	9/22/2011	TS	9/2/2011	11X0A0230703512100001	8	4
LGA	3072135	703336	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	9/22/2011	TS	9/9/2011	11X0A0230703512100001	8	0
LGA	3072135	703337	PM	FIRE ALARM ZONE TEST	307	101	SUM	9/22/2011	TS	9/16/2011	11X0A0230703512100001	8	8
LGA	3072135	703338	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	10/14/2011	TS	9/23/2011	11X0A0230703512100001	8	0
LGA	3072135	703339	PM	FIRE ALARM ZONE TEST	307	101	SUM	10/14/2011	TS	9/30/2011	11X0A0230703512100001	8	4
LGA	3072135	705982	PM	FIRE ALARM ZONE TEST	307	101	SUM	11/10/2011	TS	10/7/2011	11X0A0230703512100001	8	4
LGA	3072135	705983	PM	FIRE ALARM ZONE TEST	307	101	SUM	11/10/2011	TS	10/14/2011	11X0A0230703512100001	8	6
LGA	3072135	705984	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	11/10/2011	TS	10/21/2011	11X0A0230703512100001	8	0
LGA	3072135	705985	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	11/10/2011	TS	10/28/2011	11X0A0230703512100001	8	0
LGA	3072135	708568	PM	FIRE ALARM ZONE TEST	307	101	CANSUM	11/10/2011	TS	11/4/2011	11X0A0230703512100001	8	0
LGA	3072135	708569	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	12/5/2011	TS	11/11/2011	11X0A0230703512100001	8	2
LGA	3072135	708570	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/5/2011	TS	11/18/2011	11X0A0230703512100001	8	0
LGA	3072135	708571	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/5/2011	TS	11/25/2011	11X0A0230703512100001	8	0
LGA	3072135	710944	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	12/6/2011	TS	12/2/2011	11X0A0230703512100001	8	12
LGA	3072135	710945	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	1/4/2012	TS	12/9/2011	11X0A0230703512100001	8	4
LGA	3072135	710946	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	1/5/2012	TS	12/16/2011	11X0A0230703512100001	8	0
LGA	3072135	710947	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	1/5/2012	TS	12/23/2011	11X0A0230703512100001	8	0
LGA	3072135	710948	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	1/5/2012	TS	12/30/2011	11X0A0230703512100001	8	0
LGA	3072135	713291	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	1/25/2012	TS	1/6/2012	11X0A0230703512100001	8	2
LGA	3072135	713292	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	1/25/2012	TS	1/13/2012	11X0A0230703512100001	8	0
LGA	3072135	713293	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	1/25/2012	TS	1/20/2012	11X0A0230703512100001	8	16
LGA	3072135	713294	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	2/13/2012	TS	1/27/2012	11X0A0230703512100001	8	0
LGA	3072135	715773	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	2/13/2012	TS	2/3/2012	11X0A0230703512100001	8	0
LGA	3072135	715774	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	3/19/2012	TS	2/10/2012	11X0A0230703512100001	8	16
LGA	3072135	715775	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	3/19/2012	TS	2/17/2012	11X0A0230703512100001	8	0
LGA	3072135	715776	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	3/19/2012	TS	2/24/2012	11X0A0230703512100001	8	4
LGA	3072135	717989	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	3/19/2012	TS	3/2/2012	11X0A0230703512100001	8	0
LGA	3072135	717990	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	3/19/2012	TS	3/9/2012	11X0A0230703512100001	8	16
LGA	3072135	717991	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	4/6/2012	TS	3/16/2012	11X0A0230703512100001	8	0
LGA	3072135	717992	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	4/19/2012	TS	3/23/2012	11X0A0230703512100001	8	0
LGA	3072135	717993	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	4/19/2012	TS	3/30/2012	11X0A0230703512100001	8	0
LGA	3072135	720511	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	4/19/2012	TS	4/6/2012	11X0A0230703512100001	8	0
LGA	3072135	720512	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	4/19/2012	TS	4/13/2012	11X0A0230703512100001	8	0
LGA	3072135	720513	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	5/5/2012	TS	4/20/2012	11X0A0230703512100001	8	16
LGA	3072135	720514	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	5/5/2012	TS	4/27/2012	11X0A0230703512100001	8	0
LGA	3072135	723109	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	5/17/2012	TS	5/4/2012	11X0A0230703512100001	8	0
LGA	3072135	723110	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	5/17/2012	TS	5/11/2012	11X0A0230703512100001	8	0
LGA	3072135	723111	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	6/5/2012	TS	5/18/2012	11X0A0230703512100001	8	0
LGA	3072135	723112	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	6/5/2012	TS	5/25/2012	11X0A0230703512100001	8	8
LGA	3072135	725791	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	6/5/2012	TS	6/1/2012	11X0A0230703512100001	8	0
LGA	3072135	725792	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	6/25/2012	TS	6/8/2012	11X0A0230703512100001	8	0
LGA	3072135	725793	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	6/25/2012	TS	6/15/2012	11X0A0230703512100001	8	0
LGA	3072135	725794	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	9/19/2012	TS	6/22/2012	11X0A0230703512100001	8	0
LGA	3072135	725795	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/14/2012	TS	6/29/2012	11X0A0230703512100001	8	0
LGA	3072135	728295	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/14/2012	TS	7/6/2012	11X0A0230703512100001	8	0

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072135	728296	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	7/18/2012	TS	7/13/2012	11X0A0230703S12100001	8	15
LGA	3072135	728297	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	8/9/2012	TS	7/20/2012	11X0A0230703512100001	8	0
LGA	3072135	728298	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	8/9/2012	TS	7/27/2012	11X0A0230703512100001	8	8
LGA	3072135	731168	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	8/22/2012	TS	8/3/2012	11X0A0230703S12100001	8	0
LGA	3072135	731169	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	8/22/2012	TS	8/10/2012	11X0A0230703512100001	8	0
LGA	3072135	731170	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	8/22/2012	TS	8/17/2012	11X0A0230703512100001	8	0
LGA	3072135	731171	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	9/19/2012	TS	8/24/2012	11X0A0230703512100001	8	2
LGA	3072135	731172	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	9/19/2012	TS	8/31/2012	11X0A0230703512100001	8	12
LGA	3072135	733760	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	9/19/2012	TS	9/7/2012	11X0A0230703S12100001	8	4
LGA	3072135	733761	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	9/19/2012	TS	9/14/2012	11X0A0230703512100001	8	0
LGA	3072135	733762	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/6/2012	TS	9/21/2012	11X0A0230703512100001	8	0
LGA	3072135	733763	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	10/6/2012	TS	9/28/2012	11X0A0230703512100001	8	23
LGA	3072135	736260	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	10/17/2012	TS	10/5/2012	11X0A0230703512100001	8	2
LGA	3072135	736261	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/18/2012	TS	10/12/2012	11X0A0230703512100001	8	0
LGA	3072135	736262	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	11/16/2012	TS	10/19/2012	11X0A0230703S12100001	8	0
LGA	3072135	736263	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	11/16/2012	TS	10/26/2012	11X0A0230703512100001	8	0
LGA	3072135	738885	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	11/16/2012	TS	11/2/2012	11X0A0230703512100001	8	0
LGA	3072135	738886	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	11/16/2012	TS	11/9/2012	11X0A0230703512100001	8	0
LGA	3072135	738887	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	11/28/2012	TS	11/16/2012	11X0A0230703512100001	8	0
LGA	3072135	738888	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	11/28/2012	TS	11/23/2012	11X0A0230703512100001	8	2
LGA	3072135	738889	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/11/2012	TS	11/30/2012	11X0A0230703512100001	8	0
LGA	3072135	741345	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/11/2012	TS	12/7/2012	11X0A0230703512100001	8	0
LGA	3072135	741346	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	1/4/2013	TS	12/14/2012	11X0A0230703512100001	8	0
LGA	3072135	741347	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	1/4/2013	TS	12/21/2012	11X0A0230703512100001	8	8
LGA	3072135	741348	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	1/4/2013	TS	12/28/2012	11X0A0230703512100001	8	0
LGA	3072135	743704	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	1/8/2013	TS	1/4/2013	11X0A0230703512100001	8	16
LGA	3072135	743705	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	1/26/2013	TS	1/11/2013	11X0A0230703512100001	8	16
LGA	3072135	743706	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	2/13/2013	TS	1/18/2013	11X0A0230703512100001	8	0
LGA	3072135	743707	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	2/13/2013	TS	1/25/2013	11X0A0230703512100001	8	0
LGA	3072135	746357	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	2/13/2013	TS	2/1/2013	11X0A0230703512100001	8	16
LGA	3072135	746358	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	2/13/2013	TS	2/8/2013	11X0A0230703512100001	8	0
LGA	307213S	746359	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	3/11/2013	TS	2/15/2013	11X0A0230703512100001	8	8
LGA	3072135	746360	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	3/11/2013	TS	2/22/2013	11X0A0230703512100001	8	0
LGA	3072135	748572	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	3/11/2013	TS	3/1/2013	11X0A0230703512100001	8	0
LGA	3072135	748573	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	3/20/2013	TS	3/8/2013	11X0A0230703512100001	8	0
LGA	3072135	748574	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	3/20/2013	TS	3/15/2013	11X0A0230703512100001	8	0
LGA	3072135	748575	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	4/9/2013	TS	3/22/2013	11X0A0230703512100001	8	4
LGA	3072135	748576	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	4/10/2013	TS	3/29/2013	11X0A0230703512100001	8	0
LGA	3072135	751140	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	4/10/2013	TS	4/5/2013	11X0A0230703512100001	8	6
LGA	307213S	751141	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	4/30/2013	TS	4/12/2013	11X0A0230703512100001	8	0
LGA	3072135	751142	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	4/30/2013	TS	4/19/2013	11X0A0230703512100001	8	16
LGA	307213S	751143	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	4/30/2013	TS	4/26/2013	11X0A0230703512100001	8	0
LGA	3072135	753627	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	5/7/2013	TS	5/3/2013	11X0A0230703512100001	8	0
LGA	3072135	753628	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	5/28/2013	TS	5/10/2013	11X0A0230703512100001	8	0
LGA	3072135	753629	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	5/28/2013	TS	5/17/2013	11X0A0230703512100001	8	0
LGA	3072135	753630	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	5/28/2013	TS	5/24/2013	11X0A0230703512100001	8	0
LGA	307213S	753631	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	6/25/2013	TS	5/31/2013	11X0A0230703512100001	8	0

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072135	756253	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	6/25/2013	TS	6/7/2013	11X0A0230703512100001	8	8
LGA	3072135	756254	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	6/25/2013	TS	6/14/2013	11X0A0230703512100001	8	14
LGA	3072135	756255	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/3/2013	TS	6/21/2013	11X0A0230703512100001	8	0
LGA	3072135	756256	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/3/2013	TS	6/28/2013	11X0A0230703512100001	8	0
LGA	3072135	758968	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/31/2013	TS	7/5/2013	11X0A0230703512100001	8	0
LGA	3072135	758969	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/31/2013	TS	7/12/2013	11X0A0230703512100001	8	0
LGA	3072135	758970	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	8/5/2013	TS	7/19/2013	11X0A0230703512100001	8	0
LGA	3072135	758971	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	8/5/2013	TS	7/26/2013	11X0A0230703512100001	8	0
LGA	3072135	761581	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	9/11/2013	TS	8/2/2013	11X0A0230703512100001	8	16
LGA	3072135	761582	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	9/11/2013	TS	8/9/2013	11X0A0230703512100001	8	4
LGA	3072135	761583	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	9/11/2013	TS	8/16/2013	11X0A0230703512100001	8	0
LGA	3072135	761584	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	9/11/2013	TS	8/23/2013	11X0A0230703512100001	8	6.5
LGA	3072135	761585	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	9/17/2013	C1	8/30/2013	11X0A0230703512100001	8	0
LGA	3072135	764097	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	9/17/2013	C1	9/6/2013	11X0A0230703512100001	8	8
LGA	3072135	764098	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	9/17/2013	C1	9/13/2013	11X0A0230703512100001	8	0
LGA	3072135	764099	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/17/2013	C1	9/20/2013	11X0A0230703512100001	8	0
LGA	3072135	764100	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/17/2013	C1	9/27/2013	11X0A0230703512100001	8	0
LGA	3072135	767104	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/24/2013	C1	10/4/2013	11X0A0230703512100001	8	0
LGA	3072135	767105	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/24/2013	C1	10/11/2013	11X0A0230703512100001	8	0
LGA	3072135	767106	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/29/2013	C1	10/18/2013	11X0A0230703512100001	8	0
LGA	3072135	767107	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/29/2013	C1	10/25/2013	11X0A0230703512100001	8	0
LGA	3072135	769650	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	11/16/2013	C1	11/1/2013	11X0A0230703512100001	8	7
LGA	3072135	769651	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/5/2013	C1	11/8/2013	11X0A0230703512100001	8	0
LGA	3072135	769652	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/5/2013	C1	11/15/2013	11X0A0230703512100001	8	0
LGA	3072135	769653	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/10/2013	C1	11/22/2013	11X0A0230703512100001	8	0
LGA	3072135	769654	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/10/2013	C1	11/29/2013	11X0A0230703512100001	8	0
LGA	3072135	772013	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/10/2013	C1	12/6/2013	11X0A0230703512100001	8	0
LGA	3072135	772014	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	12/27/2013	C1	12/13/2013	11X0A0230703512100001	8	6
LGA	3072135	772015	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	12/27/2013	C1	12/20/2013	11X0A0230703512100001	8	0
LGA	3072135	772016	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	1/14/2014	C1	12/27/2013	11X0A0230703512100001	8	0
LGA	3072135	774407	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	1/14/2014	C1	1/3/2014	11X0A0230703512100001	8	0
LGA	3072135	774408	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	1/28/2014	C1	1/10/2014	11X0A0230703512100001	8	0
LGA	3072135	774409	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	1/28/2014	C1	1/17/2014	11X0A0230703512100001	8	0
LGA	3072135	774410	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	2/10/2014	C1	1/24/2014	11X0A0230703512100001	8	20
LGA	3072135	774411	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	2/10/2014	C1	1/31/2014	11X0A0230703512100001	8	8
LGA	3072135	776998	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	3/5/2014	C1	2/7/2014	11X0A0230703512100001	8	15
LGA	3072135	776999	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	3/5/2014	C1	2/14/2014	11X0A0230703512100001	8	0
LGA	3072135	777000	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	3/5/2014	C1	2/21/2014	11X0A0230703512100001	8	0
LGA	3072135	777001	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	3/5/2014	C1	2/28/2014	11X0A0230703512100001	8	0
LGA	3072135	780788	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	3/22/2014	C1	3/7/2014	11X0A0230703512100001	8	8
LGA	3072135	780789	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	3/22/2014	C1	3/14/2014	11X0A0230703512100001	8	8
LGA	3072135	780790	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	4/8/2014	C1	3/21/2014	11X0A0230703512100001	8	12
LGA	3072135	780791	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	4/8/2014	C1	3/28/2014	11X0A0230703512100001	8	3
LGA	3072135	783081	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/31/2014	C1	4/4/2014	11X0A0230703512100001	8	0
LGA	3072135	783082	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	5/12/2014	C1	4/11/2014	11X0A0230703512100001	8	0
LGA	3072135	783083	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	5/12/2014	C1	4/18/2014	11X0A0230703512100001	8	0
LGA	3072135	783084	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	5/12/2014	C1	4/25/2014	11X0A0230703512100001	8	6

FACILITY	PM/PROJECT NUMBER	WO NUMBER	WO TYPE	WO DESCRIPTION	ORG UNIT	SECT SUBS	WO STATUS	COMPLETE DATE	MAINT TYPE	NEED DATE	ACCOUNT CODE	EST LABOR HOURS	ACT LABOR HOURS
LGA	3072135	785797	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	5/15/2014	C1	5/2/2014	11X0A0230703512100001	8	16
LGA	3072135	785798	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	5/19/2014	C1	5/9/2014	11X0A0230703512100001	8	8
LGA	3072135	785799	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	7/31/2014	C1	5/16/2014	11X0A0230703512100001	8	12
LGA	3072135	785800	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	6/9/2014	C1	5/23/2014	11X0A0230703512100001	8	12
LGA	3072135	785801	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	6/10/2014	C1	5/30/2014	11X0A0230703512100001	8	12
LGA	3072135	788610	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	7/31/2014	C1	6/6/2014	11X0A0230703512100001	8	0
LGA	3072135	788611	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	7/11/2014	C1	6/13/2014	11X0A0230703512100001	8	7
LGA	3072135	788612	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	7/11/2014	C1	6/20/2014	11X0A0230703512100001	8	4
LGA	3072135	788613	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	7/11/2014	C1	6/27/2014	11X0A0230703512100001	8	4
LGA	3072135	791309	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/11/2014	C1	7/4/2014	11X0A0230703512100001	8	0
LGA	3072135	791310	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/31/2014	C1	7/11/2014	11X0A0230703512100001	8	0
LGA	3072135	791311	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	7/31/2014	C1	7/18/2014	11X0A0230703512100001	8	0
LGA	3072135	791312	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	8/23/2014	C1	7/25/2014	11X0A0230703512100001	8	0
LGA	3072135	794137	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	8/23/2014	C1	8/1/2014	11X0A0230703512100001	8	20
LGA	3072135	794138	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	8/23/2014	C1	8/8/2014	11X0A0230703512100001	8	0
LGA	3072135	794139	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	8/23/2014	TS	8/15/2014	11X0A0230703512100001	8	0
LGA	3072135	794140	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	9/15/2014	C1	8/22/2014	11X0A0230703512100001	8	0
LGA	3072135	794141	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	9/15/2014	C1	8/29/2014	11X0A0230703512100001	8	16.5
LGA	3072135	796735	PM	FIRE ALARM ZONE TEST	307	101	CLOSED	9/19/2014	C1	9/5/2014	11X0A0230703512100001	8	4
LGA	3072135	796736	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	9/19/2014	C1	9/12/2014	11X0A0230703512100001	8	0
LGA	3072135	796737	PM	FIRE ALARM ZONE TEST	307	101	COMPLT	10/18/2014	C1	9/19/2014	11X0A0230703512100001	8	16
LGA	3072135	796738	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/18/2014	C1	9/26/2014	11X0A0230703512100001	8	0
LGA	3072135	799651	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/18/2014	C1	10/3/2014	11X0A0230703512100001	8	0
LGA	3072135	799652	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	10/18/2014	C1	10/10/2014	11X0A0230703512100001	8	0
LGA	3072135	799653	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	11/10/2014	C1	10/17/2014	11X0A0230703512100001	8	0
LGA	3072135	799654	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	11/10/2014	C1	10/24/2014	11X0A0230703512100001	8	0
LGA	3072135	799655	PM	FIRE ALARM ZONE TEST	307	101	CANCEL	11/10/2014	C1	10/31/2014	11X0A0230703512100001	8	0
LGA	3072135	802427	PM	FIRE ALARM ZONE TEST	307	101	ACTIVE		C1	11/7/2014	11X0A0230703512100001	8	0

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	2/19/2014 1:57	2/19/2014 1:50	2/19/2014 1:50	Joe Carney	Term D- numerous fire alarms.New facility maint company ISS-Corrigan Hawker (3020032185) forgot to call PAPD Fire Marshall Operations anyone about walk through.Engineer-Carmela Cinicolo was there as a courtesy and upset that proper calls were not made.PAPD desk was advised.
FIRE ALARMS	2/19/2014 11:33	2/19/2014 11:33	2/19/2014 11:33	Minerva Colon	
FIRE ALARMS	2/19/2014 12:49	2/19/2014 12:41	2/19/2014 12:41	Minerva Colon	0918 hrs. - AAL Bldg. Mtce. (Paul Balassano) will be performing hydrant flow testing at hangar 1. PAPD Electric shop and CH&RP notified.
FIRE ALARMS	2/20/2014 3:37	2/20/2014 2:57	2/20/2014 2:57	Joe Carney	0138- ISS at Term D doing testing. PAPD and Ops advised.0330-Test complete.
FIRE ALARMS	2/20/2014 11:43	2/20/2014 11:41	2/20/2014 8:25	Rosemary Millan	0825L CHRP testing fire alarms at west zone areas(Flight Safety BldgHertz Avis Hgr 7S and Old Post office).1045L Testing completed.
FIRE ALARMS	2/20/2014 20:27	2/20/2014 20:09	2/20/2014 20:09	Minerva Colon	1900 hrs. - Fire alarm strobes activated. 1079 notified. Alarm panel indicates Warm reset MMD MSL CTB 1st flr East PNL. 1079 and CH&RP notified. PAPD responded. 1901 hrs. - OCC issued fire alarm investigation announcement.1915 hrs. - Electrical 3 (Ray Eng) and electricans checking room 133. Negative condition and they are responding to CH&RP to reset fire board.1916 hrs. - OCC issued investigation complete announcement.
FIRE ALARMS	2/21/2014 20:48	2/21/2014 20:48	2/21/2014 20:48	Joe Carney	1939- H4 had a false alarm.AAL maint advised.FW was in place.
FIRE ALARMS	2/22/2014 3:37	2/22/2014 1:09	2/22/2014 1:09	Joe Carney	Electric Shop here for testing.0034- Test starts.0247- Test complete.
FIRE ALARMS	2/24/2014 13:14	2/24/2014 13:13	2/24/2014 13:13	Minerva Colon	0755 hrs. - ISS (Delta bldg. maint.) advises fire alarm system partial bypass. PAPD notified.
FIRE ALARMS	2/26/2014 13:33	2/26/2014 13:24	2/26/2014 13:24	Minerva Colon	0812 hrs. - Delta bldg. mtce. - ISS - advises will be conducting fire alarm testing in Terminal C. PAPD notified.1125 hrs. - ISS advises fire alarm testing complete. PAPD notified.
FIRE ALARMS	2/26/2014 13:49	2/26/2014 13:47	2/26/2014 13:47	Minerva Colon	1000 hrs. - Electric shop (George) advises staff will be conducting fire alarm testing in the CTB.1120 hrs. - Electric shop completed testing CTB.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	2/26/2014 14:56	2/26/2014 14:53	2/26/2014 13:47	Rosemary Millan	1347L FAA Pablo 516-749-6085 advises weekly fire alarm testing is being conducted.1413L Fire alarm testing completed.
FIRE ALARMS	2/26/2014 22:00	2/26/2014 21:40	2/26/2014 21:15	Rosemary Millan	Terminal C fire alarm activated.Manual pull station. Responded with PAPD PO Rodriguez and negative fire condition but pull station was activated. The location of pull station is believed to be near Delta Ops door at Terminal C towards ramp side. ISS shift supervisor Joel Coronel is looking into repairing the faulty wall for repair and to advise if this was actual cause of pull station fire alarm.ISS Assistant manager Max Lapierre advises their emergency contact phone number for Lga shift supervisors is 718-570-4965.During regular hours the ISS phone number for maintenance requests is 718-565-4616.Phone numbers are for Terminal A C and D (ISS replaced ABM for facility maintenance).
FIRE ALARMS	2/27/2014 14:40	2/27/2014 14:36	2/27/2014 14:36	Minerva Colon	1331 hrs. - Fuel Farm (Ellio) advises will conduct alarm testing in the fuel farm. PAPD notified.1415 hrs. - Fuel farm advises testing complete. PAPD advised.
FIRE ALARMS	2/28/2014 3:14	2/28/2014 2:23	2/28/2014 0:35	Rosemary Millan	0035L ISS Roger advises fire alarm testing fire sprinklers at terminal D being conducted: PAPD notified.0310L ISS Roger advises continues testing at Terminal D; water draining sprinkler line; PAPD notified.
FIRE ALARMS	2/28/2014 13:56	2/28/2014 13:53	2/28/2014 13:53	Minerva Colon	0810 hrs. - CHRP advises fire alarm testing will be conducted in hgrs. 2 4 and bldg. 85. PAPD notified.1032 hrs. - CHRP advise testing complete.
FIRE ALARMS	3/1/2014 4:32	3/1/2014 4:30	2/28/2014 23:05	Rosemary Millan	2305L Roger Terminal C ISS advises they are relocating spriklerheads at terminal.0425L Rob from ISS advises work completed.
FIRE ALARMS	3/3/2014 5:59	3/3/2014 5:39	3/3/2014 5:39	Minerva Colon	0427 hrs. - Fire alarms activitated CTB East Fire Alarm SD CTB Continental Baggage. 1079 responding.0430 hrs. - OCC notified negative condition. Advised by employee in bag room that workers started vehicles and one vehicle emitted some smoke from the tailpipe.0445 hrs. - Alarms reset.
FIRE ALARMS	3/4/2014 17:57	3/4/2014 17:53	3/4/2014 17:53	Minerva Colon	1542 hrs. - CHRP advise they will be conducting testing of bldg. 25 new fire pump station.1750 hrs. - Testing complete.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	3/4/2014 17:59	3/4/2014 17:57	3/4/2014 17:57	Minerva Colon	1625 hrs. - Electric shop advises they will be conducting repair to CTB pull station.1735 hrs. - Repairs complete.
FIRE ALARMS	3/6/2014 4:04	3/6/2014 0:40	3/6/2014 0:11	Rosemary Millan	ISS Ralph at Terminal C advises system is in bypas mode due to sprinkler head work.
FIRE ALARMS	3/6/2014 11:20	3/6/2014 11:15	3/6/2014 8:17	Rosemary Millan	0817L - PA electric shop testing fire alarms at hgr11.0905L testing completed.0905L PA electric shop testing fire alarm at hgr 70957L testing completed.0936L PA electric testing hold up alarms in parking garage.1015L testing completed.
FIRE ALARMS	3/7/2014 13:05	3/7/2014 12:59	3/7/2014 7:32	Rosemary Millan	0732L ISS Roger advises they are testing sprinkler and fire system.0834L CHRP Pete testing parking garage alarms0957L ISS testing completed.1012L FAA Carmelo advises they are testing fire alarms at new ATCT1050L FAA testing completed
FIRE ALARMS	3/10/2014 14:32	3/10/2014 14:28	3/10/2014 14:28	Joe Carney	MER 3 at Term D.ISS called for explanation.
FIRE ALARMS	3/11/2014 5:44	3/11/2014 1:32	3/10/2014 23:01	Rosemary Millan	2301L Terminal C ISS Kerrigan advises they are replacing 3 sprinkler heads. 0518L Terminal C fire completed.
FIRE ALARMS	3/11/2014 6:25	3/11/2014 1:34	3/11/2014 23:43	Rosemary Millan	2343L CTB fire alarm activated PSR 1st floor south panel # 2 71 on scene upper level food court audible and strobes activated.PAPD1079 and CHRP notified.PA Ops CC sent out advisory announcements throughout the fire alarm investigation. Audible concentrated in lower level food court area; strobes activated at both arrivals and departures level.107971 PAPD searched for activated pull station with no avail.0042L PA1079 secured the fire alarm.PA Ops CC sent out closing announcements.PAPD PO J. Gimigliano filed fire case report #28560150L PA 1079 continues investigation of fire alarm; CHRP advises their fans never turned back on. The fans in PA ops did not turn on either.0530L CHRP Eric contacted for Ops fans remain off and temperatures getting very warm. Electricians continue to investigate matter.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	3/11/2014 6:57	3/11/2014 6:25	3/11/2014 6:25	Joe Carney	2343L CTB fire alarm activated PSR 1st floor south panel # 2 71 on scene upper level food court audible and strobes activated.PAPD1079 and CHRP notified.PA Ops CC sent out advisory announcements throughout the fire alarm investigation. Audible concentrated in lower level food court area; strobes activated at both arrivals and departures level.107971 PAPD searched for activated pull station with no avail.0042L PA1079 secured the fire alarm.PA Ops CC sent out closing announcements.PAPD PO J. Gimigliano filed fire case report #28560150L PA 1079 continues investigation of fire alarm; CHRP advises their fans never turned back on. The fans in PA ops did not turn on either.0530L CHRP Eric contacted for Ops fans remain off and temperatures getting very warm. Electricians continue to investigate matter.0620- Temps in Ops office is at 78-79 degrees.....0650- Strobe alarms ongoing in Central Food Court LL- by bathrooms and in hall to storage area behind restaurants.0656- Jetblue reports no power in half their office.
FIRE ALARMS	3/12/2014 5:32	3/12/2014 2:44	3/11/2014 23:00	Rosemary Millan	Terminal D ISS Roger advises they are conducting fire alarm testing.0530L testing completed.
FIRE ALARMS	3/12/2014 2:49	3/12/2014 2:46	3/11/2014 21:46	Rosemary Millan	2146L Terminal C Delta Delta D Arrival corridor Hudson concourse fire alarm activated. PAPD notifiedISS Anastasia advises a pull box was activated but negative fire condition; ISS resetting pull box.
FIRE ALARMS	3/13/2014 10:47	3/13/2014 9:31	3/13/2014 9:31	Joe Carney	0847- Terry from CHRP conducting testing at new pump station.1030- test complete.
FIRE ALARMS	3/14/2014 11:03	3/14/2014 9:39	3/14/2014 9:39	Joe Carney	0933- CHRP testing new pump station bldg 230948- Done.1002- ATCT alarm testing1041- complete.
FIRE ALARMS	3/17/2014 21:16	3/17/2014 21:15	3/17/2014 21:15	Joe Carney	2115- ISS at Term D- sprinkler shut down.PAPD advised.
FIRE ALARMS	3/18/2014 13:45	3/18/2014 13:43	3/18/2014 13:43	Minerva Colon	0728 hrs. - Delta Mtce. - ISS - advises fire alarm testing will be conducted in Terminal D. PAPD notified.1315 hrs. - ISS advises alarms are B/I/S.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	3/18/2014 14:22	3/18/2014 14:20	3/18/2014 14:20	Minerva Colon	1039 hrs. - Holt construction advises they will have contractor - Firecraft - working on fire alarm panel in hangar 1 3 and 5. PAPD advised.
FIRE ALARMS	3/18/2014 15:15	3/18/2014 15:14	3/18/2014 15:14	Joe Carney	1500- Bill Holy from Fire Craft advises of alarm check in H-1/3/5
FIRE ALARMS	3/19/2014 1:26	3/19/2014 1:24	3/19/2014 0:40	Rosemary Millan	Manual pull station activated at 4th level parking garage connector walkway.PAPA 71 1079 responded.0107L 1079 located pull station and reset; negative fire condition.
FIRE ALARMS	3/19/2014 14:02	3/19/2014 14:01	3/19/2014 14:01	Minerva Colon	0953 hrs. - Electric shop advises they are conducting Fire Alarm testing at Bldg. 30. 1035 hrs. - Testing complete.
FIRE ALARMS	3/19/2014 21:14	3/19/2014 21:13	3/19/2014 21:13	Joe Carney	ISS advises that system in Term C will be in by-pass.
FIRE ALARMS	3/20/2014 5:45	3/20/2014 5:43	3/20/2014 5:15	Rosemary Millan	0515L Terminal C fire alarms back on line.
FIRE ALARMS	3/20/2014 13:45	3/20/2014 13:15	3/20/2014 13:15	Minerva Colon	1010 hrs. - Electric shop advises they will be conducting fire alarm testing in parking lot 2. 1112 hrs. - Testing complete.
FIRE ALARMS	3/20/2014 13:41	3/20/2014 13:16	3/20/2014 13:16	Minerva Colon	0805 hrs. - CHRP conducting fire alarm testing at Flight Safety Avis Hertz Mail Facility Fuel Farm and Gate Gourmet.1145 hrs. - Fire alarm testing is complete.
FIRE ALARMS	3/20/2014 14:15	3/20/2014 13:51	3/20/2014 13:51	Minerva Colon	0721 hrs. - Fire Alarm activated - Hgr. 4 ACME Panel Pull Station deluge valve #1 water flow. CHRP notified and advise fire watch in hangar. 0741 hrs. - Fire alarm activated again then cleared.
FIRE ALARMS	3/20/2014 21:14	3/20/2014 15:02	3/20/2014 15:02	Joe Carney	Terry from CHRP advises of test at new pump station.1640 pump station test complete.Also techs on roof by R-6 PAPD advised.----------1540- Electric Shop performing alarm testing at Parking Office.----------1545- FAA doing ATCT alarm testing.----------2113- Roger from ISS called to advise of pull station work at term C.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	3/21/2014 5:05	3/21/2014 0:47	3/21/2014 0:00	Rosemary Millan	0000L PA Electrical testing parking alarms in lot2 from 0000l to 0100L; strobes and audible may be activated: PAPD notified.0016L Terminal C lovell advises manual pull station was activated; no actual condition. ISS investigating.0455L ISS completed testing at Terminal C0200L RE 22 advises fire alarm testing ctb arrivals with fire craft. PAPD fire Marshall on scene.0230L fire alarm testing completed.
FIRE ALARMS	3/21/2014 14:04	3/21/2014 14:02	3/21/2014 14:02	Minerva Colon	0753 hrs. - Delta Bldg. Mtce. ISS advises terminal C fire alarms will be off line for change of sprinkler heads.
FIRE ALARMS	3/22/2014 5:46	3/22/2014 1:47	3/22/2014 0:08	Rosemary Millan	0008L ISS Ralph advises they are testing fire alarms at terminal D.0403L ISS completed fire alarm testing.
FIRE ALARMS	3/23/2014 5:53	3/23/2014 5:43	3/23/2014 23:05	Rosemary Millan	2305L ISS Roger advises fire alarm testing; pull station being conducting.0327L testing completed.
FIRE ALARMS	3/24/2014 2:50	3/24/2014 2:44	3/24/2014 0:55	Rosemary Millan	0055L ISS Terminal D advises fire alarm system is in bypass mode for testing.
FIRE ALARMS	3/24/2014 9:36	3/24/2014 9:35	3/24/2014 9:35	Minerva Colon	0800 hrs. - CHRP (Pete) advises they will be testing fire alarms in CTB.
FIRE ALARMS	3/25/2014 1:07	3/24/2014 9:36	3/24/2014 9:36	Minerva Colon	0814 hrs. - Delta Bldg. Mtce. - ISS - (Corrigan) will be conducting fire alarm testing/repairs in terminal C and D. Fire alarm system on bypass.
FIRE ALARMS	3/25/2014 5:51	3/25/2014 1:05	3/25/2014 0:49	Rosemary Millan	0049L ISS Terminal C Ralph advises fire system is in bypass mode for sprinkler work at upper food court area.0530L Terminal C fire alarm system back on line.
FIRE ALARMS	3/25/2014 5:49	3/25/2014 1:07	3/25/2014 1:07	Rosemary Millan	0814 hrs. - Delta Bldg. Mtce. - ISS - (Corrigan) will be conducting fire alarm testing/repairs in terminal C and D. Fire alarm system on bypass.1255L Terminal C and D fire alarm system back on line.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	3/26/2014 13:49	3/26/2014 9:05	3/26/2014 8:30	Rosemary Millan	0830L ISS advises fire alarm testing being conducted at Terminal D and Terminal A.1230L ISS completed testing.0830L PA Electric testing fire alarms at bldg 39 and 84.1031L Fire alarm testing.0735L Holt construction Glen working on fire sprinkler system at Hgr 5BGlen contact number 914-490-3539CHRP JE advises fire protection at United bag room restored. UAL has their own fire watch. Fire Marshall to notify when UAL can secure fire watch.1230L FAA testing at new control tower.1345L FAA completed testing.
FIRE ALARMS	3/27/2014 13:45	3/27/2014 13:42	3/27/2014 8:00	Rosemary Millan	0800L PA electrical testing alarms from AFA.1335L testing completed.0808L ISS Terminal D fire alarm in bypass mode for testing.
FIRE ALARMS	3/27/2014 19:54	3/27/2014 19:53	3/27/2014 19:53	Minerva Colon	1444 hrs. - CHRP (Terry) advises testing fire alarms at high power pump station.1733 hrs. - CHRP advise testing complete.
FIRE ALARMS	3/28/2014 4:43	3/27/2014 23:59	3/27/2014 23:59	Joe Carney	2346- PA electricians at CTB for alarm testing.0053- test complete.0005-ISS doing testing at Term D.0243- test complete.
FIRE ALARMS	3/28/2014 13:58	3/28/2014 11:23	3/28/2014 11:23	Minerva Colon	0800 hrs. - CHRP conducting testing of fire alarms at hangars 1 3 5 and bldg. 30.1400 hrs. - CHRP advise testing complete.
FIRE ALARMS	3/29/2014 17:19	3/29/2014 17:13	3/29/2014 17:13	Minerva Colon	1346 hrs. - Fire alarms activated - CTB West SD CTB Am Eagle Gr Fl Gate D2. PAPD 1079 and CHRP notified.1349 hrs. - OCC issuing fire alarm investigation announcement.1352 hrs. - Negative condition found. PAPD securing. 1079 reset alarms and CHRP will reset ventilation.
FIRE ALARMS	3/30/2014 11:17	3/30/2014 9:13	3/30/2014 9:13	Minerva Colon	0742 hrs. - Fire alarm activated - Hgr 4 ACME Pull station Hgr 4 fire alarm Deluge valve #6. CHRP and 1079 notified. 0744 hrs. - Hgr. 4 fire watch (Cystal) advises negative condition. PAPD CHRP and 1079 advised.1004 hrs. - Fire alarm activated - Hgr. 4 Deluge valve #5 water flow. 1006 hrs. - Hgr. 4 fire watch advises negative condition.1007 hrs. - Fire watch reports negative condition.1023 hrs. - Hgr. 4 fire alarm activated - Chataqua Air Entrance Pull Stat. 1027 hrs. - Fire watch reports negative condition.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	3/30/2014 9:55	3/30/2014 9:20	3/30/2014 9:20	Minerva Colon	0855 hrs. - Fire alarm activated - parking lot 2 4th flr stair #10. PAPD 1079 and CHRP notified.0915 hrs. - 72 advises negative condition. PAPD CHRP and 1079 securing and will reset station.
FIRE ALARMS	3/31/2014 5:19	3/30/2014 23:32	3/30/2014 23:33	Joe Carney	2330- report of Chataqua pull station fire alarm.2359- originally PAPD advised area secure.0300- PAPD called back alarm on board still.1079 advised. Will advise R. Eng.
FIRE ALARMS	3/31/2014 14:14	3/31/2014 14:12	3/31/2014 14:12	Gregory Darden	1231 hrs. - Cupola advises Communication loss hangars 2 and 4.
FIRE ALARMS	3/31/2014 21:57	3/31/2014 16:12	3/31/2014 15:43	Rosemary Millan	1543L Fire alarms activated for:CTB WW fire alarm 1st and 2nd floorCTB room 3636ACooling towerCTB west alarm CTB east alarmHgr 4 Deluge Valve # 5 water flowHgr 4 Acme pull stationHgr 4 fire alarm Deluge # 1 water flowPAPD 71 1079 CHRP notified and responded. PA ops CC sent advisory audio/visual announcements.1550L CHRP Murphy advises negative condition; cause of activation was fire sprinkler "charged itself".PAPD notified. Fire report being filed by PO Peress.1555L PA Ops CC sent out closing audio/visual announcement.PA 1079 resetting fire boards.PA CHRP resetting fans.1625L Fire boards and fans reset.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	3/31/2014 21:53	3/31/2014 20:39	3/31/2014 20:39	Robert Duggins	1958 Fire Alarms activated for:CTB WW fire alarm 1st and 2nd floorCTB room 3636ACooling towerCTB west alarm CTB east alarm2000l 71 1079 CHRP notified and responding PA ops CC sent advisory audio/visual announcements.2000 CHRP checking deluge system tripped and now draining.2005 PAPD/71 on scene2006 PA ops CC sent advisory audio/visual announcements2015 1079 Reset Fire panel and fans reset also fire watch is posted at the cooling tower2019 PA Ops CC sent out closing audio/visual announcement.2100L same fire alarm activated. Same responding units; see ops CC fire alarm entry 2039L.2100L Allied Barton fire watch guard posted at cooling tower; requested by CHRP.CHRP Murphy advises the fire sprinkler had been reset by the sprinkler fitter but it tripped again. The affected valve has been drained. Fire watch requested.1079 reset fire board at 3636A and PA Ops.Fire watch is posted ufn.
FIRE ALARMS	4/1/2014 11:36	4/1/2014 10:23	4/1/2014 10:23	Gregory Darden	0730L - Received a Cooling Tower Panel Alarm in the CTB. CHRP and E shop notified.0731L - CC issued audio announcement. 0732L - CHRP advised alarm activated in error. Electric Shop resetting the fire alarm system. CHRP resetting ventilation system. OCC issued final audio announcement.
FIRE ALARMS	4/3/2014 9:04	4/3/2014 9:02	4/3/2014 9:02	Gregory Darden	0715L - Delta building Maintenance ISS advises Terminal C fire alarms on bypass for construction. Will advise when they are back online.
FIRE ALARMS	4/3/2014 23:14	4/3/2014 22:39	4/3/2014 21:10	Rosemary Millan	2110L CTB west Fire alarm activated. Manual pull station gate C3107971 PAPD CHRP responded. ASG also responded.PA Ops CC sent out audio/visual announcements.Pull stations in C gate and concourse inspected; no pulled station observed.CHRP secured.2230L 1079 advises they cannot reset the fire board at this time; concourse being inspected again for pull station; negative fire condition.PA Ops CC sent out closing announcements.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	4/4/2014 2:49	4/4/2014 0:43	4/3/2014 23:00	Rosemary Millan	2117L ISS at terminal C advises fire alarm panel is on bypass mode. 2300L ISS Ralph at terminal D advises they are conducting fire alarm testing; system is by pass mode. 04/04/140145L PAPD Fire marshall conducting fire alarm testing at Hgr 7 sky chef.0245L Fire testing completed at Hgr 7
FIRE ALARMS	4/5/2014 0:53	4/5/2014 0:51	4/5/2014 0:13	Rosemary Millan	0013L CHRP is testing fire alarms at bldg 23.
FIRE ALARMS	4/5/2014 19:58	4/5/2014 19:52	4/5/2014 19:52	Minerva Colon	1616 hrs. - Fire alarms activated. MS CTB 1 Flr United Bag Claim CTB East. CC issued audible announcement. PAPD 1079 and CHRP notified. 1624 hrs. - 71 with PAPD checking pull stations in arrrivals. 1631 hrs. - Pull station identified and 1079 in process of resetting. 1639 hrs. - Fire alarms reset and CHRP restoring ventilation.
FIRE ALARMS	4/7/2014 13:54	4/7/2014 13:50	4/7/2014 7:10	Robert Feury	Delta/USAir 12345 screening alarms testing by PAPD. 0720: ISS conducting fire alarm testing at Terminal C.
FIRE ALARMS	4/8/2014 5:34	4/7/2014 23:51	4/7/2014 23:51	Joe Carney	2345- Term C doing alarm testing. System in by-pass. PAPD advised.Will proceed till 0500.0430- Testing complete.
FIRE ALARMS	4/8/2014 21:47	4/8/2014 10:55	4/8/2014 10:55	Gregory Darden	1030L- ISS advised that they will be testing the Fire Alarm system in Terminal D for 2 hours. ISS will notify Ops when they have completed.
FIRE ALARMS	4/8/2014 10:57	4/8/2014 10:56	4/8/2014 10:56	Gregory Darden	1030L - PA George advises that they will testing the fire alarms in Hangar 7.
FIRE ALARMS	4/8/2014 21:48	4/8/2014 21:47	4/8/2014 21:47	Minerva Colon	1030L- ISS advised that they will be testing the Fire Alarm system in Terminal D for 2 hours. ISS will notify Ops when they have completed. 1450 hrs. - Delta A/L - ISS - advises fire alarms are B/I/S.
FIRE ALARMS	4/9/2014 0:28	4/9/2014 0:27	4/9/2014 0:27	Joe Carney	2315- ISS-Roger advises that F/A system will be in by-pass until 0400 for sprinkler work at Term D.
FIRE ALARMS	4/9/2014 15:07	4/9/2014 7:02	4/9/2014 7:02	Robert Feury	ISS at Terminal C is conducting fire alarm checks. They will notify when completed.
FIRE ALARMS	4/9/2014 15:08	4/9/2014 15:07	4/9/2014 15:07	Minerva Colon	ISS at Terminal C is conducting fire alarm checks. They will notify when completed. 1440 hrs. - Delta Maintenance - ISS - advises terminal C fire alarms B/I/S.
FIRE ALARMS	4/10/2014 11:11	4/10/2014 10:52	4/10/2014 8:00	Robert Feury	ISS conducting Fire Alarm testing Terminal C. Also notified by Terry of CHRP that they will be testing the Fire Alarms at the new pumping station at 0845.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	4/11/2014 21:13	4/11/2014 7:26	4/11/2014 6:35	Robert Feury	There will be Fire Alarm testing at Terminal C
FIRE ALARMS	4/11/2014 21:25	4/11/2014 21:11	4/11/2014 21:11	Gregory Darden	There will be Fire Alarm testing at Terminal C 1445L - Terminal fire panel back online.
FIRE ALARMS	4/11/2014 21:15	4/11/2014 21:13	4/11/2014 21:13	Gregory Darden	There will be Fire Alarm testing at Terminal C 1445L - Terminal C fire panel back online.
FIRE ALARMS	4/12/2014 3:39	4/12/2014 3:38	4/12/2014 3:38	Joe Carney	0135- PA Electric Shop doing alarm testing at H-7.0330- Test complete.
FIRE ALARMS	4/13/2014 11:31	4/13/2014 11:29	4/13/2014 11:29	Minerva Colon	1121 hrs. - Delta Bldg. Mtce. - ISS - advises Terminal C fire alarm panel is off line for testing/repair.
FIRE ALARMS	4/14/2014 13:25	4/14/2014 10:47	4/14/2014 10:47	Robert Feury	1039: Fuel Farm: Elvio from Allied Aviation testing their fire suppresion system. He will advise when complete. 1230: Testing complete.
FIRE ALARMS	4/15/2014 9:02	4/15/2014 9:01	4/15/2014 8:08	Robert Feury	Fire Alarm system in Fan Room 11 is in bypass because Maintenance is welding in the room.
FIRE ALARMS	4/15/2014 9:04	4/15/2014 9:03	4/15/2014 8:35	Robert Feury	ISS advises Terminal C fire alarms are in bypass.
FIRE ALARMS	4/15/2014 9:07	4/15/2014 9:04	4/15/2014 8:39	Robert Feury	Terry (CHRP) advises fire alarm testing in Buildings 84 and 39.
FIRE ALARMS	4/15/2014 13:41	4/15/2014 13:32	4/15/2014 13:32	Robert Feury	At 1230 CC reports fire alarms in the C and D connectors went off. At 1236 ISS advises that a contractor is working on the system. 1331: Finished with Fire alarm testing Terminal C. 1340: Finished fire alarm testing at CTB.
FIRE ALARMS	4/15/2014 17:44	4/15/2014 17:43	4/15/2014 17:43	Joe Carney	1730- The fire alarm system that was in bypass is back o line per Electric Shop.
FIRE ALARMS	4/16/2014 5:59	4/16/2014 5:54	4/16/2014 5:54	Gregory Darden	0545L - B5 jet bridge Duct detector fire alarm. CC sent out Fire alarm announcement. 71 and PAPD responded. 1079 notified. 0550L - B5 jet bridge inspected by 71 and PAPD. Negative condition. Fire alarm announcement cancelled and 1079 reset the alarm.
FIRE ALARMS	4/16/2014 15:12	4/16/2014 15:08	4/16/2014 14:57	Rosemary Millan	1457L Deluge water flow alarm activated at CTB garage lot 2 stairwell # 14. 71 responded with CHRP. PAPD72 and 1079 notified. 1500L Negative water flow condition observed in stairwell. CHRP is providing reset and they will be inspecting the sprinklers systems.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	4/17/2014 0:58	4/17/2014 0:43	4/17/2014 0:43	Gregory Darden	2210L - 71 received notice from Allied Barton fire watch that the Hangar 5 fire alarms are going off. The alarms do not show up on the fire alarm monitor in ops.2215L - 71 responded
FIRE ALARMS	4/17/2014 10:36	4/17/2014 8:56	4/17/2014 8:56	Joe Carney	Lot 2 stairway 6 rear of level 2 alarming.Same place and time as yesterday.Ray Eng advised.----------0900-Lot alarm testing for Lot 2.1030- testing concluded.
FIRE ALARMS	4/17/2014 13:13	4/17/2014 9:00	4/17/2014 9:00	Joe Carney	0900- ISS doing alarm testing at Term C. System in by-pass.1300- Lou from US Air called saying the alarms at Term C have not stopped since 900.Call to ISS. They are having technical issues. Cannot shut off alarms.Asked to speak with manager.1308- Lou from ISS called. Alarm shut off.
FIRE ALARMS	4/17/2014 13:20	4/17/2014 13:20	4/17/2014 13:20	Joe Carney	1310- Gate Gourmet in alarm testing.
FIRE ALARMS	4/18/2014 12:41	4/18/2014 2:44	4/18/2014 2:44	Gregory Darden	2225L - ISS asvised that Terminal D Fire Alarms will be in bypass mode.
FIRE ALARMS	4/18/2014 12:42	4/18/2014 12:41	4/18/2014 12:41	Minerva Colon	2225L - ISS asvised that Terminal D Fire Alarms will be in bypass mode. 0648 hrs. - Delta Bldg. Mtce. (ISS) advises fire alarm B/I/S.
FIRE ALARMS	4/18/2014 13:24	4/18/2014 13:21	4/18/2014 13:21	Minerva Colon	0730 hrs. - Electric shop advises will be conducting fire alarm testing hangar 11. 0838 hrs. - Testing complete. Will conduct testing hangar 7. 0949 hrs. - Hangar 7 testing complete. Will conduct cooling tower testing. 1030 hrs. - Electric shop advises cooling tower testing is complete.
FIRE ALARMS	4/18/2014 13:26	4/18/2014 13:24	4/18/2014 13:24	Minerva Colon	0835 hrs. - FAA advises will conduct fire alarm testing @ ATCT. 0909 hrs. - Testing complete.
FIRE ALARMS	4/19/2014 5:28	4/19/2014 4:11	4/19/2014 4:11	Corey Farrell	0359 - Fire alarm monitor had a pop up box stating 24 hour trouble resound for node 38. Contacted Electric Shop and inquired if it had meant anything. They told me they were unfamiliar with it and told me to silence it by clicking the pop up box.
FIRE ALARMS	4/20/2014 5:08	4/20/2014 5:06	4/20/2014 5:07	Joe Carney	0312- Alarm for Term D.0313- ISS called to request status.0320- Manual Pull station pulled- unknown.System reset.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	4/21/2014 15:16	4/21/2014 12:26	4/21/2014 12:26	Minerva Colon	0808 hrs. - Delta Building Maintenance - ISS - advises fire alarm sprinkler testing will be conducted in terminals C and D. PAPD notified.
FIRE ALARMS	4/21/2014 15:17	4/21/2014 15:16	4/21/2014 15:16	Robert Feury	0808 hrs. - Delta Building Maintenance - ISS - advises fire alarm sprinkler testing will be conducted in terminals C and D. PAPD notified. 1515 - Fire Alarm Testing complete.
FIRE ALARMS	4/22/2014 12:33	4/22/2014 12:32	4/22/2014 12:32	Minerva Colon	0700 hrs. - Delta Building Maintenance - ISS - advises Terminal C fire alarms off line for work.
FIRE ALARMS	4/23/2014 2:07	4/23/2014 2:06	4/23/2014 0:22	Rosemary Millan	0022L High pressure pump station building alarm activated at 1st floor pump # 1 running. CHRP notified and advises they are aware and are resetting the system. PAPD notified.
FIRE ALARMS	4/23/2014 12:50	4/23/2014 11:26	4/23/2014 11:26	Minerva Colon	0830 hrs. - CHRP advise they will be conducting fire alarm testing terminal C and Bldg. 99. 1215 hrs. - Testing complete.
FIRE ALARMS	4/23/2014 12:52	4/23/2014 11:26	4/23/2014 11:26	Minerva Colon	0929 hrs. - Electric shop advises they will be working on fire alarm system at parking lot 2.
FIRE ALARMS	4/23/2014 14:40	4/23/2014 14:38	4/23/2014 14:38	Minerva Colon	0720 hrs. - Delta Building Maintenance - ISS - advises terminal C fire alarms in bypass. 1421 hrs. - ISS advises fire alarms on line.
FIRE ALARMS	4/24/2014 5:14	4/24/2014 2:27	4/24/2014 0:44	Rosemary Millan	0044L PAPD testing fire alarms at terminal D 0321L PAPD Fire marshall completed fire alarm testing.
FIRE ALARMS	4/24/2014 11:23	4/24/2014 11:22	4/24/2014 11:22	Gregory Darden	0618L - ISS advised that Terminal C Fire Panel in bypass.0830L - ISS advised that Terminal D Fire Panel in bypass.
FIRE ALARMS	4/24/2014 11:28	4/24/2014 11:25	4/24/2014 11:25	Gregory Darden	0810L - CHRP conducting Fire Alarm testing for the West zone.
FIRE ALARMS	4/24/2014 15:18	4/24/2014 15:16	4/24/2014 15:16	Joe Carney	1424- Term D fire alarm test complete.
FIRE ALARMS	4/24/2014 18:23	4/24/2014 16:21	4/24/2014 16:21	Joe Carney	1606- PA Electric advised that they will conduct alarm testing in Lot 2.1800- Test complete.
FIRE ALARMS	4/25/2014 13:17	4/25/2014 13:16	4/25/2014 13:16	Gregory Darden	0740L - ISS conducting Terminal C Fire Alarm testing. 0850L - ISS conducting Terminal D Fire Alarm testing.
FIRE ALARMS	4/25/2014 13:19	4/25/2014 13:18	4/25/2014 13:18	Gregory Darden	0750L - CHRP conducting fire alarm testing in CTB.1314L - CHRP completed fire alarm testing in CTB.
FIRE ALARMS	4/25/2014 14:03	4/25/2014 14:02	4/25/2014 14:02	Joe Carney	1400- Alarm test at ATCT per Will.
FIRE ALARMS	4/25/2014 20:22	4/25/2014 20:18	4/25/2014 20:18	Joe Carney	1500- ISS advises that alarm testing complete at Term C and D.
FIRE ALARMS	4/26/2014 4:31	4/26/2014 2:16	4/26/2014 0:14	Rosemary Millan	PA Electric George advises fire alarm testing being conducted at hgr 7. 0245L Testing completed.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	4/26/2014 20:44	4/26/2014 20:43	4/26/2014 20:43	Joe Carney	21015- CTB fire alarm.False alarm reset by Electric Shop.Announcements made.
FIRE ALARMS	4/27/2014 17:34	4/27/2014 17:08	4/27/2014 17:08	Minerva Colon	1402 hrs. - Fire alarm activated - SD CTB basement; Pretzel; CTB E. PAPD 1079 and CHRP notified. 1404 hrs. - 1st audio announcement issued. 1410 hrs. - Negative condition found. 1079 resetting alarms. 1411 hrs. - Investigation complete announcement issued.
FIRE ALARMS	4/28/2014 6:57	4/28/2014 6:32	4/28/2014 6:32	Gregory Darden	0625L - ISS conducting fire alarm testing in Terminal C. Alarms in bypass mode.
FIRE ALARMS	4/28/2014 8:45	4/28/2014 8:44	4/28/2014 8:44	Gregory Darden	0745L - CHRP conducting Fire Alarm testing in the CTB. PAPD advised. CHRP will advise when the tested has completed.
FIRE ALARMS	4/29/2014 4:08	4/28/2014 23:19	4/28/2014 21:58	Rosemary Millan	2158L ISS advises they are working on fire system and have the system on bypass mode. 0407L ISS advises fire system is back on line.
FIRE ALARMS	4/29/2014 6:12	4/29/2014 6:11	4/29/2014 6:11	Gregory Darden	0610L - ISS is doing sprinkler work at Terminal C. Fire Alarm system is in bypass mode.
FIRE ALARMS	4/29/2014 8:41	4/29/2014 8:39	4/29/2014 8:39	Gregory Darden	0730L - CHRP is doing fire alarm testing at buildings 85 1 3 5 5A and 5B.
FIRE ALARMS	4/29/2014 11:19	4/29/2014 11:17	4/29/2014 11:17	Gregory Darden	0930L - Fire alarm testing being conducted at the Parking Lot 2. 72 advised.
FIRE ALARMS	4/30/2014 13:51	4/30/2014 11:19	4/30/2014 11:19	Gregory Darden	0740L - CHRP conducting Fire Alarm Testing conducted at Hangars 24 MAT Building 85 until 12 noon. PAPD advised.1230L - Testing complete.
FIRE ALARMS	4/30/2014 20:45	4/30/2014 11:27	4/30/2014 11:27	Gregory Darden	0735L - ISS will be conducting Fire Alarm testing in Terminals C and D. PAPD advised.
FIRE ALARMS	4/30/2014 20:46	4/30/2014 20:45	4/30/2014 20:45	Robert Feury	0735L - ISS will be conducting Fire Alarm testing in Terminals C and D. PAPD advised. 1415: ISS advises Fire Panel on line Concourse C.
FIRE ALARMS	5/1/2014 9:00	5/1/2014 8:59	5/1/2014 8:59	Gregory Darden	0742L - CHRP testing fire alarms at the new pump station.
FIRE ALARMS	5/1/2014 9:01	5/1/2014 9:00	5/1/2014 9:00	Gregory Darden	0750L - ISS put fire alarm system at Terminal C and D in bypass mode.
FIRE ALARMS	5/1/2014 11:20	5/1/2014 11:19	5/1/2014 11:19	Gregory Darden	0650L - Fire alarm in lot 2 2nd level stairwell 11. CHRP advised.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	5/1/2014 20:30	5/1/2014 16:05	5/1/2014 14:39	Robert Feury	Responded to Fire Alarm at CTB first floor central food court at Fig's Restaurant. At 1442 notified 71 1079 CHRP Police. 1448: Negative conditions reported.
FIRE ALARMS	5/2/2014 2:53	5/2/2014 2:52	5/2/2014 2:52	Joe Carney	2215- Fire Alarm testing at Term C and D per Lovell.
FIRE ALARMS	5/2/2014 13:18	5/2/2014 13:18	5/2/2014 13:18	Gregory Darden	0630L - ISS will have Terminal C fire alarms in by pass mode.
FIRE ALARMS	5/3/2014 3:20	5/3/2014 3:20	5/3/2014 3:20	Joe Carney	2230- Lot 2 fire alarm testing.0300 test complete.
FIRE ALARMS	5/5/2014 0:50	5/5/2014 0:48	5/5/2014 0:48	Robert Feury	Fire alarm at base of old control tower. Electric shop contacted. First and last announcements were made. Alarm was re-set by electricians. CHRP was contacted to turn fans back on.
FIRE ALARMS	5/5/2014 18:20	5/5/2014 17:22	5/5/2014 17:22	Minerva Colon	1514 hrs. - Delta Bldg. Mtce. - ISS - advises fire alarm testing complete in terminal C.
FIRE ALARMS	5/5/2014 23:37	5/5/2014 23:37	5/5/2014 23:37	Robert Feury	ISS called to inform they will be conducting fire alarm tests in Terminal C.
FIRE ALARMS	5/7/2014 8:18	5/7/2014 8:18	5/7/2014 8:18	ERIC ESSLING	0615L - Delta Mx ISS working on fire alarms Terminal C bypass until 1400L
FIRE ALARMS	5/7/2014 23:20	5/7/2014 23:19	5/7/2014 23:19	Robert Feury	ISS calls the fire panel will be down in Terminal C until 0500.
FIRE ALARMS	5/8/2014 13:55	5/8/2014 13:54	5/8/2014 13:54	Minerva Colon	1024 hrs. - FAA conducting fire alarm tests in the ATCT. 1047 hrs. - FAA advise fire alarm testing completed.
FIRE ALARMS	5/8/2014 14:00	5/8/2014 13:56	5/8/2014 13:56	Minerva Colon	0803 hrs. - CHRP advise they will be with AFA conducting fire alarm testing @ hangar 11. 0840 hrs. - Testing complete at hangar 11 and testing will be conducted at hangar 7. 1004 hrs. - Testing complete at hangar 7 and testing will be conducted in cooling tower. 1030 hrs. - Testing complete.
FIRE ALARMS	5/9/2014 5:30	5/9/2014 0:47	5/9/2014 0:47	Robert Feury	Fire Alarm testing in CTB starting at 0040. Announcements were broadcast throughout the terminal. 0101: Fire Alarm tests finished. 0237: Heating Plant conducts silent fire alarm tests. 0257: Heating Plant tests complete.
FIRE ALARMS	5/9/2014 11:23	5/9/2014 11:18	5/9/2014 11:18	Minerva Colon	0805 hrs. - Electric shop (Eng) advises they are conducting fire alarm testing in parking lot 2. 0858 hrs. - Testing complete.
FIRE ALARMS	5/9/2014 19:41	5/9/2014 17:42	5/9/2014 17:42	Minerva Colon	0609 hrs. - Delta Bldg. Mtce. - ISS - advise will conduct fire alarm testing terminal C. 1356 hrs. - Testing complete and system on line.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	5/10/2014 22:08	5/10/2014 22:06	5/10/2014 22:06	Minerva Colon	2112 hrs. - Fire Alarms activated. Board indicates CTB west ual bag. CC issued first announcement. 1079 notified. 2114 hrs. - CC advised negative condition. 1079 notified for reset of fire alarms. CC issued final announcement.
FIRE ALARMS	5/10/2014 22:14	5/10/2014 22:10	5/10/2014 22:10	Minerva Colon	2005 hrs. - Fire alarms activated - US Apron SD Comm Room. CTB West Fire Alarm. PAPD and 1079 notified. CC issued first announcement. 72 and 78 responding (71 with tech in D164). 2018 hrs. - Negative condition. CC issued final announcement and 1079 reset alarms.
FIRE ALARMS	5/12/2014 8:02	5/12/2014 7:59	5/12/2014 7:59	Robert Feury	0705: ISS calls they will be testing the fire alarm system at Terminal C until 1400. Alarm is on bypass.
FIRE ALARMS	5/12/2014 12:42	5/12/2014 8:02	5/12/2014 8:02	Robert Feury	0733: AFA will be testing the fire alarms with American Airlines until 1300.
FIRE ALARMS	5/12/2014 9:07	5/12/2014 8:55	5/12/2014 8:30	Rosemary Millan	0830L TSD working on fire alarm connections for hgr4 and terminal D. Allied Barton guard providing escort.
FIRE ALARMS	5/12/2014 12:45	5/12/2014 12:44	5/12/2014 12:44	Robert Feury	0855: ISS calls Terminal A fire alarms will be in bypass until 1500.
FIRE ALARMS	5/13/2014 3:40	5/13/2014 3:37	5/13/2014 3:37	Gregory Darden	2228L - ISS is testing the fire alarms at Terminal C.
FIRE ALARMS	5/13/2014 10:52	5/13/2014 10:21	5/13/2014 10:21	Robert Feury	0810: ISS conducting fire alarm testing at Terminal C. System taken off line.
FIRE ALARMS	5/13/2014 13:34	5/13/2014 10:22	5/13/2014 10:22	Robert Feury	1000: Tim from ISS advises Terminal A Fire alarms on bypass. PAPD notified. 1315: Tests complete. Back on line.
FIRE ALARMS	5/13/2014 10:54	5/13/2014 10:53	5/13/2014 10:53	Robert Feury	0932: George Weekly from PA Electric advises that he will be working on the Fire Alarm System in Hangar 7. System will be in bypass mode.
FIRE ALARMS	5/14/2014 5:46	5/14/2014 2:31	5/14/2014 2:31	Gregory Darden	2150L - ISS fire alarms at Terminal D.
FIRE ALARMS	5/14/2014 7:00	5/14/2014 7:00	5/14/2014 7:00	Robert Feury	0655: Fire alarm panel at Terminal D on line.
FIRE ALARMS	5/14/2014 20:00	5/14/2014 7:00	5/14/2014 7:00	Robert Feury	0655: Fire alarm at Terminal C off line until 1400.
FIRE ALARMS	5/14/2014 11:46	5/14/2014 10:12	5/14/2014 10:12	Robert Feury	Fire Alarm testing Lot 2 until 1400
FIRE ALARMS	5/14/2014 20:01	5/14/2014 20:00	5/14/2014 20:00	Gregory Darden	0655: Fire alarm at Terminal C off line until 1400.1700L - Terminal C fire alarms back online.
FIRE ALARMS	5/14/2014 22:55	5/14/2014 22:35	5/14/2014 22:35	Gregory Darden	2210L - ISS is testing fire alarms in Terminal C. Alarms are in bypass.
FIRE ALARMS	5/15/2014 20:53	5/15/2014 13:32	5/15/2014 13:32	Robert Feury	AFA testing smoke alarms in CTB until 1400. CHRP testing alarms in Building 23 at 0806.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	5/15/2014 20:54	5/15/2014 20:53	5/15/2014 20:53	Rosemary Millan	AFA testing smoke alarms in CTB until 1400. CHRP testing alarms in Building 23 at 0806. 1352L CTB fire alarm testing completed.
FIRE ALARMS	5/16/2014 18:33	5/16/2014 17:42	5/16/2014 17:42	Gregory Darden	1740L - PAPD fire alarm panel in Building 137 went completely blank. The Electric Shop has been notified and will respond to the location. PAPD advised.1800L - The Electricians responded. They were unable to reset the monitor. The computer help desk has been called and a message has been left.
FIRE ALARMS	5/17/2014 13:13	5/17/2014 12:00	5/17/2014 12:00	Max Medina	1155L-Tony Vero (Hanger 7) informed OPS that there was a Fire Pump Station Alarm ringing behind Bldg. 28. 71 (GD) 78 (WB) CHRP (Ponzo) and PAPD advised. 71 (GD) 78 (WB) CHRP and PAPD responding. PAPD Desk informed OPS that they were not getting the Fire Pump Station Alarm on their alarm board/panel. 71 (GD) and Electric Sop advised. Electric Shop responding. 1308L-Mike (Electric Shop) testing fire alarms at Hangar 11. 71 (GD) advised.
FIRE ALARMS	5/17/2014 13:34	5/17/2014 13:22	5/17/2014 13:22	Gregory Darden	1225L - 78 (WB) advised that a fan exhaust alarm is coming from the pump house adjacent to Hangar 11. PAPD CHRP 78 & 71 responded. No smoke condition. CHRP reset alarm. Cause of alarm unknown.
FIRE ALARMS	5/18/2014 9:03	5/18/2014 9:02	5/18/2014 9:02	Gregory Darden	0800L - PAPD reports Fire Alarm Panel OTS at Building 137. 71 reported outage to Electric Shop.
FIRE ALARMS	5/19/2014 1:35	5/18/2014 21:36	5/18/2014 21:36	Gregory Darden	2130L - Fire Alarm Monitor shows MS 1FL Cabin SVC\STor\Catering at Delta Terminal C Fire Alarm Delta Terminal D Fire Alarm 2132L - ISS was notified. Tony from ISS informed that the shift managaer will investigate the alarm.PAPD notifed.
FIRE ALARMS	5/19/2014 1:37	5/19/2014 1:35	5/19/2014 1:35	Robert Feury	2130L - Fire Alarm Monitor shows MS 1FL Cabin SVC\STor\Catering at Delta Terminal C Fire Alarm Delta Terminal D Fire Alarm 2132L - ISS was notified. Tony from ISS informed that the shift manager will investigate the alarm. PAPD notified. 2145 - Notified that these were false alarms.
FIRE ALARMS	5/19/2014 7:04	5/19/2014 7:03	5/19/2014 7:03	Joe Carney	Term C will be in bypass per Roger at ISS till 1500.
FIRE ALARMS	5/19/2014 9:59	5/19/2014 9:57	5/19/2014 9:57	Joe Carney	0927- Electric Shop working on old post office alarms.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	5/19/2014 16:35	5/19/2014 16:34	5/19/2014 16:34	Gregory Darden	1635L - Electric Shop is conducting Fire Alarm testing the CTB.
FIRE ALARMS	5/19/2014 21:44	5/19/2014 21:28	5/19/2014 21:28	Gregory Darden	1740L Fire alarm in West Wing room 3636A. Electric and CHRP advised. Announcement sent out for alarm.1754L - Room 3636A room had negative condition. PAPD responded. Electricians responded and reset. Announcement sent out for false alarm.
FIRE ALARMS	5/20/2014 9:27	5/20/2014 9:26	5/20/2014 9:26	Joe Carney	0900- Sunny from DayCom working on alarm systems at Term C till 1400.
FIRE ALARMS	5/21/2014 15:44	5/20/2014 21:21	5/20/2014 21:21	Rosemary Millan	2003L Duct Detector fire alarm activated at FIGS inside concourse D. PAPD 1079 CHRP notified. 71 responded. PA Ops CC sent out advisory announcement.2005L 71 in concourse D observed slight odor of smoke. 71 spoke with FIGS shift manager Karim Askari who advised the motor for their exhaust hood was not working and the motor was removed earlier this morning by their repair contractor. Manager Karim advises that they had stopped cooking in the morning after the motor was removed from roof unit. Tonight one of the cleaners had turned on the grill to warm it up for heating causing the duct detector alarm to activate. PA Ops PAPD notified. PA Ops sent out closing fire alarm investigation completed announcement. 2008L Manager Karim advises he has notified FIGS morning cook not to come in until 0900L tomorrow as they will not be cooking hot foods until the exhaust motor is repaired. The repair work is expected to be done by tomorrow. 2105L 1079 briefed on matter and they are resetting the fire protection to area at concourse D FIGS.
FIRE ALARMS	5/21/2014 15:45	5/21/2014 8:21	5/21/2014 8:21	Joe Carney	0718- PA Electric shop doing alarm testing till end of day.
FIRE ALARMS	5/21/2014 8:24	5/21/2014 8:23	5/21/2014 8:23	Joe Carney	0822- Alarm testing at Term C by ISS.
FIRE ALARMS	5/21/2014 9:37	5/21/2014 9:36	5/21/2014 9:36	Joe Carney	DRILL- DRILL0900- CTB Evacuation Drill.0930- Drill concluded.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	5/21/2014 20:14	5/21/2014 15:44	5/21/2014 15:44	Rosemary Millan	concourse D. PAPD 1079 CHRP notified. 71 responded. PA Ops CC sent out advisory announcement.2005L 71 in concourse D observed slight odor of smoke. 71 spoke with FIGS shift manager Karim Askari who advised the motor for their exhaust hood was not working and the motor was removed earlier this morning by their repair contractor. Manager Karim advises that they had stopped cooking in the morning after the motor was removed from roof unit. Tonight one of the cleaners had turned on the grill to warm it up for heating causing the duct detector alarm to activate. PA Ops PAPD notified. PA Ops sent out closing fire alarm investigation completed announcement. 2008L Manager Karim advises he has notified FIGS morning cook not to come in until 0900L tomorrow as they will not be cooking hot foods until the exhaust motor is repaired. The repair work is expected to be done by tomorrow. 2105L 1079 briefed on matter and they are resetting the fire protection to area at concourse D FIGS.**********05/21/14 @ 1540L FIGS shift manager Karim advises repairs have been completed. Motor
FIRE ALARMS	5/21/2014 15:46	5/21/2014 15:45	5/21/2014 15:45	Rosemary Millan	0718- PA Electric shop doing alarm testing till end of day.1430L PA Terry advises all testing completed.
FIRE ALARMS	5/22/2014 4:02	5/22/2014 4:01	5/22/2014 4:01	Robert Feury	0125: Fire Alarm testing in Control Tower.0145: Fire Alarm testing complete.
FIRE ALARMS	5/23/2014 5:42	5/23/2014 5:42	5/23/2014 5:42	Robert Feury	Fire Alarm Testing in CTB.
FIRE ALARMS	5/23/2014 17:23	5/23/2014 7:48	5/23/2014 7:48	Joe Carney	0745- ISS reports system in bypass at Term D.0746- CHRP doing testing at B-23.
FIRE ALARMS	5/23/2014 17:21	5/23/2014 8:43	5/23/2014 8:43	Joe Carney	Ray Eng advises Old PO is off-line.
FIRE ALARMS	5/23/2014 12:28	5/23/2014 12:26	5/23/2014 12:26	Joe Carney	1225- Fire Alarms in Term C. Empire alarm set off due to toaster in kitchen.
FIRE ALARMS	5/23/2014 17:22	5/23/2014 17:21	5/23/2014 17:21	Rosemary Millan	Ray Eng advises Old PO is off-line.1345L R. Eng advises fire system back on line at old post office.
FIRE ALARMS	5/23/2014 17:23	5/23/2014 17:23	5/23/2014 17:23	Rosemary Millan	0745- ISS reports system in bypass at Term D.0746- CHRP doing testing at B-23.1440L ISS advises fire system at terminal d is back on line.
FIRE ALARMS	5/24/2014 10:17	5/24/2014 10:16	5/24/2014 10:16	Joe Carney	0930- False alarm at D4 concourse D.PA Electric reset.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	5/24/2014 19:52	5/24/2014 19:50	5/24/2014 19:50	Minerva Colon	1700 hrs. - Holt Construction advises building 28 fire alarms are back on line.
FIRE ALARMS	5/25/2014 5:20	5/25/2014 5:17	5/25/2014 5:17	Gregory Darden	0445L - Ops receiaved a fire alarm for United Airlines Elevator Duct Detector. The Electric Shop was notified. CHRP advised. PAPD & 71(GD)responded to United Airlines elevator. No smell of smoke. No visible fire. Negative condition. Electricians reset alarm. CHRP reset fans.
FIRE ALARMS	5/25/2014 9:21	5/25/2014 9:18	5/25/2014 9:18	Gregory Darden	0815L - Fire Alarm strobes flashing throughout the CTB. Electric Shop advised. Announcement sent.0820L - Fire Alarm reset. Announcement sent.
FIRE ALARMS	5/25/2014 9:25	5/25/2014 9:21	5/25/2014 9:21	Gregory Darden	0815L - Allied Barton TS Rosa advised that the Hangar 5A fire watch has alarm in Hangar 5A. 0820L - Allied Barton advised that the Hangar 5A alarm reset.
FIRE ALARMS	5/26/2014 18:47	5/26/2014 18:09	5/26/2014 18:09	Joe Carney	1809- Fire Alarm at Term C Empire restaurant.False alarm.
FIRE ALARMS	5/27/2014 9:25	5/27/2014 9:22	5/27/2014 9:22	Joe Carney	0711- Term D fire alarm.0727- Tug in bag room set off alarm.0706- H-2/4 in bypass.0712- Old Post Office in bypass.
FIRE ALARMS	5/27/2014 13:18	5/27/2014 13:15	5/27/2014 13:15	Joe Carney	1110- Term D Bldg 99 MAT alarm testing by CHRP.1315- test complete.
FIRE ALARMS	5/27/2014 20:40	5/27/2014 20:39	5/27/2014 20:39	Robert Feury	Electrician George working on fire alarms for parking lot 2.
FIRE ALARMS	5/29/2014 21:06	5/29/2014 13:15	5/29/2014 13:15	Gregory Darden	0735L - Electric Shop has the Old Post Office building #85 in bypass.0812L - New tower is in bypass (FAA)0832L - FAA completed testing of new tower.0834L - Hertz Avis Fuel Farm Gate Gourmet in bypass from CHRP.1025L - Terminal D in bypass from ISS.
FIRE ALARMS	5/29/2014 21:07	5/29/2014 21:06	5/29/2014 21:06	Robert Feury	0735L - Electric Shop has the Old Post Office building #85 in bypass.0812L - New tower is in bypass (FAA)0832L - FAA completed testing of new tower.0834L - Hertz Avis Fuel Farm Gate Gourmet in bypass from CHRP.1025L - Terminal D in bypass from ISS.1745 - Terminal C and D Fire Alarms back online. Electric Shop has old post office Fire Alarm System back online.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	5/30/2014 3:58	5/30/2014 1:09	5/29/2014 23:13	Rosemary Millan	2313L ISS Roger at terminal D advises fire alarm testing being conducted until 0400L. The PA Fire Marshall A. Baichic is on scene for testing.0100L ISS Wilbur at terminal D advises they will be conducting fire alarm testing.0307L Testing at Terminal D completed.
FIRE ALARMS	5/30/2014 13:50	5/30/2014 13:26	5/30/2014 13:26	Gregory Darden	1300L - Fire alarm set off at Hangar 7 for a boiler room alarm. Contacted Ray Eng of the Electric Shop. Maintenance was conducting work in the Hangar. The Hangar was evacuated due to the alarm. Electric Shop responded as well as PAPD. The alarm was deemed a false alarm. It was reset by the Electric Shop.
FIRE ALARMS	5/30/2014 23:27	5/30/2014 23:14	5/30/2014 23:14	Rosemary Millan	2314L ISS advises at Terminal C the system is in bypass mode for testing.
FIRE ALARMS	5/31/2014 5:38	5/31/2014 0:44	5/31/2014 0:32	Rosemary Millan	0032L PA Electrical are testing CTB fire alarms.0318L Fire alarm testing completed.
FIRE ALARMS	6/3/2014 1:22	6/3/2014 1:20	6/2/2014 23:07	Rosemary Millan	2307L ISS Corrigan advises they are testing fire alarms at terminal C
FIRE ALARMS	6/3/2014 16:10	6/3/2014 15:42	6/3/2014 15:42	Gregory Darden	1428L - Ops received a Hangar 7 water flow fire alarm. Hangar 7 was evacuated. CHRP The Electric Shop and 71 responded to the location.1448L - An investigation discovered it to be a false alarm. Personnel were allowed back into the Hangar 7. CHRP reset the fans and E shop reset the Fire Panel.
FIRE ALARMS	6/4/2014 5:51	6/4/2014 2:09	6/4/2014 2:09	Joe Carney	2335- ISS conducting alarm testing at Term C.0548- Complete.
FIRE ALARMS	6/5/2014 10:00	6/5/2014 9:56	6/5/2014 9:56	Robert Feury	0850 - Electrician Ray Eng testing duress alarms in Lot 2. Testing complete at 0923.0936 - FAA Carmelo testing fire alarm in Control Tower.Daycom Sunny testing Terminal C post station alarms. PAPD advised.Electrician Ray Eng welding in Hangar 7. Alarms taken off line.
FIRE ALARMS	6/6/2014 1:35	6/6/2014 1:32	6/6/2014 1:32	Joe Carney	0110- H5A has alarm sounding.78 investigated.Electric shop called.0115- System reset.
FIRE ALARMS	6/6/2014 3:57	6/6/2014 3:56	6/6/2014 3:56	Joe Carney	1520- False alarm at UAL elevator.PA Electric responded.Went to Tel Closet 117 and reset panel.
FIRE ALARMS	6/6/2014 7:51	6/6/2014 7:50	6/6/2014 7:50	Robert Feury	Heating Plant testing at Building 23 the new pump station.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	6/8/2014 11:07	6/8/2014 10:58	6/8/2014 10:06	Rosemary Millan	1006L CTB East water flow fire alarm room 319 activated.71 responding. PAPD CHRP 1079 Contracts MP notified elevators PE1 and PE2 have stopped working.1008L PA Operations CC sent out advisory Audio/Visual announcements.1010L 71 PAPD and CHRP inspecting 3rd floor fan rooms.Southwest fan room Jet Blue IT room and NY Telcom rooms also inspected.1015L Negative water flow condition observed in all rooms inspected. Previous leak outside NY Telcom room by fire board had small bucket full with water CHRP Tom disposed of water and placed bucket back under panel unit.1020L 1079 reset fire board. 1021L PA Ops notified negative water flow condition and final advisory announcement sent securing alarm. PAPD CHRP 71 Contracts MP securing. Elevators PE1 and PE2 returned to service.
FIRE ALARMS	6/9/2014 8:20	6/9/2014 8:09	6/9/2014 8:09	Gregory Darden	0810L - ISS Lovell advised that the Delta Fire Panel will be taken offline for repairs. Will advise when it is back online.
FIRE ALARMS	6/10/2014 9:42	6/10/2014 9:41	6/10/2014 9:41	Gregory Darden	0800L - ISS advises that Fire alarm system in Terminal D is in repair.
FIRE ALARMS	6/10/2014 17:55	6/10/2014 17:43	6/10/2014 17:43	Robert Feury	At 1556 noticed very loud fire-type alarm sounding in CTB arrivals level East end. Contacted Electricians Heating Plant PAPD. Alarm notifications were periodically broadcast throughout the terminal by CC. The alarm did not show up on alarm screens in CC or in Heating Plant. The alarms were silenced and cleared by electricians at 1640. Electricians advise cause to be a glitch and they will investigate further.
FIRE ALARMS	6/11/2014 5:53	6/11/2014 0:08	6/10/2014 21:51	Rosemary Millan	2151L Phil from Fire craft advises they are testing fire alarms at terminal C and will advise when testing is completed. 2330L Fire alarms received at Terminal D. PA Operations CC contacted Delta Terminal D ISS maintenance and was advised they were changing sprinklers at terminal D. ISS notified by CC importance of proper notifications to PA Operations when work is being done on fire suppression systems.
FIRE ALARMS	6/11/2014 19:38	6/11/2014 19:37	6/11/2014 19:37	Robert Feury	Fire alarm testing in Terminal D completed at 1448.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	6/12/2014 11:24	6/12/2014 7:37	6/12/2014 7:37	Gregory Darden	0737L - CHRP will be doing Fire Alarm testing at Building 23. The alarms system will be offline.0924L - CHRP Fire Alarm testing is complete at Building 23.
FIRE ALARMS	6/13/2014 13:46	6/13/2014 13:18	6/13/2014 13:18	Gregory Darden	1135L - Fire alarm ATA CTB Conveyor panel MCP35B alarm. Electric Shop called to respond.1145L - Electric shop responded and discovered that the power had been shut off at the conveyor belt causing the alarm to sound. It was discovered that Oxford turned the power on to the belt & that caused the alarm. Negative condition for fire.
FIRE ALARMS	6/14/2014 4:41	6/14/2014 4:39	6/14/2014 4:39	Gregory Darden	0145l - Electric shop testing the fire alarm system. PAPD advised.0300L - Electric Shop has completed Fire alarm system testing. PAPD advised.
FIRE ALARMS	6/16/2014 11:46	6/16/2014 11:42	6/16/2014 11:42	Robert Feury	0957: Fire alarm at Concourse D by D7. 71's and Electrician Ray Eng respond. Smoke detector #27 found to be the detector that sounded the alarm. Heating plant notified and turning all fans back on. Electricians will investigate further.
FIRE ALARMS	6/17/2014 13:19	6/17/2014 13:16	6/17/2014 12:15	Rosemary Millan	1215L High temp alarm activated for west end pump station. CHRP provided reset false alarm.1300L High temp alarm activated again for west end pump station. CHRP responding for reset.
FIRE ALARMS	6/18/2014 3:16	6/18/2014 3:16	6/18/2014 3:16	Gregory Darden	2300L - Fire alarm testing being conducted by ISS at Terminal C. System offline until completion.
FIRE ALARMS	6/18/2014 18:03	6/18/2014 16:57	6/18/2014 16:57	Joe Carney	1708- Building 23 test by Electric shop concluded.
FIRE ALARMS	6/19/2014 3:33	6/19/2014 3:32	6/19/2014 3:32	Gregory Darden	2337L - ISS is conducting fire alarm testing in Terminal C. The system is in bypass mode.0330L - ISS has completed testing. The system is back online.
FIRE ALARMS	6/19/2014 11:13	6/19/2014 8:55	6/19/2014 8:00	Rosemary Millan	0800L CHRP testing fire alarms at west end buildings rental cars old post office.0845L ISS at terminal C had fire suppression on bypass mode for testing.West End fire testing completed at 1038. Testing at C completed at 1038.
FIRE ALARMS	6/19/2014 23:18	6/19/2014 23:17	6/19/2014 23:17	Joe Carney	2120- ISS advises that Term C will be in by-pass.2317- Roger from ISS advises testing will commence.
FIRE ALARMS	6/20/2014 8:25	6/20/2014 7:42	6/20/2014 6:25	Rosemary Millan	0625L Fire alarm testing being conducted by FAA at ATCT0700L FAA testing completed.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	6/21/2014 4:02	6/20/2014 23:29	6/20/2014 23:29	Joe Carney	2325- Jurel from ISS putting system in by-pass for testing.0400- back on line.
FIRE ALARMS	6/22/2014 2:20	6/21/2014 23:06	6/21/2014 22:30	Rosemary Millan	2230L Fire alarm activated at Terminal C. Met with ISS supervisor Joel and he advises it is a false alarm someone possible bumped into a pull station. ISS and PAPD are looking for the actual pull station. ISS Joel advises they are currently upgrading their pull station lists and some of the numbers do not coincide making it difficult to locate actual station for this alarm.0015L Joel from ISS advises their fire board has been reset. They are working with issues of old fired board being tied into new fire board system.0110L CTB east PSR fire alarm activated audible and strobes.107971 PAPD responded.PA Ops CC sent out advisory announcements.0115L Inspection for 3rd floor areas show negative condition.0145L PA 1079 Supervisor Ray Eng advises system reset.0147L PA Ops CC sent out closing announcement.
FIRE ALARMS	6/23/2014 9:34	6/23/2014 9:33	6/23/2014 9:33	Joe Carney	0900- CTB alarm testing.
FIRE ALARMS	6/23/2014 17:54	6/23/2014 17:53	6/23/2014 17:53	Joe Carney	1702- Fire alarm at Cont bag room.1079 advised.No issue at bag room area.System reset.All announcements made.
FIRE ALARMS	6/24/2014 11:12	6/24/2014 11:11	6/24/2014 8:15	Robert Feury	Heating plant conducting fire alarm testing at Building 99 Delta Terminal D.
FIRE ALARMS	6/26/2014 9:54	6/26/2014 9:52	6/26/2014 9:52	Joe Carney	0811- CHRP testing alarms at Term C.
FIRE ALARMS	6/27/2014 0:31	6/27/2014 0:30	6/27/2014 0:30	Gregory Darden	0028L - ISS Terminal D fire alarms in bypass mode until 0300L.
FIRE ALARMS	6/27/2014 8:47	6/27/2014 8:11	6/27/2014 8:11	Joe Carney	Pete from CHRP doing alarm testing at H-2 and Bldg 84.
FIRE ALARMS	6/27/2014 13:21	6/27/2014 13:20	6/27/2014 13:20	Joe Carney	1255- Fire alarm in H-7North.Flight Safety tripped alarm by accident.R. Eng reset alarm.CHRP advised for a check if needed.
FIRE ALARMS	6/28/2014 0:35	6/27/2014 23:44	6/27/2014 23:44	Gregory Darden	2130l - ISS Terminal C alarms in bypass mode for testing.2340L - ISS Terminal C alarms back in service.
FIRE ALARMS	7/1/2014 7:37	7/1/2014 7:37	7/1/2014 7:37	Joe Carney	2204- ISS testing alarms at Term C.0730- ISS advises alarms restored to operation.
FIRE ALARMS	7/2/2014 4:36	7/2/2014 4:34	7/2/2014 4:34	Joe Carney	0400- Fire alarm in Tel-Com closet 117 by UAL baggage belt #2.False alarm as work by NJD produced dust which triggered alarm.Electric Shop and CHRP reset.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	7/3/2014 13:20	7/3/2014 12:23	7/3/2014 12:23	Gregory Darden	1111L - Received a PSR fire alarm 3rd floor east panel. Electricians and PAPD notified of the alarm. Alarm announcement has been sent.1115L -71 GD responded. Alarm audible and strobes visible on the 3rd floor only. Negative smoke or fire condition. Various offices evacuated due to loud noise. Additional alarm announcement has been sent.1125L - N. Kennedy called again to have someone responded. They are unable to pinpoint the problem with the alarm system. They are still working on the problem.1145L - Electricians reset the alarm. It was determined to be a power supply issue. No know cause. Panel reset.
FIRE ALARMS	7/3/2014 13:27	7/3/2014 13:26	7/3/2014 13:26	Gregory Darden	0853L - The FAA ATCT is conducting fire alarm testing.0915L - The fire alarm testing is complete.
FIRE ALARMS	7/5/2014 22:11	7/5/2014 19:34	7/5/2014 19:34	Joe Carney	1855- Responded to Hertz Lot with PAPD Electric Shop.Alarm at location was reset by Electricians.Could not find reason for alarm.There was a pull station at site with missing glass rod.Sending this note to Fire Marshall.Hertz staff had no idea what to do with alarm further they had no idea who to contact.Electric panel room had items stored that seem irregular ie paint cans cleaning supplies paper and cardboard.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	7/6/2014 16:00	7/5/2014 22:11	7/5/2014 22:11	Joe Carney	1855- Responded to Hertz Lot with PAPD Electric Shop.Alarm at location was reset by Electricians.Could not find reason for alarm.There was a pull station at site with missing glass rod.Sending this note to Fire Marshall.Hertz staff had no idea what to do with alarm further they had no idea who to contact.Electric panel room had items stored that seem irregular ie paint cans cleaning supplies paper and cardboard.--- ---------- 2055- 2nd alarm went with no reset. Julianne from Hertz had no info for Alarm repair or Electrician for repair.Contacted CHRP and Contracts to see if they had a number- no luck.Contacted Fire Marshall direct but did not have file with him.Contacted Hertz sister stores- no luck.Provided FIRE WATCH via Allied Barton starting at 2200 UFN. HERTZ clearly understood that they would be back billed for this service.Provided Fire watch to allow business to keep doors open.Alternative to close doors seemed improper with Hertz expecting numerous rental returns.Case # 14A7710

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	7/6/2014 11:41	7/6/2014 11:37	7/6/2014 11:37	Gregory Darden	at location was reset by Electricians.Could not find reason for alarm.There was a pull station at site with missing glass rod.Sending this note to Fire Marshall.Hertz staff had no idea what to do with alarm further they had no idea who to contact.Electric panel room had items stored that seem irregular ie paint cans cleaning supplies paper and cardboard.--- ---------- 2055- 2nd alarm went with no reset. Julianne from Hertz had no info for Alarm repair or Electrician for repair.Contacted CHRP and Contracts to see if they had a number- no luck.Contacted Fire Marshall direct but did not have file with him.Contacted Hertz sister stores- no luck.Provided FIRE WATCH via Allied Barton starting at 2200 UFN. HERTZ clearly understood that they would be back billed for this service.Provided Fire watch to allow business to keep doors open.Alternative to close doors seemed improper with Hertz expecting numerous rental returns.Case # 14A7710**********

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	7/6/2014 20:11	7/6/2014 16:00	7/6/2014 16:00	Joe Carney	at location was reset by Electricians.Could not find reason for alarm.There was a pull station at site with missing glass rod.Sending this note to Fire Marshall.Hertz staff had no idea what to do with alarm further they had no idea who to contact.Electric panel room had items stored that seem irregular ie paint cans cleaning supplies paper and cardboard.---------- 2055- 2nd alarm went with no reset. Julianne from Hertz had no info for Alarm repair or Electrician for repair.Contacted CHRP and Contracts to see if they had a number- no luck.Contacted Fire Marshall direct but did not have file with him.Contacted Hertz sister stores- no luck.Provided FIRE WATCH via Allied Barton starting at 2200 UFN. HERTZ clearly understood that they would be back billed for this service.Provided Fire watch to allow business to keep doors open.Alternative to close doors seemed improper with Hertz expecting numerous rental returns.Case # 14A7710----------
FIRE ALARMS	7/6/2014 20:38	7/6/2014 20:11	7/6/2014 20:11	Joe Carney	1939- Alarm sensor went off in CTB concourse D at FIGS.Sensor was over grill hood.Workers were cleaning grill and steam set it off.1079 responded and reset.CC made announcements.
FIRE ALARMS	7/7/2014 21:20	7/7/2014 21:13	7/7/2014 21:13	Gregory Darden	2115L - All fire alarms in standby mode from CHRP. Demo work is taking place.
FIRE ALARMS	7/8/2014 4:30	7/8/2014 4:04	7/8/2014 4:04	Joe Carney	2315-0400- CHRP conducted alarm testing.PAPD advised.
FIRE ALARMS	7/8/2014 7:21	7/8/2014 7:08	7/8/2014 7:08	Robert Feury	0602: Trouble alarm due to communication loss between fire panels 3rd floor east panel. Also alarm going off 4th floor FE-1 Lobby and CTB departure ticketing 39B. 0610: Smoke detector alarm on 1st floor south panel #2 CTB East going off.0622: Alarms silenced0650: All alarms re-set by PA Electricians Heating Plant has been notified and will re-set fans.
FIRE ALARMS	7/8/2014 8:19	7/8/2014 8:17	7/8/2014 8:17	Robert Feury	0744: J. Koupolos Construction draining Building 28 fire suppression system. Contact: Eric Hail 5169033264

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	7/8/2014 20:40	7/8/2014 20:37	7/8/2014 20:37	Gregory Darden	1840L - Fire alarm in Concourse C lowel level United Ops. 71 and Electric Shop responded.1850L - Alarm shut off on via United Ops fire alarm panel. False alarm. United Building Maintenance reset.
FIRE ALARMS	7/10/2014 1:48	7/10/2014 0:56	7/10/2014 0:56	Joe Carney	0035- Alarm test with PA Electric and CHRP for AMEX/MPD site.Announcement made.0130 Alarm test has been completed Announcement has been made
FIRE ALARMS	7/10/2014 20:49	7/10/2014 20:23	7/10/2014 20:23	Gregory Darden	1535L - Hangar 2 fire alarm MS panel. Alarm reset but still shows on the board. Check with United and they had no alarm. They suspect that it may be due to demolition work that is occurring in Hangar 4.
FIRE ALARMS	7/11/2014 7:38	7/11/2014 7:37	7/11/2014 7:37	Robert Feury	Work being done on fire panel in Building 28.FAA conducting testing on their fire system all day today. PAPD notified.
FIRE ALARMS	7/11/2014 8:54	7/11/2014 8:54	7/11/2014 8:54	Robert Feury	Fire testing in Hangar 11 at 0830. Fire testing complete at 0855.
FIRE ALARMS	7/11/2014 10:16	7/11/2014 10:16	7/11/2014 10:16	Robert Feury	0800: Fire alarm testing in hangar 7. 0950: Fire test complete.
FIRE ALARMS	7/12/2014 21:13	7/12/2014 7:22	7/12/2014 7:22	Robert Feury	Alarm going off in "Continental auto shop" building 85. Electricians investigating. United notified to investigate. United unable to properly fix the alarm. Spoke with Jose supervisor with United building maintenance and the water supply to the fire suppression system will be closed off and a fire watch guard will be placed.1130: ASG Guard in place for fire watch. Water suppression shut off. Alarm silenced.
FIRE ALARMS	7/12/2014 21:13	7/12/2014 21:13	7/12/2014 21:13	Gregory Darden	Alarm going off in "Continental auto shop" building 85. Electricians investigating. United notified to investigate. United unable to properly fix the alarm. Spoke with Jose supervisor with United building maintenance and the water supply to the fire suppression system will be closed off and a fire watch guard will be placed.1130: ASG Guard in place for fire watch. Water suppression shut off. Alarm silenced.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	7/12/2014 21:15	7/12/2014 21:13	7/12/2014 21:13	Gregory Darden	Alarm going off in "Continental auto shop" building 85. Electricians investigating. United notified to investigate. United unable to properly fix the alarm. Spoke with Jose supervisor with United building maintenance and the water supply to the fire suppression system will be closed off and a fire watch guard will be placed.1130: ASG Guard in place for fire watch. Water suppression shut off. Alarm silenced.++July 12 20142012L - United hired United Fire Protection make repairs to the fire alarm and suppression system. Building 85 fire alarm system is back online. PAPD E Shop advised.
FIRE ALARMS	7/15/2014 21:29	7/15/2014 21:23	7/15/2014 17:45	Rosemary Millan	1745L CTB west Concourse C entrance SD fire alarm activated. 71 PAPD 1079 responded. Concourse C tavern has fryer on and grill was smoking from cooking light smoke visible from fryer and grill negative fire condition.PA 1079 provided reset. PA Ops CC sent out advisory announcements and closing announcements; all audible and visible.
FIRE ALARMS	7/16/2014 13:04	7/16/2014 8:26	7/16/2014 8:26	Gregory Darden	0715L - Fire Alarm testing at the FAA Air Traffic Control Tower.1200L - Fire Alarm testing completed at the FAA Air Traffic Control Tower.
FIRE ALARMS	7/18/2014 2:17	7/18/2014 0:40	7/18/2014 0:40	Rosemary Millan	0040L FAA Will advises they are conducting Fire alarm testing at new ATCT0215L Testing completed.
FIRE ALARMS	7/18/2014 11:12	7/18/2014 11:05	7/18/2014 11:05	Gregory Darden	0915L - ISS Delta terminal C advised that the fire suppression system will be in bypass mode until 1500L.
FIRE ALARMS	7/18/2014 16:53	7/18/2014 16:51	7/18/2014 16:51	Robert Feury	Fire Alarm testing at Delta Terminal C from 0915 to 1418. Fuel Farm alarm testing from 0900-1015.
FIRE ALARMS	7/21/2014 12:33	7/21/2014 12:32	7/21/2014 7:35	Rosemary Millan	0735L ISS terminal C and terminal D advises fire alarm system is in bypass mode until 1600L.
FIRE ALARMS	7/21/2014 19:22	7/21/2014 19:22	7/21/2014 19:22	Joe Carney	1453- Alarm testing Term C/D concluded.
FIRE ALARMS	7/22/2014 14:25	7/22/2014 10:26	7/22/2014 8:00	Rosemary Millan	0800L Delta ISS Roger advises Terminal C and D fire suppression on bypass mode until 1400L1023L AAL conducting water flow testing at Hgr 5B.
FIRE ALARMS	7/22/2014 20:40	7/22/2014 20:40	7/22/2014 20:40	Joe Carney	2015- False alarm at Term D. ISS checked.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	7/23/2014 4:03	7/23/2014 1:22	7/23/2014 1:22	Robert Feury	0112: Fire Alarm Testing at American Express Lounge. Fire Marshall Heating Plant PA Electricians notified. Alarm testing announcements broadcast throughout terminal. 0330: Fire Alarm testing complete.
FIRE ALARMS	7/23/2014 17:01	7/23/2014 15:05	7/23/2014 15:05	Joe Carney	1430- Fire Alarms in CTB east.Responded with CHRP PAPD.False alarm during valve check.1540- False alarm at Term D.1545- False alarm at Term C.
FIRE ALARMS	7/24/2014 13:05	7/24/2014 11:27	7/24/2014 7:00	Rosemary Millan	0700L FAA is conducting testing at new ATCT until 0800L. PAPD 1079 notified.0700L CHRP is inspecting fire alarms at west side buildings Rental Car and old post office locations system in bypass mode during testing.
FIRE ALARMS	7/24/2014 21:44	7/24/2014 21:44	7/24/2014 21:44	Joe Carney	2115- term C alarm in by-pass per ISS.this is showing on panel in H-5.
FIRE ALARMS	7/25/2014 2:58	7/25/2014 2:56	7/24/2014 23:40	Robert Feury	PA Electricians conducting Fire Alarm tests in fan rooms. There will be no audible alarms. Heating Plant notified. 0230: Tests complete.
FIRE ALARMS	7/25/2014 2:59	7/25/2014 2:58	7/24/2014 21:50	Robert Feury	Per ISS fire Alarm testing in Terminal C.0257: Fire Alarm tests in C complete.
FIRE ALARMS	7/25/2014 14:03	7/25/2014 13:57	7/25/2014 7:35	Rosemary Millan	0735L CHRP Pete conducting fire alarm testing at CTB.1104L CTB testing completed.0736 J. Koto testing fire alarms at Bldg 281300L J. Koto testing completed. ISS terminal C and D fire alarm system on bypass mode for 2 to 3 hours.
FIRE ALARMS	7/26/2014 0:26	7/26/2014 0:26	7/26/2014 0:26	Robert Feury	Delta and ISS conducting live fire alarms in Terminal C.
FIRE ALARMS	7/26/2014 3:56	7/26/2014 0:47	7/26/2014 0:47	Robert Feury	Scheduled electrical shut down in Concourses B C and D is underway. This electrical shut down is causing Fire Alarms to sound in CTB East and West. PA Electricians and Heating Plant notified and responding.After approximately one hour of silence the alarms started again. Fire alarms continued until approximately 0200 with that alarm being Concourse A foam system.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	7/28/2014 20:22	7/28/2014 16:01	7/28/2014 16:01	Gregory Darden	1515L - Manual pull station showing at Stairwell 12 in Lot 2 garage. Also stairwell 14 has a water deluge alarm. The alarm was investigated and reset by CHRP and E shop. No issued found.1540L - Stairwell alarms returned. 71Gd investigated and found water flow in fire sprinkler room of stairwell 12. CHRP advised and investigated. CHRP found waterflow. Unable to make repair. CHRP advised that the alarms to stairwell 12 & 14 should be taken offline.1700L - E shop took areas offline. CHRP will make repairs tomorrow.
FIRE ALARMS	7/28/2014 23:44	7/28/2014 23:42	7/28/2014 22:25	Robert Feury	ISS Wilbur advises Terminal C fire panel will be on bypass for testing for approximately 3-4 hours. They will call when system is back on line.
FIRE ALARMS	7/30/2014 6:09	7/30/2014 6:08	7/30/2014 5:15	Rosemary Millan	0515L Terminal C fire alarm testing completed.
FIRE ALARMS	7/30/2014 11:35	7/30/2014 11:32	7/30/2014 8:19	Rosemary Millan	0819L CHRP Terry testing fire alarms at Terminal C system is in bypass mode. 1130L Terminal C fire alarms back on line
FIRE ALARMS	7/31/2014 4:22	7/31/2014 4:21	7/31/2014 4:21	Gregory Darden	0001L - Delta ISS Terminal C testing fire alarm. system offline.0031L - Delta ISS Terminal C back online.
FIRE ALARMS	7/31/2014 5:49	7/31/2014 5:48	7/20/2014 5:35	Rosemary Millan	0535L Hgr 5A fire alarm. PA 1079 notified. Negative condition.
FIRE ALARMS	8/1/2014 3:48	8/1/2014 3:07	8/1/2014 3:07	Gregory Darden	2311L - Fire alarm at Hangar 2 going off. MS panel and fire alarm showed up on the board. United contacted. They advised that the system is being worked on and there is a fire watch Aviation Safeguard in place. CHRP PAPD and Electric Shop advised.2315L - Electric Shop doing water flow test of Lot 2 and CTB. 0000L ISS Delta Terminal D in bypass mode.
FIRE ALARMS	8/1/2014 13:14	8/1/2014 13:10	8/1/2014 13:10	Robert Feury	Per R. Russo fire alarm testing in Hangar 5B at 0957.Per Joe Elliott at 1150 fire pump is secured from a trip test in 5B.
FIRE ALARMS	8/2/2014 0:58	8/2/2014 0:57	8/2/2014 0:57	Gregory Darden	0001L - Delta testing fire alarm in Terminal C.0008L - Electric Shop testing fire alarms in Parking Lot 2.
FIRE ALARMS	8/4/2014 13:11	8/4/2014 13:09	8/4/2014 7:30	Rosemary Millan	0730L PA Electrical testing fire alarms at Hgr 2 with Nick Gotlieb.
FIRE ALARMS	8/6/2014 0:24	8/6/2014 0:13	8/5/2014 21:50	Rosemary Millan	
FIRE ALARMS	8/7/2014 17:05	8/7/2014 17:04	8/7/2014 17:04	Robert Feury	Per Joe Leone Hangar 2 fire alarm system B is still off line with fire watch in place.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	8/8/2014 2:50	8/7/2014 22:21	8/7/2014 22:00	Rosemary Millan	2200L ISS Carrigan advises fire suppression system at Terminal C is in by pass mode for testing. PAPD notified. 08/08/14 @ 0230L testing completed.
FIRE ALARMS	8/9/2014 4:09	8/9/2014 0:14	8/8/2014 22:23	Rosemary Millan	Delta ISS has fire suppression at terminal c in by pass mode for testing.0030Pa Electrical has parking lot 2 in bypass mode for alarm testing.0140L PA electrical advises they have CTB west in by pass mode for testing.0207L PA Electrical advises CTB west back online.
FIRE ALARMS	8/9/2014 20:33	8/9/2014 20:15	8/9/2014 20:15	Minerva Colon	1931 hrs - Fire alarm panel activated "DAL Term D MS 2nd Primo Tavern. ISS Bldg. Mtce notified. PAPD responding.1938 hrs. - Negative condition overheard and PAPD filing report (B radio transmission).
FIRE ALARMS	8/11/2014 11:15	8/11/2014 11:15	8/11/2014 11:15	Robert Feury	Terminal C Fire Alarm testing from 0700 to 1500. Hangar 2 Fire testing 0700 to 1500.
FIRE ALARMS	8/12/2014 13:35	8/12/2014 10:01	8/12/2014 10:01	Robert Feury	Terminal C and D fire alarms on bypass from 0725 to 1500.Building 34 by AVIS fire alarms on bypass until 1300.Contact Eric Harre 516-903-32641303 Building 34 back on line.
FIRE ALARMS	8/13/2014 12:28	8/13/2014 12:25	8/13/2014 9:15	Robert Feury	Will from FAA called the ATCT Fire Alarms will be on bypass UFN for testing.0940 - Testing complete.
FIRE ALARMS	8/13/2014 18:03	8/13/2014 18:01	8/13/2014 17:35	Rosemary Millan	1735L Air Canada break room departure level smoke detector activated due to employee burnt toast.PA Ops CC sent out advisory announcements. PAPD notified. 71 responded.PA 1079 provided reset and cleaned smoke detector.1800L CTB panel reset.
FIRE ALARMS	8/14/2014 3:57	8/14/2014 3:56	8/14/2014 3:56	Joe Carney	0315- Term C/US Air bag room had alarm going off.ISS advised that system was in error due to work being done.
FIRE ALARMS	8/15/2014 2:38	8/14/2014 23:45	8/14/2014 23:45	Joe Carney	2324- Alarm testing at Term C.0220- Roof alarms went off. Call placed to ISS.2 men on roof per PIDS. Call placed to ISS.
FIRE ALARMS	8/15/2014 14:04	8/15/2014 13:53	8/15/2014 13:53	Minerva Colon	1331 hrs. - CC advises fire alarm activated - "Delta Term D - SD 2nd flr Prime Tavern". PAPD and ISS notified.1336 hrs. - ISS advises negative condition and alarm secured. PAPD notified.
FIRE ALARMS	8/18/2014 2:34	8/18/2014 2:07	8/18/2014 2:07	Joe Carney	0030- ATCT doing alarm testing.0230- test complete.
FIRE ALARMS	8/19/2014 1:29	8/18/2014 22:42	8/18/2014 22:42	Joe Carney	CHRP is doing alarm testing in PAPD building 137.Complete at 0031.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	8/19/2014 17:20	8/19/2014 17:18	8/19/2014 14:15	Rosemary Millan	1415L ISS at terminal D has fire alarm system on by pass mode for testing. PAPD notified. 1558L PA Electrical has west field lighting vault pull station off line for testing. 1710: ISS at Terminal A Efrain 718-772-4557- advises fire suppression system is in bypass mode for testing. PAPD notified.
FIRE ALARMS	8/20/2014 1:12	8/20/2014 1:11	8/20/2014 1:11	Robert Feury	Fire Alarm testing CTB Concourse A from 0000-0100. PAPD Fire Marshall PA Electricians Heating Plant notified. Audio message broadcast by CC.
FIRE ALARMS	8/20/2014 15:12	8/20/2014 15:12	8/20/2014 14:40	Rosemary Millan	1440L Eric advises fire suppression at bldg 28 is back on line.
FIRE ALARMS	8/21/2014 13:58	8/21/2014 13:45	8/21/2014 13:45	Gregory Darden	08:19L CHRP conducted fire alarm testing in the following areasHangar 7 south gateFuel farmContinental auto ShopAvis/HertzOld Post Office12:56L - FAA conducting fire pump test at the ATCT.1300L - FAA Fire alarm testing complete.
FIRE ALARMS	8/21/2014 16:31	8/21/2014 16:31	8/21/2014 16:31	Gregory Darden	1530L - fire pump alarm testing conducted by PA Terri @ building 23.
FIRE ALARMS	8/22/2014 8:56	8/22/2014 8:45	8/22/2014 8:45	Gregory Darden	0820L - CHRP conducting fire alarm testing in the CTB
FIRE ALARMS	8/23/2014 23:46	8/23/2014 23:43	8/23/2014 23:43	Gregory Darden	2245L - An alarm sounded in the CTB for United Airlines elevator shaft smoke detector. PAPD Contract Services E shop and 71 GD responded.2300L - It was deemed to be a false alarm. No fire nor smoke condition was observed. Alarm will be reset by the Electricians.
FIRE ALARMS	8/24/2014 12:28	8/24/2014 12:15	8/24/2014 12:15	Joe Carney	1210- Fire Alarm at Term D.ISS contacted for explanation.1225- alarm reset and advised that toaster was cause.
FIRE ALARMS	8/25/2014 9:57	8/25/2014 9:55	8/25/2014 9:55	Gregory Darden	0800L - CHRP conducting fire alarm testing in the CTB.
FIRE ALARMS	8/26/2014 14:44	8/26/2014 14:41	8/26/2014 14:41	Joe Carney	Alarm testing by CHRP for Hangars 1355A.0830-1248.
FIRE ALARMS	8/27/2014 13:43	8/27/2014 10:47	8/27/2014 8:16	Rosemary Millan	0816 CHRP testing fire alarms bldg 99 and at Terminal D0832L ISS at terminal C has fire suppression in bypass mode for testing.1005L PA Electrical testing fire alarms at CTB1052L CTB fire alarm testing completed. 1255L CHRP completed testing at bldg 99
FIRE ALARMS	8/28/2014 21:09	8/28/2014 16:28	8/28/2014 16:28	Joe Carney	1430- Term C testing complete. System restored.1619- Alarm testing at Old Police garage.1734- Done.2040- CC advises of alarms in Hangars 135. AAL contacted.2049- AAL advises that it was a false alarm involving a water flow.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	8/29/2014 8:21	8/29/2014 8:20	8/29/2014 8:20	Rosemary Millan	0750L CHRPPete advises fire alarm testing being conducted at CTB.
FIRE ALARMS	9/2/2014 10:35	9/2/2014 10:34	9/2/2014 10:34	Joe Carney	Alarm testing at Bld 28.
FIRE ALARMS	9/3/2014 3:58	9/3/2014 1:57	9/3/2014 1:57	Gregory Darden	0130L - CTB Fire Alarm testing conducted by the Electric Shop. Testing also conducted for the new Eddie Bauer and Tumi stores. Message sent out to all areas advising of the test.0357L - All fire alarm testing is complete.
FIRE ALARMS	9/3/2014 13:12	9/3/2014 10:47	9/3/2014 10:47	Joe Carney	1040- Fire alarms at Term C.ISS checking it out.Alarm due to pull station use by unknown person.1048- BP has a fire alarm.This is due to a filter change. They will advise when done.
FIRE ALARMS	9/5/2014 11:14	9/5/2014 9:10	9/5/2014 9:10	Joe Carney	0900- Alarm testing at P2 garage by CHRP.0940- Test complete.
FIRE ALARMS	9/6/2014 5:42	9/6/2014 2:21	9/6/2014 2:21	Gregory Darden	0130L - Fire Alarm system checked by the Electric Shop in the CTB. 0530L - CTB fire alarm system back online.
FIRE ALARMS	9/8/2014 9:39	9/8/2014 9:38	9/8/2014 9:38	Joe Carney	0825- CHRP testing alarms at Hangars 7 and 11.0834- Fire Craft testing at Buildings 28-34.
FIRE ALARMS	9/9/2014 5:40	9/9/2014 3:25	9/9/2014 3:25	Gregory Darden	2300L - PA Electricians checked fire alarm strobes for Tumi and Bijoux shops.0400L - PA Electricians completed fire alarm checks.
FIRE ALARMS	9/11/2014 0:55	9/11/2014 0:51	9/11/2014 0:51	Gregory Darden	0015L - E shop tested fire alarm horn and strobes in t he CTB. PAPD notified. Announcement sent out.0040L - E shop completed testing.
FIRE ALARMS	9/12/2014 1:00	9/12/2014 0:57	9/12/2014 0:57	Gregory Darden	0100L - CTB fire alarm testing is being conducted for Fan Room 11 & 12. PA Electricians and RE J. Spero on site for testing.
FIRE ALARMS	9/13/2014 4:29	9/13/2014 4:28	9/13/2014 4:28	Joe Carney	PA Electric doing alarm testing in Lot 2.
FIRE ALARMS	9/16/2014 8:05	9/16/2014 7:19	9/16/2014 7:19	Robert Feury	Heating Plant advises Fire Alarm testing at Building 23 for approximately 2 hours. They notified PAPD.Delta ISS advises sprinkler system testing at Building 28 until approximately 1500. They advised PAPD.
FIRE ALARMS	9/18/2014 4:16	9/18/2014 0:07	9/18/2014 0:07	Joe Carney	2345- R. Eng of Electric shop called to advise of testing to take place at 0015.0152- Work continues on departure level for MPD/Holt work area.0300- Work concluded for this morning.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	9/18/2014 12:30	9/18/2014 12:28	9/18/2014 12:28	Gregory Darden	0820L - AFA conducting fire alarm testing. CHRP and E Shop with them1230L - AFA completed smoke detector testing.
FIRE ALARMS	9/20/2014 12:05	9/20/2014 12:04	9/20/2014 9:55	Rosemary Millan	0955L FAA conducting fire alarm testing at new ATCT.1029L FAA completed testing.
FIRE ALARMS	9/24/2014 0:11	9/24/2014 0:09	9/23/2014 23:25	Robert Feury	At approximately 2325 CTB fire alarm sounded. Monitor in CC indicated the source was the American Express Lounge. 71 investigated and found that Unispace shop vacuum had reversed and sent dust into the air which caused the alarm to sound. Heating Plant and Electric shop notified. All systems were re-set.
FIRE ALARMS	9/24/2014 16:07	9/24/2014 16:06	9/24/2014 15:40	Rosemary Millan	1540L Terminal C MER1 fore alarm activated. ISS contacted and investigation showed it was a manual pull station negative fire condition. ISS providing reset.
FIRE ALARMS	9/25/2014 13:54	9/25/2014 13:08	9/25/2014 13:08	Gregory Darden	0730L - ISS reports Terminal C Fire System in bypass for sprinkler system maintenance.0805L - CHRP testing at AVIS Hertz Gate Gourmet and Flight Safety MAT/Delta Shuttle. and bldg 28
FIRE ALARMS	9/26/2014 1:02	9/26/2014 0:50	9/26/2014 0:50	Minerva Colon	2323 hrs. - Electrical 3 (Eng) advises fire alarm testing - audible and visual - will be conducted throughout the CTB. Will call back to confirm start time.0015 hrs. - Electrical 3 advised they can begin testing & PAPD advised. Ops Contract Svcs. ASG and TSA advised.0030 hrs. - CTB Fire alarm testing begins. CC issued announcement.0100 hrs. - Electrical 3 advises testing complete. OCC PAPD Contract Svcs. ASG & TSA notified. CC issued audio announcement.
FIRE ALARMS	9/26/2014 11:32	9/26/2014 10:28	9/26/2014 10:28	Gregory Darden	0800L - CTB fire alarm testing.ISS Terminal C fire alarm testing; System in bypass from 0800L until 1400L.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	9/28/2014 4:22	9/28/2014 3:49	9/28/2014 3:49	Gregory Darden	0130L - Allied Barton fire watch guard received an alarm on the Fire Panel in Hangar 5A. 71GD responded. Alarm was for Gate Gourmet.0140L - 71GD responded to Gate Gourmet. Supervisor Ed Baez escorted 71 through the building. No sign of fire or smoke condition in the Gate Gourmet facility. Trouble alarm showing on fire panel. E shop advised. They will continue to monitor alarm board. 71GD advised Mr. Baez to have a technician look at their panel fire alarm & fire control system.
FIRE ALARMS	9/30/2014 4:36	9/29/2014 23:59	9/29/2014 23:59	Robert Feury	Marketplace will be conducting fire alarm testing in CTB for new stores in Central Food Court from Midnight until approximately 0130. PAPD CHRP PA Electricians have all been notified per J. Drucker.Audio messages regarding fire alarm testing were broadcast throughout.0227: Fire Alarm tests complete.
FIRE ALARMS	9/30/2014 15:48	9/30/2014 9:44	9/30/2014 9:44	Rosemary Millan	Fire alarm manual pull station activated east end arrivals continental Air Canada. 1079 and 71 inspected all pull station and none were observed activated. PA operations CC sent out advisory announcements. 1079 out the system in bypass mode then did full reset. Unknown at this time what activated the pull station # 97-07 0700L Delta ISS advises fire suppression system is in bypass mode at terminal C and D sprinkler testing.0730L FAA conducting fire alarm testing at ATCT 1120L Fire alarm testing completed.1541L Terminal D for alarm back in service
FIRE ALARMS	9/30/2014 18:24	9/30/2014 16:16	9/30/2014 16:16	Joe Carney	1615- Electric Shop has CTB in bypass for testing.1700- Test complete.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	10/1/2014 0:10	10/1/2014 0:05	10/1/2014 0:05	Robert Feury	2240: Fire alarm in CTB. Monitor indicates CTB West Concouse C roof.Heating Plant PA Electricians and PAPD contacted by CC.Met with Heating Plant in Concourse C. Construction work by C6 drilling in progress. Workmen indicate it was not caused by dust from drilling into floor. Investigate roof with Heating Plant and found A/C unit with AC-6 Fan Fail Alarm and AC-8 Fan Fail Alarm. Contacted electricians they re-set panels contacted CHRP office they re-set fans.
FIRE ALARMS	10/1/2014 9:39	10/1/2014 9:36	10/1/2014 8:00	Rosemary Millan	0800L ISS at terminal D advises they will have the fire alarm system on bypass mode for testing PAPD notified.
FIRE ALARMS	10/2/2014 13:12	10/2/2014 8:20	10/2/2014 7:30	Rosemary Millan	0730L ISS advises terminal C and D are in bypass mode.0745L CHRP on roof concourse D0800L CHRP on roof concourse C0815L CHRP advises fire alarm testing at new pump station.1200L Hgr5A fir alarm activated. CHRP71 responded negative condition found.1252L Hgr 2 Deluge valve fire alarm activated. 71 responded. Negative condition observed.
FIRE ALARMS	10/2/2014 15:17	10/2/2014 15:05	10/2/2014 15:05	Joe Carney	1430- Term C in by-pass for testing.ISS aware.1505- Term C back on line.
FIRE ALARMS	10/3/2014 0:05	10/3/2014 0:03	10/3/2014 0:03	Robert Feury	PA Electricians notify Ops of fire alarm testing at CTB. PAPD and Heating Plant notified.0000L: Terminal D on bypass for fire alarm testing.
FIRE ALARMS	10/4/2014 3:39	10/4/2014 1:45	10/4/2014 1:45	Robert Feury	Terminal D Fire Alarms on bypass. 0300: Testing at D complete.PA Electricians working on Fire Alarms in CTB. 0330: Testing at CTB complete.
FIRE ALARMS	10/4/2014 8:34	10/4/2014 8:34	10/4/2014 8:34	Joe Carney	0830- Alarm testing for Bldg 30 by Electric Shop. PAPD advised.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	10/4/2014 20:22	10/4/2014 20:00	10/4/2014 20:00	Gregory Darden	1430L - Fire alarm for ATA carousel. E Shop called. Alarm announcements sent.1435L - 71 investigated and found that the alarm was due to a power reset by Oxford at SouthWest baggage carousel #1. E shop notified and reset panel. False Alarm announcement sent.1935L - Fire alarm for ATA carousel. E shop notified. 71 investigated and found that alarm was again attributed to Oxford working on the baggage carousel. Oxford advised to contact PA Ops if they will continue to cut or restore power to the carousel. False Alarm announcement sent.1950L - The same fire alarm was triggered. 71 responded to the location and Oxford advised that they didn't do anything this time to set the alarm off. E shop advised and will further investigate. False alarm announcement sent.
FIRE ALARMS	10/5/2014 17:10	10/5/2014 16:53	10/5/2014 16:53	Gregory Darden	1452L - A fire alarm was indicated for Delta C terminal Tavern. Delta ISS has been contacted to advise of the issue.
FIRE ALARMS	10/6/2014 10:23	10/6/2014 8:37	10/6/2014 8:37	Joe Carney	0720- Alarm testing at Term D per ISS.0725- Alarm testing at H-11 per PA.0834- Test complete.0844- H-7 alarm testing per PA.0950- Cooling Tower under test for Alarms.
FIRE ALARMS	10/7/2014 13:13	10/7/2014 9:27	10/7/2014 9:27	Joe Carney	0815- Term C in bypass for ISS.0910- B-28 in bypass for sprinkler work- HOLT.0953- CTB in bypass for Electric Shop.1030- test complete.1012- new Pump station under test.1027- test complete.1313- AAL doing alarm testing at H-3.
FIRE ALARMS	10/7/2014 19:04	10/7/2014 19:02	10/7/2014 13:50	Rosemary Millan	1350L Terminal C fire alarm testing completed.1601L testing at parking lot 2 completed.1633L testing at building 28 completed.
FIRE ALARMS	10/8/2014 7:57	10/8/2014 7:56	10/8/2014 7:56	Joe Carney	0700- Term C in bypass till 1400 per ISS.
FIRE ALARMS	10/8/2014 18:52	10/8/2014 17:18	10/8/2014 14:25	Rosemary Millan	1425L- Water flow alarm activate in terminal C. Delta ISS notified and advises they were draing a system which caused alarm. 1427L water flow alarm cleared.
FIRE ALARMS	10/9/2014 0:02	10/9/2014 0:01	10/9/2014 0:02	Gregory Darden	0002L - Delta Terminal D is conducting a fire alarm test.
FIRE ALARMS	10/10/2014 7:09	10/10/2014 7:09	10/10/2014 7:09	Joe Carney	0645- Terminal C is in bypass for testing per ISS.
FIRE ALARMS	10/10/2014 10:53	10/10/2014 10:53	10/10/2014 10:52	Joe Carney	1053- FAA conducting test at ATCT.
FIRE ALARMS	10/11/2014 1:46	10/11/2014 1:45	10/11/2014 1:45	Gregory Darden	2210L - As per ISS Terminal C fire system horn and strobes are offline.0145L - AS per ISS Terminal C fire system is back online.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	10/16/2014 0:17	10/16/2014 0:07	10/16/2014 0:07	Joe Carney	2336- Alarms sounded for Continental bag room smoke detector.Responded with PA Electric CHRP PAPD.Alarm notifications went out.Alarm closed bag belt doors.Pax had to wait for alarm reset.
FIRE ALARMS	10/16/2014 10:59	10/16/2014 8:16	10/16/2014 8:16	Gregory Darden	CHRP will be conducting fire alarm testing @ the new pump station.
FIRE ALARMS	10/17/2014 4:44	10/17/2014 4:43	10/17/2014 4:43	Robert Feury	Terminal C and D fire alarm testing begins at 2300. Fire Alarm testing ends at 0440.
FIRE ALARMS	10/18/2014 7:03	10/18/2014 6:56	10/18/2014 6:56	Gregory Darden	0633L - Received a SD CTB Continental Baggage CTB East Fire Alarm.0634L - E Shop CHRP 71 & PAPD responding. Fire alarm announcement made.0639L - 71 CHRP and PAPD on scene at United Baggage claim area of CTB east. No smoke condition. Baggage make up room inspected. No smoke detected.0646L - Electric Shop responded and reset the alarms. It was determined to be caused by idling tugs in the baggage make up area. Final announcement sent.
FIRE ALARMS	10/20/2014 9:52	10/20/2014 9:48	10/20/2014 9:48	Robert Feury	At approximately 0830 Fire Alarm in CTB was activated but did not sound. 71 responded with PAPD. Source was in Concourse C the number was PSR 170 on the panel in the CC. The sensor was located in the seating area by Gate C9. Alarm was re-set by Electricians and Heating Plant re-started HVAC systems.
FIRE ALARMS	10/20/2014 10:06	10/20/2014 10:05	10/20/2014 10:05	Robert Feury	Sprinkler head adjustment at Building 28 from 1000-1200. Contact: Ted 914-760-6225
FIRE ALARMS	10/20/2014 10:07	10/20/2014 10:06	10/20/2014 10:06	Robert Feury	0953: Peter from ISS advises Terminal C conducting Fire Alarm testing. System is in bypass mode.349-752-7017
FIRE ALARMS	10/21/2014 19:07	10/21/2014 19:05	10/21/2014 19:05	Gregory Darden	1600L - E shop doing testing at Building 137 fire alarm testing. 1800L - Fire alarm testing complete.
FIRE ALARMS	10/22/2014 1:53	10/21/2014 23:59	10/21/2014 23:59	Joe Carney	2358- Fire Marshal advises of testing in concourse A and D.Electric Shop checked in.Announcements made.0130- Test complete.
FIRE ALARMS	10/22/2014 5:02	10/22/2014 1:54	10/22/2014 1:54	Joe Carney	0154- Alarm testing at Term D. per ISS.0400- Test complete.
FIRE ALARMS	10/23/2014 3:03	10/23/2014 3:00	10/23/2014 3:00	Minerva Colon	0036 hrs. - Electric shop advises fire alarm testing will be conducted in terminal C and in terminal B concourse C. 0121 hrs. - Electric shop advises testing complete all areas.

FormHeader	UpdateDateTime	ActDateTime	SubjectDateTime	EnteredByUser	RT1
FIRE ALARMS	10/23/2014 10:43	10/23/2014 10:29	10/23/2014 10:29	Minerva Colon	0810 hrs. - ISS advises fire alarms in Terminal D will be on bypass until 1400 hrs.1040 hrs. - ISS advises fire alarms in Terminal C will be on bypass until 1400 hrs.
FIRE ALARMS	10/23/2014 16:27	10/23/2014 16:21	10/23/2014 16:21	Gregory Darden	1620L - PA Electrician conducting fire alarm testing in Hangar 7.
FIRE ALARMS	10/24/2014 1:11	10/24/2014 0:12	10/24/2014 0:12	Joe Carney	2315- ISS conducting alarm testing at Terminals C and D.0037- Electric Shop conducting testing at CTB.
FIRE ALARMS	10/24/2014 13:33	10/24/2014 13:25	10/24/2014 13:25	Minerva Colon	0628 hrs. - ISS (Delta) advises fire alarms back in service at Terminals C and D.0932 hrs. - ISS (Delta) advises fire alarms testing at Terminal C - system on by-pass.
FIRE ALARMS	10/25/2014 18:50	10/25/2014 18:40	10/25/2014 18:40	Minerva Colon	1309 hrs. - Fire alarms activated - CTB arrivals East. 1314 hrs. - CHRP (Murphy) advise negative indication of fire. He believes the alarm was triggered from heat of asphalt being used on ZA.
FIRE ALARMS	10/27/2014 11:28	10/27/2014 11:27	10/27/2014 11:27	Gregory Darden	0800 - CTB fire alarm testing in progress.O915 Roger from ISS working on Terminal D Fire alarm at the ticketing counter.1019 ISS Roger working on the Fire panel in Terminal C Fire .
FIRE ALARMS	10/27/2014 23:30	10/27/2014 23:22	10/27/2014 23:22	Joe Carney	Term C in by-pass per ISS.ISS-Corrigan 347-247-8265.
FIRE ALARMS	10/28/2014 1:20	10/28/2014 1:15	10/28/2014 1:15	Joe Carney	0005- Electric Shop doing tests in CTB.0120- test complete.
FIRE ALARMS	10/28/2014 13:28	10/28/2014 13:25	10/28/2014 13:25	Gregory Darden	0628 - Coroban from ISS called and advised that Terminal C alarm system is back online. 0746 - Jim from ASA will be checking the smoke detector in the CTB and Monitored by the heating Plant.0850- Terry from heating Plant advised he will be doing fire alarm testing at delta main and building 990935 Roger Soodeen (ISS) Working on fire alarm system till 1400 Terminal D 1235L - CHRP completed with fire alarm testing.
FIRE ALARMS	10/28/2014 22:05	10/28/2014 22:05	10/28/2014 22:05	Joe Carney	CHRP concluded testing at new pump house.
FIRE ALARMS	10/29/2014 1:27	10/28/2014 23:23	10/28/2014 23:23	Joe Carney	2315- ISS conducting alarm testing at Term C.0126- Test complete.
FIRE ALARMS	11/3/2014 13:14	11/3/2014 13:13	11/3/2014 10:45	Peter Drewniak	Terminal A put in Bypass by heating plant for testing 13:15 Terminal A back online